

Fire Suppression Systems Report



SERVICE COMPANY

ACG FIRE & SAFETY

PO BOX 148
DANSVILLE, NY 14437
Ofc (585) 728-9507
Cell (585) 957-0714

CUSTOMER

Name CALIFORNIA DUBBINS
Address Village Gate Plaza
City Schenectady NY 14617
Telephone (585) 271-2990 Store No. 1

Owner or Manager Tom BEAMON

COOKING APPLIANCE LOCATIONS: LEFT TO RIGHT

<u>15" Fryer</u>	<u>15" Fryer</u>	<u>24" 4-Burner Stove</u>
------------------	------------------	---------------------------

DATE OF SERVICE <u>7/27/2010</u>		TIME <u>2:30</u>		A.M.	P.M. <input checked="" type="checkbox"/>
ANNUAL	SEMI-ANNUAL <input checked="" type="checkbox"/>	RECHARGE	INSTALLATION	RENOVATION	
LOCATION OF SYSTEM CYLINDERS <u>on wall to left of Exhaust Hood</u>					
MANUFACTURER <u>Kings Guard</u>	MODEL NUMBER <u>GL</u>	WET <input checked="" type="checkbox"/>	DRY CHEMICAL		
CYLINDER SIZE MASTER <u>4-gallon</u>	CYLINDER SIZE SLAVE	CYLINDER SIZE SLAVE			
FUSE LINKS 360° F	FUSE LINKS 450° F <u>1</u>	FUSE LINKS 500° F	OTHER		
FUEL SHUT-OFF <input checked="" type="checkbox"/>	ELECTRIC	GAS <input checked="" type="checkbox"/>	SIZE <u>3/4"</u>		
SERIAL NUMBER	LAST HYDRO TEST DATE <u>1999</u>	LAST RECHARGE DATE <u>1999</u>			
MANUFACTURER'S MANUAL REFERENCE <u>(mills ul 300)</u>					
PAGE NUMBER:			DRAWING NUMBER:		

274-302 N. Goodman

- | | |
|----------------------------------------------------------------------|--------------------------------------------------------------------|
| 1. All appliances properly covered w/correct nozzles <u>yes</u> | 20. Replaced fuse links <u>1-4/500</u> |
| 2. Duct and plenum covered w/correct nozzles <u>yes</u> | 21. Check travel of cable nuts/S-hooks <u>yes</u> |
| 3. Check positioning of all nozzles. <u>yes</u> | 22. Piping & conduit securely bracketed <u>yes</u> |
| 4. System installed in accordance w/MFG UL listing <u>yes</u> | 23. Proper separation between fryers & flame <u>yes</u> |
| 5. Hood/duct penetrations sealed w/weld or UL device <u>yes</u> | 24. Proper clearance-flame to filters <u>yes</u> |
| 6. Check if seals intact, evidence of tampering <u>yes/no</u> | 25. Exhaust fan in operating order <u>yes</u> |
| 7. If system has been discharged, report same <u>no</u> | 26. All filters replaced <u>no</u> |
| 8. Pressure gauge in proper range (If gauged) <u>175</u> | 27. Fuel shut-off in on position <u>3/4"</u> |
| 9. Check cartridge weight (If applicable) <u>16 grams</u> <u>yes</u> | 28. Manual & remote set/seals in place <u>yes</u> |
| 10. Hydrostatic test date <u>(mills ul 300)</u> <u>1999</u> | 29. Replace systems covers <u>no</u> |
| 11. 6 year maintenance date <u>no</u> | 30. System operational & seals in place <u>ul 300</u> <u>yes</u> |
| 12. Inspect cylinder and mount <u>yes</u> | 31. Slave system operational <u>yes</u> |
| 13. Operate system from terminal link <u>(1)</u> <u>yes</u> | 32. Clean cylinder & mount <u>yes</u> |
| 14. Test for proper operation from remote <u>yes</u> | 33. Fan warning sign on hood <u>yes</u> |
| 15. Check operation of micro switch <u>no</u> | 34. Personnel instructed in manual operation of system <u>yes</u> |
| 16. Check operation of gas valve <u>3/4"</u> <u>yes</u> | 35. Proper hand portable extinguishers <u>K.I.</u> <u>yes</u> |
| 17. Clean nozzles <u>yes</u> | 36. Portable extinguishers properly serviced <u>(2)</u> <u>yes</u> |
| 18. Proper nozzle covers in place <u>yes</u> | 37. Service & Certification tag on system <u>yes</u> |
| 19. Check fuse links and clean <u>yes</u> | |

NOTE DISCREPANCIES OR DEFICIENCIES BELOW

COMMENTS:

On this date, the above system was tested and inspected in accordance with procedures of the presently adopted editions of NFPA 17, 17A, 96 and the manufacturer's manual and was operated according to these procedures with results indicated above.

X	<u>Eugene J Baith</u>	<u>E00901</u>	<u>7/27/2010</u>	<u>3:15</u>			<u>yes</u>	<u>yes</u>
	SERVICE TECHNICIAN	LICENSE NO.	DATE:	TIME:	AM	PM	CUSTOMERS AUTHORIZED AGENT	

The above service technician certifies that the system was personally inspected and found conditions to be as indicated on this report.

White - Distributor

Yellow - Customer Copy

Pink - Authority Having Jurisdiction