FD570 603605 FIRE SAFETY INSPECTION RECORD

☐ LICENSE
☐ TANK REMOVAL

GENERAL PUBLIC ED. PERMIT

LOCATION: 185 TROUP ST

DATE RECEIVED IN FIRE SAFETY: NOV 3 1986

DATE	APPOINTMENT	PERSON CONTACTED	NO ENTRY	ORDERS ISSUED	REFERRALS ISSUED	NO WORK DONE	SOME WORK DONE	OTHER	OK TO FILE	INSPECTOR
11/24/86					X			2 1) Exit from third floor 2) Are these singles or mult.	X	[signature]

Fire Safety Division
Fire Department

City of Rochester

Public Safety Building
Civic Center Plaza - 3rd Floor
Rochester, New York 14614
(716) 428-7037

BUILDING INSPECTION / COMPLAINT FORM

INCIDENT #

INSPECTION # 8

ADDRESS 185 TROUP STREET

PROPERTY OWNER URBAN PARK	ADDRESS 150 VAN AUCKER ST.	PHONE
EMERGENCY CONTACT	ADDRESS	PHONE
COMPLAINANT B/C R. GRANER	ADDRESS —	PHONE —

NFPA 901 CODES | GENERAL PROPERTY USE | SPECIFIC PROPERTY USE | STRUCTURE TYPE | STRUCTURE STATUS

A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
# = FLOOR #

BUSINESS: PHONE
NAME
OWNER
ADDRESS PHONE
EMERGENCY CONTACT PHONE

DISPOSITION by FIRE SAFETY:
NOT REQUIRED
CORRECTED
ORDERS ISSUED
REFERRED

DIRECTION, ROOM #, ETC.	NATURE of VIOLATION or COMPLAINT
	See Attached!

OFFICER PREPARING REPORT: Lt. D. J. Cavuoto	COMPANY F.S.	GROUP —	DATE 11/3/86
BUS/PROP REPRESENTATIVE:	POSITION/TITLE		DATE
FIRE SAFETY INSPECTOR: [signature]			DATE 11/24/86

FD501

COPY TO FIRE SAFETY

ROCHESTER, NEW YORK FIRE DEPARTMENT FIELD INCIDENT REPORT

ALARM

A — INCIDENT # 61004 3 — BOX # — NODE # 41040 — ADDRESS NUMBER 185 — STREET TROUP — TYPE ST — DIR

DATE MO 10 DA 29 YR 86 — DAY OF WEEK 4 — WEATHER COND 1 — TEMP 5 — ALARM TYPE 1

TIMES

FIRST ALARM

TIME OF ALARM 03:23 — CODE 9 ENGINE 03:25 — CODE 9 TRUCK 03:25 — UNDER CONTROL 03:39 — CODE 2 TIME 04:50

EXTRA UNITS SENT

TIME OF ALARM 03:30 — CODE 9 ENGINE 03:33 — CODE 9 TRUCK : — TIME OF ALARM : — CODE 9 ENGINE : — CODE 9 TRUCK :

SECOND ALARM

TIME OF ALARM : — CODE 9 ENGINE : — CODE 9 TRUCK :

RESPONSE

FIRST ALARM

UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R
E13	W	E04	W	T10	W	BC2	W								

EXTRA UNITS SENT

UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R
A01	W	P10	W												

MULTIPLE ALARM

UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R

UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R	UNIT	W/R

DESCRIPTION OF INCIDENT

INC TYPE 11 — TYPE CONST 3 — STORIES 3 — SPECIFIC PROPERTY USE 422 — MOBILE PROP TYPE — AREA OF ORG. 62 — EQUIP INV 11 — FORM OF HEAT IGN 15 — FORM MAT'L 65 — TYPE MAT'L 21 — IGN FACTOR 46 — CODE 5 1

YEAR — MAKE — MODEL — LICENSE NUMBER — SERIAL NUMBER — VOLTAGE

FIRE EXTENDED TO entire basement, all wiring, Floor Joists, & Plywood sub Floor For First Floor, up small shaft To 2nd Floor - Started by Gasoline Fumes From motor bike placed next To Furnace — EXT OF FLAME DMG 6

OWNER/OCCUPANT

OWNER INITIALS — NAME URBAN PARK — OCCUPANT INITIALS E — NAME GREGORY Family

OWNER ADDRESS NUMBER 150 — STREET VANHAUKER — TYPE — DIR — CITY — STATE — ZIP

EQUIPMENT USED

NUMBER USED BOOST	1 1/2"	1 3/4"	2 1/2"	3"	M.S.	OXY	PORT ABLE	FOAM	AMOUNT OF WATER USED	SPKLR	STAND PIPE	HYD PRESS	HYD COND	SMOKE DET	ENTRY
		2							500	0	0	1	1	4	01

AFTERMATH

DOLLAR LOSS OF PROPERTY 10 — NUMBER OF RESCUES — INJURED CIV. F.F. — DEAD CIV. F.F. — REFERRED TO: 1 FIRE SAFETY — FIRE INVESTIGATION

REMARKS Several Tenants Question only one exit From 3rd Floor Rooms Thru out This complex

RANK BC — INIT. R — NAME KRANER — GRP CPY 1 — BATT BC22 — SIGNED: R. Kraner

rev. 1/84 — RFD 101