FD570

FIRE SAFETY INSPECTION RECORD

☐ LICENSE
☐ TANK REMOVAL

GENERAL ☐
PUBLIC ED. ☐
PERMIT 379 ☐

LOCATION: 2 VANAUKER ST. Artco Industrial Laundries

1 con

DATE RECEIVED IN FIRE SAFETY: / DATE	APPOINTMENT	PERSON CONTACTED	NO ENTRY	ORDERS ISSUED	REFERRALS ISSUED	NO WORK DONE	SOME WORK DONE	OTHER	OK TO FILE	INSPECTOR
3-29-83				X						Pratt
4-6									X	Pratt

V-339

Fire Dept.
Fire Safety Division
Public Safety Bldg.
Rochester, N.Y. 14614

OFFICE OF THE
FIRE MARSHAL
TELEPHONE: 428-7037

NOTICE OF VIOLATIONS

Date March 29, 1983

Artco Industrial Laundries — Name

2 Van Auker St — Address

Inspection of premises located at same

reveals violations of the Fire Prevention Code. Orders are hereby issued for for correction of hazards listed herewith on or before: April 5 19 83

All fire extinguishers shall be inspected and hung in proper locations

OK to file

FD506

By Order of
FIRE MARSHAL

R. Pratt
Inspector

DATE of COMPLIANCE 4-6 83 Inspector R. Pratt

Regional Recycling & Resource Recovery Inc.
315 Ballentine St

FIRE DEPARTMENT
FIRE INVESTIGATION SECTION
COMPLAINT FORM

LOCATION: OK file 1-3-79 - [illegible]

OWNER: ARTCO INDUSTRIAL LAUNDRIES INC. ADDRESS 2 VAN AUKER STREET

OCCUPANT(S)

OCCUPIED AS: TELEPHONE 235-7650

NATURE OF COMPLAINT(S): THE CITY SCHOOL DISTRICT USED A HILLTONE PRODUCT SPRAY ON THEIR MOPS FROM THE ABOVE COMPANY AND ONE OF THE WORKERS CLAIMS THAT SOMEONE DROPPED A CIGARETTE ON IT AND IN A MATTER OF MINUTES IT FLARE UP.
CHARLOTTE HIGH SCHOOL IS ONE SCHOOL THAT USES THIS SPRAY

FIRE INVESTIGATION NAME F. J. Bott DATE 9-25-78