

2p-20KD

4-310



City of Rochester

FIRE SAFETY DIVISION
FOR INTERNAL USE ONLY

DATE Sept 21, 1992

PAGE ___ OF ___

BUSINESS NAME SIMEONE'S LAMINATED PRODUCTS OWNER: _____

MAILING ADDRESS 4 VAN AUKEN ST ZIP 14604 ADDRESS: _____

ADDRESS OF VIOLATIONS: 4 VAN AUKEN ST CITY: _____ ZIP _____

ATTENTION: / REINSPECTION DATE: OCT. 5, 1992

CODE VIOLATION #	DESCRIPTION and/or LOCATION OF VIOLATION
1175.1d	Propane tank shall be properly
	SECURED NEAR OVERHEAD DOOR
1162.3b	EXIT SIGNS SHALL BE ILLUMINATED

INSPECTOR: Paul O'Neil IBM # 7105



City of Rochester
FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL

Room 300
Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037

NOTICE OF VIOLATIONS

Copied

Simeone's Laminated Products Sept. 22, 1992
4 Van Auker Street
Rochester, New York 14608

PLEASE TAKE NOTICE THAT AN Inspection at 4 Van Auker Street.
Rochester, New York, reveals violation(s) of the Fire
Prevention Code of the City of Rochester and/or the Codes, Rules
and Regulations of the State of New York.

Orders are hereby issued for the violation(s) to be corrected
on or before the reinspection schedule for October 5, 1992.
Failure to comply with these orders will result in the issuance
of a Municipal Code Violation ~~Summons~~ for each uncorrected
violation with the following penalties:

	INITIAL	FAILURE TO RESPOND
1ST OFFENSE	\$ 75.00	\$150.00
2ND OFFENSE	150.00	300.00
3RD OFFENSE	375.00	750.00

During this period, the property owner continues to be
responsible and liable for any damages arising from the
violation(s).

Relevant section(s) of the New York State Uniform Fire Prevention
and Building Code (Title 9NYCRR) is wit:

1162.3b Exit signs shall be maintained in a clean and legible
condition, unobstructed by decorations, furnishings or equipment
and illuminated at all times. <CI-222>
(EXIT SIGNS SHALL BE ILLUMINATED).



City of Rochester
FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL

Room 300
Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037

NOTICE OF VIOLATIONS

PAGE 2

1175.1d Compressed gas cylinders in storage or in service shall be secured to prevent falling or being upset and shall be protected against tampering by unauthorized persons.
(PROPANE TANK SHALL BE PROPERLY SECURED NEAR OVERHEAD DOOR).

BY ORDER OF THE FIRE MARSHAL INSPECTOR

DATE OF COMPLIANCE 10/8/94 INSPECTOR

Samuel Alicata 7105



**City of Rochester
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

300 Public Safety Building
Rochester, New York 14614
(716) 428-7037

PERMIT

DATE 10/29/92

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

SIMEONE'S LAMINATED PRODUCTS
4 VAN AUKER ST

93-11092	PERMIT NUMBER
----------	------------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B08	DUST PRODUCING OPERATION	\$ 80
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 50
		TOTAL \$ 130

This PERMIT is issued and accepted on condition that all Fire Prevention Code provisions now adopted, or that may hereafter be adopted, shall be complied with, and said PERMIT will become valid only after receipt of total fee payment.

THIS PERMIT EXPIRES 11/30/93

Eugene Zittard
.....
FIRE MARSHAL

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

TREASURER 01
 1 FIRE PWN 130.00
 SUBTOTAL 130.00
 TOTAL 130.00
 CHECK 130.00
 # ITEM 1
 7727 01 0101 FEB15/93 01:32P
 TREASURER CLERK
 FEB15/93 01:32PM



FIRE SAFETY DIVISION
FOR INTERNAL USE ONLY

4-41

PAGE ____ OF ____

DATE OCT 18, 1991

BUSINESS NAME SIMEONES LAMINATED Products OWNER: _____

MAILING ADDRESS 4 VAN AUKE ST ZIP 14608 ADDRESS: _____

ADDRESS OF VIOLATIONS: 4 VAN AUKE ST CITY: _____ ZIP _____

ATTENTION: _____ REINSPECTION DATE: OCT 30, 1991

CODE VIOLATION #	DESCRIPTION and/or LOCATION OF VIOLATION
1163.13F-1	ALL FIRE EXTINGUISHERS SHALL HAVE
	UP DATED INSPECTION TAGS
1175.1d	PROPANE TANK SHALL BE PROPERLY
	SECURED

INSPECTOR: [Signature] IBM # 7105



City of Rochester
FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL

Room 300
Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037

NOTICE OF VIOLATIONS

Simeones Laminated Products
4 Van Auker Street
Rochester, New York 14608

October 22, 1991

PLEASE TAKE NOTICE THAT an inspection at 4 Van Auker Street, Rochester, New York reveals Violation(s) of the Fire Prevention Code of the City of Rochester and/or the Codes, Rules and Regulations of the State of New York.

Orders are hereby issued for the violation(s) to be corrected on or before the reinspection scheduled for October 30, 1991. Failure to comply with these orders will result in the issuance of a Municipal Code Violation Summons for each uncorrected violation with the following penalties:

	INITIAL	FAILURE TO RESPOND
1ST OFFENSE	\$ 50.00	\$100.00
2ND OFFENSE	100.00	200.00
3RD OFFENSE	250.00	500.00

During this period, the property owner continues to be responsible and liable for any damages arising from the violation(s).

Relevant section(s) of the New York State Uniform Fire Prevention and Building Code (Title 9NYCRR) to wit:

1163.13f-1 The provision for installation and maintenance of portable fire extinguishers shall be in accordance with this subchapter and reference standard RS 73-1.

OK

ALL FIRE EXTINGUISHERS SHALL HAVE UPDATED INSPECTION TAGS.

1175.1d Compressed gas cylinders in storage or in service shall be secured to prevent falling or being upset and shall be protected against tampering by unauthorized persons.
PROPANE TANK SHALL BE PROPERLY SECURED.

BY ORDER ON THE FIRE MARSHAL

INSPECTOR

Samuel Alicata
Samuel Alicata 7105

DATE OF COMPLIANCE 11/4/91

INSPECTOR

Samuel Alicata



CITY OF ROCHESTER

FIRE DEPARTMENT

FIRE SAFETY INVOICE

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 4 VAN AUKER ST

Table with 2 columns: Permit Number, Date, Fee Total, Date Released, Expiration Date. Values: 16779, 10/21/91, Fee Total, 11/30/92.

Table with 3 columns: Permit Code, Permit Category, Fee. Values: 5412B08, 5412B10A, DUST PRODUCING OPERATION, FLAMMABLE LQD STORAGE - CLS I, \$ 40, \$ 25.

THIS IS NOT A PERMIT

TREASURER CLERK
FEB05'92 02:37PM

TRSURER 01

1 FIRE PVN 65.00
SUBTOTAL 65.00
TOTAL 65.00
CHECK 65.00
ITEM 1

9593 01 0101 FEB05'92 02:37P

TOTAL \$ 65

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE WITH FEE PAID IN FULL TO:

CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614

NAME
MAILING ADDRESS

SIMEONE'S LAMINATED PRODUCTS
4 VAN AUKER ST
ROCHESTER NY 14605

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 4 VAN AUKER ST

09377	PERMIT NUMBER
09/14/89	DATE
90-	FEE TOTAL
9/27/89	DATE RELEASED
10/31/90	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 25
5412B10B	COMBUSTIBLE LQD STORAGE - CLS II, III	\$ 25
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 40

**THIS IS NOT
A PERMIT**

TOTAL \$ 90

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME
MAILING ADDRESS
**HAYERSTICK CO INC
P O BOX 116
ROCHESTER**

NY 14601

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



CITY OF ROCHESTER, NEW YORK
APPLICATION FOR BUILDING PERMIT

Permit Number 901273 - 15768

I. IDENTIFICATIONS (Please Print)

Location of Work (street address) 4 WAK DUKE ST Rochester, New York 14607

Owner's Name FORD STREET MISC Phone

Contractor's Name * L.V. VIKORNIK TUL FOOD Phone 414-5860

Arch./Eng. Name Phone

Applicant's Name WENBY GUCKRICKER MICH Phone 414-5860

Applicant's Address PO BOX 1177 City ROCHESTER State & Zip NY 14611

II. PROPOSED WORK (check One or More)

<input type="checkbox"/> New Const.	<input type="checkbox"/> Amusement, Tent	<input type="checkbox"/> Metal Sidings
<input type="checkbox"/> Addition	<input type="checkbox"/> Antenna	<input type="checkbox"/> Paving
<input type="checkbox"/> Alteration	<input type="checkbox"/> Awning	<input type="checkbox"/> Sign
<input type="checkbox"/> Change Use	<input type="checkbox"/> Elevator	<input type="checkbox"/> Sprinkler System
<input type="checkbox"/> Relocate	<input type="checkbox"/> Fence, Walls	<input type="checkbox"/> Stair Enclosure
<input type="checkbox"/> Demolish	<input type="checkbox"/> Fire Escape	<input type="checkbox"/> Standpipe System
<input type="checkbox"/> Other	<input type="checkbox"/> Fire-Smoke Detec.	<input type="checkbox"/> Swimming Pool
	<input type="checkbox"/> Heating, Air Cond.	<input checked="" type="checkbox"/> Tanks, Pipes & Pumps

III. COST ESTIMATE

- excluding electrical and plumbing work

- including heating, air-conditioning and elevator etc.

\$ 4,000

IV. CERTIFICATION (Sign in Presence of Plan Reviewer)

I am the owner / contractor / engineer / or owner's agent authorized by the owner to make this application.

Applicant's Signature Wendy Guckricker Date 4/12/90

V. OCCUPANCY OR USE

Residential		Non-Residential	
Present	Proposed	Present	Proposed
<input type="checkbox"/> A1 One-Family Dwelling	<input type="checkbox"/>	<input type="checkbox"/> C1 Business	<input type="checkbox"/>
<input type="checkbox"/> A2 Two-Family Dwelling	<input type="checkbox"/>	<input type="checkbox"/> C2 Mercantile	<input type="checkbox"/>
<input type="checkbox"/> Multiple Dwelling (indicate number of units) <u>340</u>		<input type="checkbox"/> C3 Industrial	<input type="checkbox"/>
<input type="checkbox"/> B1 Permanent Occupancy	<input type="checkbox"/>	<input type="checkbox"/> C4 Storage	<input type="checkbox"/>
<input type="checkbox"/> B2 Transient Occupancy	<input type="checkbox"/>	<input type="checkbox"/> C5 Assembly	<input type="checkbox"/>
<input type="checkbox"/> B3 Senior Citizens House	<input type="checkbox"/>	<input type="checkbox"/> C6 Institutional	<input type="checkbox"/>
<input type="checkbox"/> B4 Adult Res. Care Facil.	<input type="checkbox"/>	<input type="checkbox"/> C7 Miscellaneous	<input type="checkbox"/>

VI. CERTIFICATE OF OCCUPANCY YES/NO YES

VII. PERMIT FEE

Permit Fee \$ 20

VIII. PERMIT DESCRIPTION Remove (1) 6,000 gal. fuel oil tank

X. FEE PAID

1 BLDG PERM	30.00
SUBTOTAL	30.00
TOTAL	30.00
CHECK	30.00

IX. APPROVALS

Zoning Eastern P Date 4/27/90

Fire Safety Lt. Jack... Date 4/30/90

Plumbing Don 5-9-90 Date 5-9-90

D.E.S. Date

Demolition Date

Buildings Virandra K Gupta Date 5/7/90

for Commissioner of Community Development

XI. INSURANCE YES/NO 5/28/90

XII. BB / IS / (FS) / DE

XIII. PLANS YES/NO

LOCATION:

1/2 Van Acker St. SPOLETA CONST.

- LICENSE
- TANK REMOVAL
- GENERAL
- PUBLIC ED.
- PERMIT

DATE RECEIVED IN FIRE SAFETY

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OKAY TO FILE

INSPECTOR

1-31-89

X

Fantigrassi

2-14-89

X


Fantigrassi

2/28/89

5/1/89

X

Fantigrassi



NOTICE OF VIOLATIONS

DATE 1/31/89

SPOLETA CONST. CO. 4 VAN ANKER ST.
Name Address

Inspection of premises located at SAME reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 2/14/89

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	<u>INITIAL</u>	<u>FAILURE TO RESPOND</u>
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9NYCR

1. A VAULT (11' x 11') IS CURRENTLY USED
FOR EXHAUSTIVE FAN WHICH BEING INSTALLED
IN THE SPRAY AREA. EXPLOSION PROOF MOTOR
AND EXHAUSTIVE FAN SHOULD BE PROVIDED
FLAMMABLE LIQUID STORAGE CABINETS
TO BE PROVIDED. 4/4/89

By Order of
FIRE MARSHAL

INSPECTOR P. J. [Signature]
Inspector P. J. [Signature]

DATE of COMPLIANCE 5/1/89

DATE/TIME January 5, 1988

DEPONENT NAME: MICHAEL PALERMO ADDRESS: 75 LYCEUM STREET

ROCHESTER, NEW YORK 14609

PHONE: Home 654-8164 Business 428-7037

Deposes and says that at about 1145 hours, on December 3rd, 1987

This Code Enforcement Officer was sent to HAVERSTICK COMPANY located at 4 VAN AUKER STREET, to inform them, that the fire department connections to the standpipe system was inaccessible due to an eight foot high barbed wire fence. At this time a Notice of Violations was issued to a MR. FRANK ZAHNISER with a time of 30 days in which to correct said violation.

On January 4th, 1988 this Code Enforcement Officer returned to HAVERSTICK COMPANY at the above stated address to find the cited violation not corrected, I spoke with DAVID J. SLEKES, Branch Manager, who state that it was not necessary to correct this violation and that it probably would not be corrected.

At 1015 hours January 4th, 1988 this Code Enforcement Officer issued a summons to HAVERSTICK COMPANY informing MR. SLEKES of his appearance at the PSB on January 20th, 1988 at 0900 hrs.

NOTICE: Any false statements made herein are punishable as a Class A Misdemeanor to Section 210.45, of the New York State Penal Law.

WITNESS Robert Steger

Michael Palermo 7398
Deponent Signature

DATE/TIME Jan 5, 1988 2:00 PM

CODE ENFORCEMENT/FIRE SAFETY

SUPPORTING DEPOSITION

ROCHESTER FIRE DEPARTMENT

DATE/TIME January 5, 1988

DEPONENT NAME: MICHAEL PALERMO ADDRESS: 75 LYCEUM STREET
ROCHESTER, NEW YORK 14609

PHONE: Home 654-8164 Business 428-7037

Deposes and says that at about 1145 hours, on December 3rd, 1987

This Code Enforcement Officer was sent to HAVERSTICK COMPANY located at 4 VAN AUKER STREET, to inform them that the fire department connections to the standpipe system was inaccessible due to an eight foot high barbed wire fence. At this time a Notice of Violations was issued to a MR. FRANK ZAHNISER with a time of 30 days in which to correct said violation.

On January 4th, 1988 this Code Enforcement Officer returned to HAVERSTICK COMPANY at the above stated address to find the cited violation not corrected, I spoke with DAVID J. SLEKES, Branch Manager, who state that it was not necessary to correct this violation and that it probably would not be corrected.

At 1015 hours January 4th, 1988 this Code Enforcement Officer issued a summons to HAVERSTICK COMPANY informing MR. SLEKES of his appearance at the PSB on January 20th, 1988 at 0900 hrs.

NOTICE: Any false statements made herein are punishable as a Class A Misdemeanor to Section 210.45, of the New York State Penal Law.

WITNESS Robert Steen

Michael Palermo 7398
Deponent Signature

DATE/TIME Jan 5 1988 2:00 PM

CODE ENFORCEMENT/FIRE SAFETY

SUPPORTING DEPOSITION

ROCHESTER FIRE DEPARTMENT

0104016

THE PEOPLE OF THE STATE OF NEW YORK - VS-

OFFICER'S COPY

Last Name (Defendant) William Parker First St M.I. _____
 Street Address 111 Park St Apt. # _____
 City Rochester State NY Zip 14609

D.O.B. _____ Sex _____ Summons Issued To _____
LICENSE INFORMATION

License # _____ Exp Date _____
 Amusmnt Cent Entmnt Cent Alarm Permit
 Taxi Driver Sol/Vendor _____
 Dog: Color _____ Breed _____ (M) (F)

VEHICLE DESCRIPTION
 Year _____ Make _____ Type _____ Clr _____ MV Reg # _____ Hk Plt# _____
PERSON ABOVE IS CHARGED AS FOLLOWS:

Place of Occurrence 4111 Park Ave St Rochester, Monroe Co., N.Y.
 Date JAN 4, 1988 Time 10:15 (A.M./P.M.)
 OFFENSE Fire Dept. Access Inaccessible
 In violation of SEC 20V-CAN SUB 111.2-1 of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place
Fire Dept. Access Inaccessible
at 4111 Park Ave St
and the inaccessible

PERSON ABOVE IS SUMMONED TO APPEAR AT:
 MUNICIPAL CODE VIOLATIONS BUREAU (ROOM 230)
 150 S. Plymouth Ave., Rochester, N.Y.
 CITY COURT PART I
 150 S. Plymouth Ave., Rochester, N.Y.

APPEARANCE DATE: JAN. day of 20th
 FINE SCHEDULE: 19 at 9 (A.M./P.M.)
 A B C D Dog

FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT C.E.D. [Signature]
 IBM 7778 SEC _____

OFFICER'S COPY



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 4 VAN AUKER ST

01665	PERMIT NUMBER
NOV 13 1986	DATE
\$60.00	FEE TOTAL
12-8-86	DATE RELEASED
10/30/87	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
-------------	-----------------	-----

5412B10A	FLAMMABLE LIQUID STORAGE	\$ 15
5412B10B	FLAMMABLE LIQUID STORAGE	\$ 15
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 30

TOTAL \$ 60


MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

NAME HAVERSTICK CO INC
MAILING ADDRESS P O BOX 116
ROCHESTER NY 14601

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



NOTICE OF VIOLATIONS

DATE Dec 3, 1987

Essential Co. Inc. 4 Van Rensselaer St.
Name Address

Inspection of premises located at 4 Van Rensselaer St. reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: Jan. 3, 1987

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	<u>INITIAL</u>	<u>FAILURE TO RESPOND</u>
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250 ^U	\$500

F.H.V. C.K.P.

1163.132-1 Fire Dept. connections shall be conspicuously identified and maintained readily accessible for fire dept. use and designed or adapted to fit equipment & specifications of the fire department.

By Order of
FIRE MARSHAL

INSPECTOR Harold Ralens ⁷³⁹⁸

DATE of COMPLIANCE 2-10-88

Inspector Robert Steger 6542

DATE 9-9-86

3

LOCATION: 00004 VAN AUKER

ST

01 OWNER: HAVERSTICK CO INC

P O BOX 116

ROCHESTER

NY 14601

OCCUPANT:

TYPE OF OPERATION:

PERSON CONTACTED: Tim Caswell

PHONE NO: 436-9770

APPOINTMENT: (Y/N)

CONDITIONS, SURROUNDINGS AND ARRANGEMENTS FOUND:

CODE	FEE	PERMIT	
5412B10A	0015	02047	FLAMMABLE LIQUID STORAGE
5412B10B	0015		FLAMMABLE LIQUID STORAGE
5412B17	0030	02048	COMBUSTIBLE MATERIAL STORAGE

REMARKS

DATE VIOLATIONS ISSUED _____ 19____ CORRECTED _____ 19____

DATE OF APPROVAL FOR PERMIT 9-9 1986 SIGNATURE: Len Palozzi

FOR OFFICE USE ONLY

DATE PERMIT ISSUED _____ 19____ DATE EXPIRED 10/30 1987

PERMIT NUMBER 1665 FEE REQ'D _____



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 4 VAN AUKER ST

03742	PERMIT NUMBER
SEP 14 1987	DATE
60-	FEE TOTAL
9/21/87	DATE RELEASED
10/30/88	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LIQUID STORAGE	\$ 15
5412B10B	COMBUSTIBLE LIQUID STORAGE	\$ 15
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 30

TOTAL \$ 60

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

NAME

MAILING ADDRESS

HAYERSTICK CO INC
P O BOX 116
ROCHESTER

NY 14601

CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

18 CE 01

3001



BUILDING INSPECTION / COMPLAINT FORM

INCIDENT #			INSPECTION #	8
ADDRESS	41 VAN AUKER ST.			
PROPERTY OWNER	Haverstick Co. INC.	ADDRESS		
EMERGENCY CONTACT		ADDRESS		
COMPLAINANT	FIRE MARSHAL	ADDRESS		

NFPA 901 CODES	GENERAL PROPERTY USE	SPECIFIC PROPERTY USE	STRUCTURE TYPE	STRUCTURE STATUS
----------------	----------------------	-----------------------	----------------	------------------

A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS: NAME _____ PHONE _____ OWNER _____ ADDRESS _____ PHONE _____	DISPOSITION by FIRE SAFETY: <input type="checkbox"/> NOT REQUIRED <input type="checkbox"/> CORRECTED <input type="checkbox"/> ORDERS ISSUED <input type="checkbox"/> REFERRED
	DIRECTION, ROOM #, ETC.	NATURE of VIOLATION or COMPLAINT

1163-13	FIRE DEP'T CONNECTION BEHIND 6' FENCE NOT READLY ACCESSIBLE TO FIRE PUMPER			
0	FIRE CONNECTION SHALL BE MOVED TO FENCE AND MADE ACCESSIBLE THROUGH FENCE.		X	

OFFICER PREPARING REPORT: IT. D. CANNY	COMPANY FS	GROUP	DATE DEC 2, 1987
BUS/PROP REPRESENTATIVE:	POSITION/TITLE		DATE
FIRE SAFETY INSPECTOR: Michael Palermo			DATE 12-3-87



BUILDING INSPECTION / COMPLAINT FORM

COMPANY E13 INSPECTION # 019524
 ADDRESS VAN AUKER ST FROM / TO 4 TAX ACCT. # 000098-06.1
 PROPERTY OWNER ROBERT E HALL ADDRESS 302 PINECREST RD PHONE 544-5270
 CITY ROCHESTER STATE NY ZIP 14617
 MAILING NAME ROBERT E HALL ADDRESS 302 PINECREST RD PHONE
 CITY ROCHESTER STATE NY ZIP 14617
 EMERGENCY CONTACT ROBERT E HALL ADDRESS 302 PINECREST RD PHONE 544-5270
 CITY ROCHESTER STATE NY ZIP 14617

NFPA 901 CODES GENERAL PROPERTY USE 80 SPECIFIC PROPERTY USE 872 STRUCTURE TYPE 1 STRUCTURE STATUS 2

A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS NAME <u>HASTERSTICK & CO INC</u> PHONE BUSINESS OWNER <u>FRANK S ZAHNISER</u> <i>SARA C. ENT.</i> ADDRESS <u>4 VAN AUKER ST</u> <u>ROCHESTER NY 14605</u> PHONE <u>436 9770</u>	DISPOSITION by FIRE SAFETY:			
	BUSINESS EMERGENCY <u>FRANK S ZAHNISER</u> ADDRESS <u>130 SYLVANIA RD</u> <u>ROCHESTER NY 14618</u> PHONE <u>586 9499</u>	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
DIRECTION, ROOM #, ETC.	COMPLAINT				
	<i>None</i>				
	<i>ALTERNATE EMERGENCY CONTACTS: D. SEEKES - 44 JULIANE DR. - 247 0256</i>				

OFFICER PREPARING REPORT: *[Signature]* COMPANY E13 GROUP 3 DATE 10/26/87
 BUS/PROP REPRESENTATIVE: *[Signature]* POSITION / TITLE DATE
 FIRE SAFETY INSPECTOR: DATE

RFD 501

125210



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 4 VAN AUKER ST

08219	PERMIT NUMBER
09/02/88	DATE
60-	FEE TOTAL
9-19-88	DATE RELEASED
10/31/89	EXPIRATION DATE

PERMIT CODE

PERMIT CATEGORY

FEE

5412B10A	FLAMMABLE LIQUID STORAGE	\$ 15
5412B10B	COMBUSTIBLE LIQUID STORAGE	\$ 15
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 30

**THIS IS NOT
A PERMIT**

TOTAL \$ 60

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**


NAME

MAILING
ADDRESS

HAVERSTICK CO INC
P O BOX 116
ROCHESTER

NY 14601

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



NOTICE OF VIOLATIONS

DATE 8-13-85

Haverstick Co Inc
Name

4 Van Orskot St
Address

Inspection of premises located at Same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 8-20-85

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 N.Y.C.P.C.

1163.13 e (1) Fire extinguisher key counter shall have missing tags replaced and be updated.

1163.4 (2) Electrical wiring hanging from ceiling near branch area shall be removed or put in junction box.

(3) Missing cover on light fixture near exit door shall be replaced.

Shipping Area

1165.5 (4) Holes in wall shall be repaired.

1163.11 (5) Hanging electrical wiring shall be removed or put in junction box

By Order of
FIRE MARSHAL

503683

INSPECTOR Anthony Gallis 6579

DATE of COMPLIANCE 8-20-85

Inspector A. Gallis



NOTICE OF VIOLATIONS

DATE 8-13-85

Homerstick Co Inc
Name

4 Van Arker St
Address

Inspection of premises located at Same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 8-20-85

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 N. C. R. R.

Shop

1163.13e

(6) Fire extinguisher shall be replaced and missing tag shall be replaced.

Metals Warehouse

(7) Fire extinguisher shall be replaced and missing tag replaced.

Dan Magin

436-9770

ext 139

By Order of
FIRE MARSHAL

INSPECTOR Anthony Gallis 6519

DATE of COMPLIANCE 8-20-85

Inspector A. Gallis

FD570 503683 FIRE SAFETY INSPECTION RECORD

LICENSE
 TANK REMOVAL

GENERAL PUBLIC ED. PERMIT 1768

LOCATION: 4 Van Auler St.

Haverstick Co.

7 corr

DATE RECEIVED IN FIRE SAFETY:

DATE

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OK TO FILE

INSPECTOR

8-13-85

8-20

6519

X Yells



ADDRESS	Street	Type	Dir
BUSINESS NAME	Haverstick, Inc.		PHONE 143619770
BUSINESS OWNER	ADDRESS	PHONE 15869799	
PROPERTY OWNER	ADDRESS	PHONE	
EMERGENCY CONTACT	ADDRESS	PHONE	
COMPLAINANT	ADDRESS	PHONE	
INCIDENT #	INSPECTION #	307818	

A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	NFPA 901 PROPERTY COMPLEX CODE: <u>810</u>	DISPOSITION BY FIRE SAFETY:	
	NFPA 901 FIXED PROPERTY USE CODE: <u>872</u>	NOT REQUIRED	
DIRECTION, ROOM #, ETC.	NATURE OF VIOLATION OR COMPLAINT	CORRECTED	
		ORDERS ISSUED	
		REFERRED	
2	S.W. BUILDING OPEN JUNCTION BOX N.E. CORNER CEILING		X
2	" GAS HEATER FEEDER PIPE NEEDS CAPPING AND		X
2	" FLUE PIPE IS DISCONNECTED		X
1	NE GARAGE OF S.W. BLDG. QUESTION STORAGE OF PROPANE CYLINDERS		X

OFFICER PREPARING REPORT:	AT. Grabowski	COMPANY	ES	GROUP	3	DATE	9/20/83
BUS/PROP REPRESENTATIVE:	MR. Squier	POSITION/TITLE	EMPLOYEE			DATE	9/20/83
FIRE SAFETY INSPECTOR:	[Signature]					DATE	10/28/83

FIRE DEPARTMENT

FIRE SAFETY DIVISION

REINSPECTION REPORT

PERMIT

Location 4 VanAuker St.

Date NOV 17 1981

1 Cur

Owner Haverstick & Co., Inc.

David Slikes

436-9770

V651

Re-Inspection Dates	Talked with	Action taken	Inspector
11- 18 ²⁰	David Slikes	OK at time of inspection	W. Hauser
		OK to file	
		11/20/81	

FD208

Hauser
Fire Safety Inspector

Fire Dept.
Fire Safety Division
Public Safety Bldg.
Rochester, N.Y. 14614



U-651

OFFICE OF THE
FIRE MARSHAL

TELEPHONE: 428-7037

NOTICE OF VIOLATIONS

Date Nov 12 1981

Haverstick + Co Inc 4 Van Auler St
Name Address

Inspection of premises at Same

reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before:

Nov 19 1981

NOTE: Penalties for failing to comply listed on opposite side of this report.

David Sleskes 436-9770

① Extinguishers to be updated
in office area OK 11/81

FD 206

By Order of
FIRE MARSHAL

W. Hauser
inspector

DATE of COMPLIANCE

11/20/81

Over

Location 4 Van Antwerp St.

Construction Cement block Stories 2 Length 125 Width 20

Use of Bldg. industrial supplies warehouse and offices 2nd floor

Fire Extinguishers: No. and Kind 6 dry chemical 2 Co₂

Floor Openings Other Than Stairs or Elevators: scuttle hole SW corner to roof

How Protected? metal door

Heating Apparatus: Type oil

Location of Floor Drains: boiler room in basement

How Can Access Be Gained to Basement? south west storage area

Main Electrical Switch: South end under basement stairs

Water Main Shut Off: center of 1st floor storage area

Gas Shut Off: South end, under basement stair landing

Air Conditioning Shut Off: ---

Special Conditions: 2nd bldg. not connected - used for storage 100' x 50'

