

✓  
**Cioppa, Geraldine M.**

---

**From:** Miranda, Isaida  
**Sent:** Thursday, January 24, 2013 12:03 PM  
**To:** Foser, Susan; Littlefield, Raymond B.; Session-Gordon, Linda; Popolizio, Margaret; Brawn, Vicki L.; Cioppa, Geraldine M.  
**Cc:** Fratta, Joseph C.; Laemlein, Jennifer K.; Altman, Karen A.; Barton, Barbara J.; Mustico, Joseph S.  
**Subject:** Ref #47489 - Request for Resolution (COM Freedom of Information System)

This is an E-mail generated from the COM Freedom of Information System. Please respond to the Communications Office with resolution.

>>>> REFERENCE# 47489 (Date Received 1/24/2013) <<<<

REQUESTOR: Peter S. Morton

PHONE: 645-8295

ORGANIZATION: Ravi Engineering

ADDRESS: 2110 S. Clinton Avenue, Rochester, NY 14618

REQUEST DESCRIPTION: 111 Buffalo Rd: tanks, permits, spills, HAZMAT, fires, incidents, environmental

# Inspection Summary

Rochester Fire Department

Building Address 0111 BUFFALO RD

## INSPECTION

**Type** Annual  
**Status** Compliant Letter Issued  
**Unit Number** T5  
**Inspected On** 09/06/2012 15:41

## SPECIAL INSTRUCTIONS

bars on second floor back windows

**Inspection ID** 28346

## INSPECTION ADDRESS

**Occupant Name** BRG CORPORATION  
**Building Name**  
**Inspection Address** 0111 BUFFALO RD  
**Alternate Address**  
**City, State and Zip** ROCHESTER, NY 14611  
**Occupant Phone** 585-235-8560

## PHONE NUMBERS

**First Person to Call** GUS TAMOUTSELIS  
**Phone** 5941349  
**Email Address**  
**Fax Number**

## OCCUPANT MAILING ADDRESS

**Mailing Name** BRG CORPORATION  
**Attention** ATTN; GUS TAMOUTSELIS  
**Address 1** 111 BUFFALO RD  
**Address 2**  
**City, State and Zip** ROCHESTER, NY 14611-

## PARCEL OWNER

**Owner / Company** TAMOUTSELIS DEMETRIIOS  
**Contact Name**  
**Parcel Address** 394 WHITTIER RD  
**City, State and Zip** SPENCERPORT, NY 14559  
**Owner Phone**

## EMERGENCY CONTACT PARCEL OWNER

**First Person to Call** GUS TAMOUTSELIS  
**Phone** 5941349

## BUILDING INFORMATION

**NFPA 901** 893 - Packaged mineral products storage.  
**Bldg Const Type** 1  
**#UNITS** 0  
**Stories**

**Sprinkler**  
**Standpipe**  
**Lock Box**

## COMMENTS

Gas shutoff NW outside corner

Alarm panel inside of EMPLOYEES door


## VIOLATION SUMMARY

Status	Violation	Location
--------	-----------	----------

GLIDE ST

**Buffalo Rd.**  
NORTH

**APPROVED**  
OF ZONING ADMINISTRATION



CITY OF ROCHESTER  
DEPT. OF BUILDINGS  
AND PROPERTY CONSERVATION

BUFFALO ROAD

N.Y., RT. 33

MAY 24 1974

PLAN  
SCALE: 1" = 40'-0"

APPROVED: *[Signature]*  
Chief of Buildings

This APPROVAL does not constitute an endorsement, architect, builder, engineer, or owner from compliance with any of the provisions of the Rochester Building Code, whether stated, implied, or certified in these plans and specifications.

1- Dns. April 1974

1- 3100 1- 4000

1- 3000 1- 4000

1- 3000 1- 1000

Pumps

Tanks removed

6-19-84

AD





# City of Rochester FIRE DEPARTMENT

FIRE SAFETY DIVISION

300 Public Safety Building  
Rochester, New York 14614  
(716) 428-7037

## PERMIT

DATE 07/02/97

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

**BUFFALO RD COLLISION**  
111 BUFFALO RD

97-	PERMIT NUMBER
-----	---------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
-------------	-----------------	-----

**Please return this part with payment - when paying in person, bring entire bill**

MAIL YOUR CHECK OR PRESENT THIS INVOICE  
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS  
ON YOUR CHECK

CITY TREASURER  
ROOM 100A, CITY HALL  
ROCHESTER, NEW YORK 14614


97	PERMIT NUMBER
07/02/97	INVOICE DATE
07/31/97	DUE DATE
\$100	AMOUNT DUE

BUFFALO RD COLLISION  
111 BUFFALO ROAD  
ROCHESTER, NY 14611

FD513

This PERMIT is issued and accepted on condition that all Fire Prevention Code provisions now adopted, or that may hereafter be adopted, shall be complied with, and said PERMIT will become valid only after receipt of total fee payment.

THIS PERMIT EXPIRES 05/31/98

  
FIRE MARSHAL

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

**Please return this part with payment - when paying in person, bring entire bill**

MAIL YOUR CHECK OR PRESENT THIS INVOICE  
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS  
ON YOUR CHECK

CITY TREASURER  
ROOM 100A, CITY HALL  
ROCHESTER, NEW YORK 14614

111 BUFFALO RD

97-	PERMIT NUMBER
07/02/97	INVOICE DATE
07/31/97	DUE DATE
\$ 100	AMOUNT DUE

BUFFALO RD COLLISION  
111 BUFFALO ROAD  
ROCHESTER

NY 14611

FD513

Permit fee payments not received by the due date will be considered delinquent.

These delinquent properties operating with invalid permits will be subject to the issuance of a Municipal Code Violations Summons pursuant to Chapter 54-10 of the Municipal Code.

Municipal Code Summons Schedule

	<b>Initial</b>	<b>Default</b>
<b>1st Offense, or after 30 days</b>	<b>\$ 75.00</b>	<b>\$150.00</b>
<b>2nd Offense, or after 60 days</b>	<b>\$150.00</b>	<b>\$300.00</b>
<b>3rd Offense, or after 90 days</b>	<b>\$375.00</b>	<b>\$750.00</b>



**City of Rochester  
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

300 Public Safety Building  
Rochester, New York 14614  
(716) 428-7037

**PERMIT**

DATE 05/18/98

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

**BUFFALO RD COLLISION**  
111 BUFFALO RD

99-05034	PERMIT NUMBER
----------	---------------


having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 50
541B18	FLAMMABLE LQD STORAGE - CLS I	\$ 50
		<i>out of business</i>
		TOTAL \$ 100

This PERMIT is issued and accepted on condition that all Fire Prevention Code provisions now adopted, or that may hereafter be adopted, shall be complied with, and said PERMIT will become valid only after receipt of total fee payment.

THIS PERMIT EXPIRES 05/31/99

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

  
FIRE MARSHAL

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

**Please return this part with payment - when paying in person, bring entire bill**

MAIL YOUR CHECK OR PRESENT THIS INVOICE  
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS  
ON YOUR CHECK

CITY TREASURER  
ROOM 100A, CITY HALL  
ROCHESTER, NEW YORK 14614

111 BUFFALO RD

99-05034	PERMIT NUMBER
05/18/98	INVOICE DATE
06/18/98	DUE DATE
\$ 100	AMOUNT DUE

BUFFALO RD COLLISION  
111 BUFFALO ROAD  
ROCHESTER

NY 14611

Permit fee payments not received by the due date will be considered delinquent.

These delinquent properties operating with invalid permits will be subject to the issuance of a Municipal Code Violations Summons pursuant to Chapter 54-10 of the Municipal Code.

Municipal Code Summons Schedule

	<b>Initial</b>	<b>Default</b>
<b>1st Offense, or after 30 days</b>	<b>\$ 75.00</b>	<b>\$150.00</b>
<b>2nd Offense, or after 60 days</b>	<b>\$150.00</b>	<b>\$300.00</b>
<b>3rd Offense, or after 90 days</b>	<b>\$375.00</b>	<b>\$750.00</b>



# City of Rochester FIRE DEPARTMENT

FIRE SAFETY DIVISION

300 Public Safety Building  
Rochester, New York 14614  
(716) 428-7037

## PERMIT

DATE 08/24/98

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY,

**PALLET EXPRESS CORP.**  
111 BUFFALO RD

99-09013	PERMIT NUMBER
----------	---------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B12A	COMPRESSED GAS - OVER 2000 CU FT	\$ 100
5412B17	COMBUSTIBLE MATERIAL STORAGE - OVER	\$ 60

**Please return this part with payment - when paying in person, bring entire bill**

MAIL YOUR CHECK OR PRESENT THIS INVOICE  
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS  
ON YOUR CHECK

CITY TREASURER  
ROOM 100A, CITY HALL  
ROCHESTER, NEW YORK 14614

111 BUFFALO RD

99-09013	PERMIT NUMBER
08/24/98	INVOICE DATE
09/24/98	DUE DATE
\$ 160	AMOUNT DUE


**PALLET EXPRESS CORP.**  
111 BUFFALO ROAD  
ROCHESTER NY 14611

FD513

THIS PERMIT IS ISSUED UNDER THE FIRE PREVENTION CODE OF THE CITY OF ROCHESTER, NY, AND SHALL BE COMPLIED WITH, AND SAID PERMIT WILL BECOME VALID ONLY AFTER RECEIPT OF TOTAL FEE PAYMENT.

THIS PERMIT EXPIRES **09/30/99**

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

  
FIRE MARSHAL

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

**Please return this part with payment - when paying in person, bring entire bill**

MAIL YOUR CHECK OR PRESENT THIS INVOICE  
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS  
ON YOUR CHECK

CITY TREASURER  
ROOM 100A, CITY HALL  
ROCHESTER, NEW YORK 14614

111 BUFFALO RD

99-09013	PERMIT NUMBER
08/24/98	INVOICE DATE
09/24/98	DUE DATE
\$ 160	AMOUNT DUE

**PALLET EXPRESS CORP.**  
111 BUFFALO ROAD  
ROCHESTER NY 14611

FD513

Permit fee payments not received by the due date will be considered delinquent.

These delinquent properties operating with invalid permits will be subject to the issuance of a Municipal Code Violations Summons pursuant to Chapter 54-10 of the Municipal Code.

Municipal Code Summons Schedule

	Initial	Default
1st Offense, or after 30 days	\$ 75.00	\$150.00
2nd Offense, or after 60 days	\$150.00	\$300.00
3rd Offense, or after 90 days	\$375.00	\$750.00



**City of Rochester  
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

300 Public Safety Building  
Rochester, New York 14614  
(716) 428-7037

**PERMIT**

DATE 08/23/99

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY,

**PALLET EXPRESS CORP.**  
111 BUFFALO RD

00-09012	PERMIT NUMBER
----------	---------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B12A	COMPRESSED GAS - OVER 2000 CU FT	\$ 100
5412B17	COMBUSTIBLE MAT'L STRGE-OVER 10 DRMS	\$ 60

**Please return this part with payment - when paying in person, bring entire bill**

MAIL YOUR CHECK OR PRESENT THIS INVOICE  
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS

CITY TREASURER  
ROOM 100A, CITY HALL  
ROCHESTER, NEW YORK 14614

ON YOUR CHECK  
00111 BUFFALO RD

00-09012	PERMIT NUMBER
08/23/99	INVOICE DATE
09/23/99	DUE DATE
\$ 160	AMOUNT DUE

**PALLET EXPRESS CORP.**  
111 BUFFALO ROAD  
ROCHESTER NY 14611

FD513

shall be complied with, and said PERMIT will become void only when

THIS PERMIT EXPIRES **09/30/00**

FIRE MARSHAL

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

**Please return this part with payment - when paying in person, bring entire bill**

MAIL YOUR CHECK OR PRESENT THIS INVOICE  
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS

CITY TREASURER  
ROOM 100A, CITY HALL  
ROCHESTER, NEW YORK 14614

ON YOUR CHECK  
00111 BUFFALO RD

00-09012	PERMIT NUMBER
08/23/99	INVOICE DATE
09/23/99	DUE DATE
\$ 160	AMOUNT DUE

**PALLET EXPRESS CORP.**  
111 BUFFALO ROAD  
ROCHESTER NY 14611

FD513

Permit fee payments not received by the due date will be considered delinquent.

These delinquent properties operating with invalid permits will be subject to the issuance of a Municipal Code Violations Summons pursuant to Chapter 54-10 of the Municipal Code.

Municipal Code Summons Schedule

	Initial	Default
1st Offense, or after 30 days	\$ 75.00	\$150.00
2nd Offense, or after 60 days	\$150.00	\$300.00
3rd Offense, or after 90 days	\$375.00	\$750.00

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q05** INSPECTION # **09-02431**  
 ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT #  
 PROPERTY OWNER **DIMITRIOS TAMOUTSELIS** ADDRESS **394 WHITTIER RD** PHONE **235-8560**  
 CITY **SPENCERPORT** STATE **NY** ZIP **14559**  
 MAILING NAME **B R G CORPORATION** ADDRESS **111 BUFFALO RD** PHONE  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 EMERGENCY CONTACT **KOSTANTINOS TAMOUTSELIS** ADDRESS **1562 VROOM RD** PHONE **594-1349**  
 CITY **SPENCERPORT** STATE **NY** ZIP **14559**

NFPA 901 CODES GENERAL PROPERTY USE **89** SPECIFIC PROPERTY USE **893** STRUCTURE TYPE **1** STRUCTURE STATUS **2**

NO ENTRY DATES:

A = ATTIC  
C = CELLAR  
G = GARAGE  
O = OUTSIDE  
# = FLOOR #

DIRECTION ROOM #, ETC.

COMPLAINT

NO VIOLATIONS NOTED AT THIS TIME  A  B  C  D

*\* REFER TO FIRE SAFETY PROPERTY NEEDS A PERMIT FOR A CUTTING TORCH.*

BUSINESS NAME **B R G CORPORATION** PHONE  
 BUSINESS OWNER **B R G CORPORATION**  
 ADDRESS **111 BUFFALO RD** **ROCHESTER NY14611** PHONE  
 BUSINESS EMERGENCY **GUS TAMOUTSELIS**  
 ADDRESS **1562 VROOM RD** **SPENCERPORT NY14559** PHONE **738 1255**

SPECIAL INSTRUCTIONS:  
 SPECIAL HAZARDS OR CONSTRUCTION

DISPOSITION BY FIRE SAFETY:  
 REFERRED  
 ORDERS ISSUED  
 CORRECTED  
 NOT REQUIRED

Y N	Y N	Y N
<input type="checkbox"/> SPRINKLER SYSTEM	<input type="checkbox"/> FIRE/SMOKE DETECT. SYSTEM	<input type="checkbox"/> SINGLE STATION SMOKE DETECTORS
<input type="checkbox"/> STANDPIPE SYSTEM	<input type="checkbox"/> KITCHEN HOOD EXTING. SYSTEM	<input type="checkbox"/> BARS/WIRE ON WINDOWS
<input type="checkbox"/> FIRE ALARM SYSTEM	<input type="checkbox"/> OTHER FIRE EXTING. SYSTEM	<input type="checkbox"/> LOCK BOX
OFFICER PREPARING REPORT: <i>Capt Joe C...</i>	COMPANY: <b>Q05</b> DISTRICT: <b>2</b> GROUP: <b>3</b>	DATE: <b>7/31/09</b>
BUS/PROP REPRESENTATIVE: <i>...</i>	POSITION / TITLE	DATE OF REINSPECTION
FIRE SAFETY INSPECTOR:		DATE

RFD 501 REV. 1/09







BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q05**  
ADDRESS **BUFFALO RD**  
PROPERTY OWNER **DIMITRIOS TAMOUTSELIS**

FROM / TO  
**111**

INSPECTION # **02-12878**  
TAX ACCT # **087245-01.0**

MAILING NAME  
**BUFFALO ROAD GLASS & MIRROR C**

ADDRESS **111 BUFFALO RD** PHONE **235-8560**  
CITY **ROCHESTER** STATE **NY** ZIP **14611**

EMERGENCY CONTACT  
**KOSTANTINOS TAMOUTSELIS**

ADDRESS **111 BUFFALO RD** PHONE  
CITY **ROCHESTER** STATE **NY** ZIP **14611**  
ADDRESS **1562 VROOM RD** PHONE **594-1349**  
CITY **SPENCERPORT** STATE **NY** ZIP **14559**

NFPA 901 CODES	GENERAL PROPERTY USE <b>89</b>	SPECIFIC PROPERTY USE <b>893</b>	STRUCTURE TYPE <b>1</b>	STRUCTURE STATUS <b>2</b>
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

NO ENTRY DATES:

BUSINESS NAME **BUFFALO ROAD GLASS & MIRROR** PHONE  
BUSINESS OWNER ~~MARSHALL LEWIS~~ *Same as Above* **235 8560**  
ADDRESS  
PHONE **436 8830**  
BUSINESS EMERGENCY ~~MARSHALL LEWIS~~  
ADDRESS ~~312 MELVILLE ST~~ **ROCHESTER NY**  
PHONE **654 8284**

DISPOSITION by FIRE SAFETY:

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

SPECIAL INSTRUCTIONS:  
SPECIAL HAZARDS OR CONSTRUCTION

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION ROOM #, ETC.

COMPLAINT  
 NO VIOLATIONS NOTED AT THIS TIME  A  B  C  D

Y N <input checked="" type="checkbox"/> SPRINKLER SYSTEM	Y N <input checked="" type="checkbox"/> FIRE/SMOKE DETECT. SYSTEM	Y N <input checked="" type="checkbox"/> SINGLE STATION SMOKE DETECTORS
<input checked="" type="checkbox"/> STANDPIPE SYSTEM	<input checked="" type="checkbox"/> KITCHEN HOOD EXTING. SYSTEM	<input checked="" type="checkbox"/> BARS/WIRE ON WINDOWS
<input checked="" type="checkbox"/> FIRE ALARM SYSTEM	<input checked="" type="checkbox"/> OTHER FIRE EXTING. SYSTEM	<input checked="" type="checkbox"/> LOCK BOX

OFFICER PREPARING REPORT: <i>FF P. Carato</i>	COMPANY <b>Q05</b>	DISTRICT <b>2</b>	GROUP <b>2</b>	DATE <b>10/17/02</b>
BUS/PROP REPRESENTATIVE: <i>X K. Jansville</i>	POSITION / TITLE			DATE OF REINSPECTION
FIRE SAFETY INSPECTOR:				DATE

RFD 501 REV. 01/02

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q05**  
ADDRESS **BUFFALO RD**  
PROPERTY OWNER

FROM / TO  
**111**

INSPECTION # **02-12877**  
TAX ACCT #

CITY ADDRESS PHONE **000-0000**  
CITY STATE ZIP  
MAILING NAME ADDRESS PHONE  
CITY STATE ZIP  
EMERGENCY CONTACT ADDRESS PHONE **000-0000**  
CITY STATE ZIP

NFPA 901 CODES	GENERAL PROPERTY USE <input type="checkbox"/>	SPECIFIC PROPERTY USE <input type="checkbox"/>	STRUCTURE TYPE <input type="checkbox"/>	STRUCTURE STATUS <input type="checkbox"/>
----------------	---	--	---	---

NO ENTRY DATES:  A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS NAME _____ PHONE _____	DISPOSITION by FIRE SAFETY:  REFERRED ORDERS ISSUED CORRECTED NOT REQUIRED
	BUSINESS OWNER ADDRESS _____ PHONE _____	
	BUSINESS EMERGENCY ADDRESS _____ PHONE _____	
	SPECIAL INSTRUCTIONS: _____	
DIRECTION ROOM #, ETC.	SPECIAL HAZARDS OR CONSTRUCTION _____	
	COMPLAINT _____	
	<input type="checkbox"/> NO VIOLATIONS NOTED AT THIS TIME <input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	

Y N	Y N	Y N
<input type="checkbox"/> <input type="checkbox"/> SPRINKLER SYSTEM	<input type="checkbox"/> <input type="checkbox"/> FIRE/SMOKE DETECT. SYSTEM	<input type="checkbox"/> <input type="checkbox"/> SINGLE STATION SMOKE DETECTORS
<input type="checkbox"/> <input type="checkbox"/> STANDPIPE SYSTEM	<input type="checkbox"/> <input type="checkbox"/> KITCHEN HOOD EXTING. SYSTEM	<input type="checkbox"/> <input type="checkbox"/> BARS/WIRE ON WINDOWS
<input type="checkbox"/> <input type="checkbox"/> FIRE ALARM SYSTEM	<input type="checkbox"/> <input type="checkbox"/> OTHER FIRE EXTING. SYSTEM	<input type="checkbox"/> <input type="checkbox"/> LOCK BOX

OFFICER PREPARING REPORT:	COMPANY	DISTRICT	GROUP	DATE
BUS/PROP REPRESENTATIVE:	POSITION / TITLE			DATE OF REINSPECTION
FIRE SAFETY INSPECTOR:				DATE

RFD 501 REV. 01/02

BUILDING INSPECTION / COMPLAINT FORM



COMPANY ADDRESS *[Redacted]*

INSPECTION # **01 - 02591**  
TAX ACCT #

PROPERTY OWNER: **DIMITRIOS TAMOUTSELIS**  
ADDRESS: **394 WHITTEN RD**  
CITY: **SPENCERPORT** STATE: **NY** ZIP: **14559**

MAILING NAME: **BUFFALO RL GLASS**  
ADDRESS: **111 BUFFALO RD**  
CITY: **ROCHESTER** STATE: **NY** ZIP: **[Redacted]**

EMERGENCY CONTACT: **KOSTANTINOS TAMOUTSELIS**  
ADDRESS: **1562 VROOM RD**  
CITY: **SPENCERPORT** STATE: **NY** ZIP: **14559**

NFPA 901 CODES: **89** GENERAL PROPERTY USE: **893** SPECIFIC PROPERTY USE: **893** STRUCTURE TYPE: **1** STRUCTURE STATUS:

- NO ENTRY DATES:
- A = ATTIC
  - C = CELLAR
  - G = GARAGE
  - O = OUTSIDE
  - # = FLOOR #

BUSINESS NAME: **BUFFALO RL GLASS** PHONE: **[Redacted]**

BUSINESS OWNER: **DIMITRIOS TAMOUTSELIS** PHONE: **[Redacted]**

BUSINESS EMERGENCY ADDRESS: **[Redacted]** PHONE: **[Redacted]**

SPECIAL INSTRUCTIONS:

SPECIAL HARZARDS OR CONSTRUCTION:

DISPOSITION by FIRE SAFETY:			
REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED

DIRECTION ROOM #, ETC.

COMPLAINT

NO VIOLATIONS NOTED AT THIS TIME  A  B  C  D

*- apt ACETYLENE in BACK ROOM.*  
*- apt FIRE EXTINGUISHER NEEDS TO BE TESTED & REINJECTED.*  
*- apt 15 GALLONS OF GAS IN BLDG.*  
*- Flammable Liquids stored on shelves*

*Refer to FIRE SAFETY*

*[Signature]*

Y N	Y N	Y N	
<input checked="" type="checkbox"/> SPRINKLER SYSTEM	<input type="checkbox"/> FIRE/SMOKE DETECT. SYSTEM	<input checked="" type="checkbox"/> SINGLE STATION SMOKE DETECTORS	
<input checked="" type="checkbox"/> STANDPIPE SYSTEM	<input type="checkbox"/> KITCHEN HOOD EXTING. SYSTEM	<input checked="" type="checkbox"/> BARS/WIRE ON WINDOWS	
<input checked="" type="checkbox"/> FIRE ALARM SYSTEM	<input type="checkbox"/> OTHER FIRE EXTING. SYSTEM	<input checked="" type="checkbox"/> LOCK BOX	
OFFICER PREPARING REPORT: <i>[Signature]</i>	COMPANY: <b>05</b> DISTRICT: <b>B2</b> GROUP: <b>3</b>	DATE: <b>7-18-01</b>	
BUS/PROP REPRESENTATIVE: <i>[Signature]</i>	POSITION / TITLE:	DATE OF REINSPECTION:	
FIRE SAFETY INSPECTOR:		DATE:	

City of Rochester Fire Department  
Fire Safety Division  
150 Plymouth Avenue S.  
Room 300  
Rochester, NY 14614



OFFICE OF THE FIRE MARSHAL  
Telephone: 428-7037  
Fax: 428-6785

## NOTICE OF VIOLATION AND ORDER TO COMPLY

Buffalo Road Assoc.  
NAME  
111 Buffalo Road  
ADDRESS  
Rochester, N.Y. 146611  
CITY, STATE, ZIP

Date 7-26-01

all violations corrected

893

1

Inspection of the premises located at 111 Buffalo Road reveals violations of the Rochester Fire Prevention Code. Orders are hereby issued for **immediate correction** of violations listed herein. Compliance shall be verified by the Fire Marshal.

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

- 1.) Acetylene tanks shall be removed from business or for on permit.
- 2.) All fire extinguishers shall have current inspection tag 1163.132
- 3.) Added at least (2) two extra fire extinguishers in storage area. 3AH1BC NFPA 10
- 4.) All flammables shall be stored in metal cabinet with note in use with the cabinet labeled Flammable Liquid 1171.1d

Reinspect Aug 3rd, 2001

Received by: [Signature]  
NAME

President  
TITLE

7/26/01  
DATE

By Order of  
Fire Marshal

Fire Marshal [Signature]

DATE OF COMPLIANCE 8-7-01

Fire Marshal [Signature]

Q5

INSPECTION REPORT PERMIT MONTH: SEPTEMBER 2000

INSPECTION DATE: 7-10-00

LOCATION: 111 BUFFALO RD 01 OWNER: PALLET EXPRESS CORP.  
111 BUFFALO ROAD  
ROCHESTER NY 14611

OCCUPANT: TYPE OF OPERATION:

PERSON CONTACTED: FRANK CERVINI PHONE NO: APPOINTMENT: (Y/N)

(CONDITIONS, SURROUNDINGS AND ARRANGEMENTS FOUND.)

CODE	FEE	PERMIT
5412B12A	100	09012 COMPRESSED GAS - OVER 2000 CU FT
5412B17	60	CMSTBL NAT'L STRGE-OVER 2500 CU FT
<p><i>Business Moved to 1069 Lyell Ave - Vacant</i></p> <p><i>VOID</i></p>		

DATE VIOLATIONS ISSUED: CORRECTED: SIGNATURE: *J. J...*

DATE OF APPROVAL FOR PERMIT: FOR OFFICE USE ONLY DATE PERMIT ISSUED: DATE EXPIRED: 20



INSPECTION DATE: 7-10-00

LOCATION: 111 BUFFALO RD 01 OWNER: PALLET EXPRESS CORP.  
111 BUFFALO ROAD  
ROCHESTER NY 14611

OCCUPANT: \_\_\_\_\_ TYPE OF OPERATION: \_\_\_\_\_

PERSON CONTACTED: FRANK CERVINI PHONE NO: \_\_\_\_\_ APPOINTMENT: (Y/N) \_\_\_\_\_

(CONDITIONS, SURROUNDINGS AND ARRANGEMENTS FOUND)

CODE	FEE	PERMIT
5412B12A	100	09012 COMPRESSED GAS - OVER 2000 CU FT
5412B17	60	CMBSTBL MAT'L STRGE-OVER 2500 CU FT
<p><i>Business Moved to 1069 Lyell</i></p> <p><i>VOID</i></p>		

DATE VIOLATIONS ISSUED: \_\_\_\_\_ CORRECTED: \_\_\_\_\_

DATE OF APPROVAL FOR PERMIT: \_\_\_\_\_ SIGNATURE: *J. Jones*

FOR OFFICE USE ONLY

DATE PERMIT ISSUED: \_\_\_\_\_ DATE EXPIRED: \_\_\_\_\_ 20 \_\_\_\_\_

PERMIT NUMBER: \_\_\_\_\_ FEE RECD: \_\_\_\_\_

FIRE SAFETY INSPECTION RECORD

**PALLET EXPRESS**

- LICENSE
- PERMIT
- EAST
- WEST
- SPECIAL

LOCATION: *111 Buffalo Rd*

Person contacted:

Telephone #:

PERSON ABOVE IS SUMMONED TO APPEAR AT:  
MUNICIPAL CODE VIOLATIONS BUREAU  
42 South Ave., Rochester, N.Y.

DATE RECEIVED IN FIRE SAFETY:	TIME OF INSPECTION	NO ENTRY	# ORDERS ISSUED	# REFERRALS ISSUED	NO WORK DONE	# VIOLATIONS CORRECT	NO VIOLATIONS NOTED	NOTES	OK TO FILE	INSPECTOR
1-19-00	9-							Issued ticket to worker on 1-14-99 @ 11 <sup>00</sup>		JF
4-7-00	12 <sup>30</sup> 5 <sup>30</sup> AM							Viewed business tools pictures tools pictures <i>Paul 75-00</i>		JF
4-19-00								Count Default		JF
4-20-00								Issued New tickets		JF
5-10-00								9-		
6-5-00	10 <sup>26</sup>							Viewed gone marked orders for per inspection 12/7/99 Do back 6-6-00 @ 4 <sup>00</sup> PM		JF
6-7-00	11 <sup>27</sup>							All violations corrected		JF

200583

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK -VS-

Last Name (Defendant) Pallett Express Corp. M.I.   
Street Address 111 Buffalo Road  
City Rochester State N.Y. Zip 14611

LICENSE INFORMATION

D.O.B. / / Sex  Summons issued To   
License #  Exp Date / /  
 Amusement Center  Entertainment Center  Alarm Permit  
 Taxi Driver  Solicitor/Vendor  
 Dog: Color

VEHICLE DESCRIPTION

Year  Make  Type  Color  MV Reg#  Hack Plat#   
PERSON ABOVE IS CHARGED AS FOLLOWS:  
Place of Occurrence 111 Buffalo Road Rochester, Monroe Co., N.Y.  
Date 4/20/00 Time 9 AM P.M.  
OFFENSE Pallett Storage  
In violation of Chapter 9MYCRR SEC 1167 SUB 15c of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place  
Pallett requires proper  
pile storage according to  
to NFPA 231  
table C4.4

PERSON ABOVE IS SUMMONED TO APPEAR AT:

- MUNICIPAL CODE VIOLATIONS BUREAU  
42 South Ave., Rochester, N.Y.
- CITY COURT PART I (MISD'S)  
150 S. Plymouth Ave., Rochester, N.Y.
- CITY COURT PART V (VIOL'S, FEL'S)  
150 S. Plymouth Ave., Rochester, N.Y.

APPEARANCE DATE: 5-10 day of 2000  
at 9 AM P.M.  
FINE SCHEDULE: A B C D E DOG REFUSE ALARM  
FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT Jim Sands Date 4/20/00  
ID # 1114 SEC RFD

200582

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK -VS-

Last Name (Defendant) Pallett Express Corp. M.I.   
Street Address 111 Buffalo Road  
City Rochester State N.Y. Zip 14611

LICENSE INFORMATION

D.O.B. / / Sex  Summons issued To   
License #  Exp Date / /  
 Amusement Center  Entertainment Center  Alarm Permit  
 Taxi Driver  Solicitor/Vendor  
 Dog: Color

VEHICLE DESCRIPTION

Year  Make  Type  Color  MV Reg#  Hack Plat#   
PERSON ABOVE IS CHARGED AS FOLLOWS:  
Place of Occurrence 111 Buffalo Road Rochester, Monroe Co., N.Y.  
Date 4/20/00 Time 9 AM P.M.  
OFFENSE Access to all areas  
In violation of Chapter 9MYCRR SEC 1164 SUB 15a of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place  
Main aisle blocked  
by trash

PERSON ABOVE IS SUMMONED TO APPEAR AT:

- MUNICIPAL CODE VIOLATIONS BUREAU  
42 South Ave., Rochester, N.Y.
- CITY COURT PART I (MISD'S)  
150 S. Plymouth Ave., Rochester, N.Y.
- CITY COURT PART V (VIOL'S, FEL'S)  
150 S. Plymouth Ave., Rochester, N.Y.

APPEARANCE DATE: 5-10 day of 2000  
at 9 AM P.M.  
FINE SCHEDULE: A B C D E DOG REFUSE ALARM  
FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT Jim Sands Date 4-20-00  
ID # 1114 SEC RFD

205183

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK, VS.

Last Name (Defendant) Pallet Express Corp M.I.   
First   
Street Address 111 Buffalo Road  
City Rochester, N.Y. State N.Y. Zip 14611

D.O.B. / / Sex  Summons Issued To   
LICENSE INFORMATION

License # / / Exp Date / /  
 Amusement Center  Entertainment Center  Alarm Permit  
 Taxi Driver  Solicitor/Vendor   
 Dog: Color

Breed  (M) (F)

VEHICLE DESCRIPTION

Year  Make  Type  Color  MV Reg#  Hack Pl#   
PERSON ABOVE IS CHARGED AS FOLLOWS:  
Place of Occurrence 111 Buffalo Road Rochester, Monroe Co., N.Y.  
Date 4-1-80 Time  A.M./P.M.

OFFENSE Pallet Storage  
In violation of Chapter 9NYCRR SEC 1164 SUB 15c of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place

Pallet require Super  
Rule Separation  
according to NFP231  
table 54.4

PERSON ABOVE IS SUMMONED TO APPEAR AT:

- MUNICIPAL CODE VIOLATIONS BUREAU 42 South Ave., Rochester, N.Y.
- CITY COURT PART I (MISD'S) 150 S. Plymouth Ave., Rochester, N.Y.
- CITY COURT PART V (VIOL'S, FEL'S) 150 S. Plymouth Ave., Rochester, N.Y.

APPEARANCE DATE: 4-19 day of 8000 at 1 A.M./P.M.

FINE SCHEDULE: A B C D E DOG REFUSE - ALARM  
FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT Jim Donk Date 4-7-80  
ID # 1144 SEC RFD

205184

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK, VS.

Last Name (Defendant) Pallet Express Corp M.I.   
First   
Street Address 111 Buffalo Road  
City Rochester, N.Y. State N.Y. Zip 14611

D.O.B. / / Sex  Summons Issued To   
LICENSE INFORMATION

License # / / Exp Date / /  
 Amusement Center  Entertainment Center  Alarm Permit  
 Taxi Driver  Solicitor/Vendor   
 Dog: Color

Breed  (M) (F)

VEHICLE DESCRIPTION

Year  Make  Type  Color  MV Reg#  Hack Pl#   
PERSON ABOVE IS CHARGED AS FOLLOWS:  
Place of Occurrence 111 Buffalo Road Rochester, Monroe Co., N.Y.  
Date 4-1-79 Time  A.M./P.M.

OFFENSE access to all parking areas  
In violation of Chapter 9NYCRR SEC 1164 SUB 15a of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place

enter truck stored  
in main aisle

PERSON ABOVE IS SUMMONED TO APPEAR AT:

- MUNICIPAL CODE VIOLATIONS BUREAU 42 South Ave., Rochester, N.Y.
- CITY COURT PART I (MISD'S) 150 S. Plymouth Ave., Rochester, N.Y.
- CITY COURT PART V (VIOL'S, FEL'S) 150 S. Plymouth Ave., Rochester, N.Y.

APPEARANCE DATE: 4-19 day of 8000 at 1 A.M./P.M.

FINE SCHEDULE: A B C D E DOG REFUSE - ALARM  
FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT Jim Donk Date 4-7-80  
ID # 1144 SEC RFD

197893

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK -VS-

**Pallet Express Corp.**  
 Last Name (Defendant) Pallet Express Corp. First Corp. M.I.  
 Street Address 111 Buffalo Road  
Rochester N.Y.  
 City State Zip

Sex Summons Issued To  
 D.O.B. License # Exp Date  
 License Information

Amusement Center  Entertainment Center  Alarm Permit  
 Taxi Driver  Solicitor/Vendor  
 Dog: Color (M) (F)  
 Breed

VEHICLE DESCRIPTION  
 Year Make Type Color MV Reg# Hack Plt#  
 111 BuFAb Road Rochester, Monroe Co., N.Y.  
 114 100 112 AMPM  
 Date OFFENSE Wood Pallet Storage  
 In violation of Chapter 9 NYCRR SEC 1164 SUB 16C of the Code of the City of Rochester, N.Y.

PERSON ABOVE IS CHARGED AS FOLLOWS:  
 FACTUAL PART: The above named delendant did on the stated date, time and place  
All Areas of Storage of Wood Pallets shall be in accordance with Reference Standard R575-4 - NEPA 231 General Storage

PERSON ABOVE IS SUMMONED TO APPEAR AT:  
 MUNICIPAL CODE VIOLATIONS BUREAU  
 42 South Ave., Rochester, N.Y.  
 CITY COURT PART I (MISD'S)  
 150 S. Plymouth Ave., Rochester, N.Y.  
 CITY COURT PART V (VIOL'S, FEL'S)  
 150 S. Plymouth Ave., Rochester, N.Y.

APPEARANCE DATE: Jan 1977 day of 18 2000  
 at 9 A.M. P.M.  
 FINE SCHEDULE: A B C D E DOG REFUSE ALARM  
 FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW  
 COMPLAINT John Gable 1-4-00 Date  
 ID # 1144 SEC RFD

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
 (Domestic Mail Only; No Insurance Coverage Provided)

Article Sent to: John Eigner 4774

Postage \$	
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
<b>Total Postage &amp; Fees \$</b>	

Name (Please Print Clearly) (to be completed by mailer)  
 Street, Apt. No., or PO Box No.  
 City, State, ZIP+4  
 See Reverse for Instructions  
 PS Form 3800, July 1999

7099 6602 E000 0000 9000 9689 7857

Chapter 4 Storage Arrangement

4-1 Piling Procedures and Precautions.

4-1.1 Any commodities that are hazardous in combination with each other shall be stored so they cannot come into contact with each other.

4-1.2\* Safe floor loads shall not be exceeded. Where water-absorbent commodities are stored, normal floor loads shall be reduced to take into account the added weight of water that can be absorbed during fire-fighting operations.

4-2 Commodity Clearance.

4-2.1 The clearance between the top of storage and the sprinkler deflectors shall be in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

*Exception: Where modified by this standard.*

4-2.2\* Where a commodity is stored above the lower chord of roof trusses, at least 1 ft (30.5 cm) of clear space shall be maintained to allow the truss to be wetted.

*Exception: The truss is protected with 1-hour fireproofing.*

4-2.3 Storage clearance from ducts shall be maintained in accordance with NFPA 91, *Standard for Exhaust Systems for Air Conveying of Materials*, Section 2-6.

4-2.4 The clearance between stored materials and unit heaters, radiant space heaters, duct furnaces, and flues shall not be less than 3 ft (0.9 m) in all directions, or clearances shall be in accordance with those specified on the approval agency label.

4-2.5\* Clearance shall be maintained to lights and light fixtures to prevent possible ignition.

4-2.6 Sufficient clearance shall be maintained around the path of fire door travel to ensure proper operation and inspection.

4-3 Aisles.

4-3.1 Wall aisles shall be at least 24 in. (61 cm) wide in warehouses used for the storage of commodities that expand with the absorption of water.

4-3.2\* Aisles shall be maintained to retard the transfer of fire from one pile to another and to allow convenient access for fire fighting, salvage, and removal of storage.

4-4\* Storage of Idle Pallets.

4-4.1 Wood Pallets.

4-4.1.1\* Pallets shall be stored outside or in a detached structure.

*Exception: Indoor pallet storage shall be permitted in accordance with 4-4.1.2.*

4-4.1.2\* Pallets that are stored indoors shall be protected as specified in Table 4-4.1.2, Table 8-1, or Table 9-1.1.

*Exception: Where the following conditions are met:*

- (a) Pallets shall be stored no higher than 6 ft (1.8 m).
- (b) Each pallet pile of no more than four stacks shall be separated from other pallet piles by at least 8 ft (2.4 m) of clear space or 25 ft (7.6 m) of commodity.

4-4.2 Plastic Pallets.

4-4.2.1 Plastic pallets shall be stored outside or in a detached structure.

*Exception No. 1: Indoor storage of plastic pallets shall be permitted in accordance with 4-4.2.2.*

*Exception No. 2: Indoor storage of nonexpanded polyethylene solid deck pallets shall be permitted to be protected in accordance with 4-4.1.2.*

*Exception No. 3: Indoor storage of plastic pallets shall be permitted to be protected in accordance with Table 9-1.1.*

*Exception No. 4: Indoor storage of nonwood pallets that have been demonstrated to present a fire hazard equal to or less than that of idle wood pallets and that are listed for such equivalency shall be permitted to be protected in accordance with 4-4.1.2.*

4-4.2.2 Plastic pallets that are stored indoors shall be protected as follows:

- (a) Where plastic pallets are stored in cutoff rooms, the following shall apply:
  1. The cutoff rooms shall have at least one exterior wall.
  2. The plastic pallet storage shall be separated from the remainder of the building by 3-hour-rated fire walls.
  3. The storage shall be protected by sprinklers that are designed to deliver 0.60 gpm/ft<sup>2</sup> [(24.5 L/min)/m<sup>2</sup>] for the entire room or by high-expansion foam and sprinklers as specified in Section 5-2.
  4. The storage shall be piled no higher than 12 ft (3.7 m).
  5. Any steel columns shall be protected by 1-hour fireproofing or a sidewall sprinkler directed to one side of the column at the top or at the 15-ft (4.6-m) level, whichever is lower. Flow from these sprinklers used to protect columns shall be permitted to be omitted from the sprinkler system demand for hydraulic calculations.
- (b) Where plastic pallets are stored without cutoffs from other storage, the following shall apply:
  1. Plastic pallet storage shall be piled no higher than 4 ft (1.2 m).
  2. Sprinkler protection shall employ high-temperature-rated sprinklers.
  3. Each pallet pile of no more than two stacks shall be separated from other pallet piles by at least 8 ft (2.4 m) of clear space or 25 ft (7.6 m) of stored commodity.

Table 4-4.1.2 Protection for Indoor Storage of Wood Idle Pallets

Storage Height		Sprinkler Density Requirements		Area of Sprinkler Demand			
				High-Temperature-Rated Sprinklers		Ordinary-Temperature-Rated Sprinklers	
ft	m	gpm/ft <sup>2</sup>	L/min/m <sup>2</sup>	ft <sup>2</sup>	m <sup>2</sup>	ft <sup>2</sup>	m <sup>2</sup>
Up to 6	Up to 1.8	0.20	8.2	2000	186	3000	279
6 to 8	1.8 to 2.4	0.30	12.2	2500	232	4000	372
8 to 12	2.4 to 3.7	0.60	24.5	3500	325	6000	557
12 to 20	3.7 to 6.1	0.60	24.5	4500	418	—	—

7-2.2.1 The design areas for Table 7-2.2 shall be a minimum of 2500 ft<sup>2</sup> (232 m<sup>2</sup>).

*Exception No. 1: Where Table 7-2.2 permits densities and areas to be selected in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, Ordinary Hazard Group 2, any area/density obtained that curve shall be permitted.*

*Exception No. 2: The design area for closed arrays shall be permitted to be reduced to 2000 ft<sup>2</sup> (186 m<sup>2</sup>).*

7-2.2.2 Interpolation of densities between storage heights shall be permitted. Densities shall be based on the 2500 ft<sup>2</sup> (232 m<sup>2</sup>) design area. The use of "up to" in Table 7-2.2 is intended to aid in the interpolation of storage height densities. Interpolation of ceiling/roof heights shall not be permitted.

7-2.2.3 Where Table 7-2.2 requires densities of 0.4 gpm/ft<sup>2</sup> [(16.3 L/min)/m<sup>2</sup>] or greater, 1/2-in. (12.7-mm) orifice sprinklers shall not be permitted.

7-2.3 Where sprinkler protection has been designed for Group A plastics, at least 500 gpm (32 L/sec) shall be added to the density/area demand for hose streams.

7-2.4 Water supply duration (sprinkler demand plus hose streams) shall be 2 hours where storage heights are 5 ft to 20 ft (1.5 m to 6.1 m) and 2 1/2 hours where storage heights are over 20 ft up to 25 ft (6.1 m up to 7.6 m).

7-2.5\* Where dry-pipe systems are used for Group A plastics, the operating area shall be increased by 30 percent without revising the density.

### Chapter 8 Fire Protection — Large-Drop Sprinklers

8-1 **General.** Large-drop sprinklers shall be permitted for use with the hazards specified in Table 8-1.

#### 8-2 Protection Criteria.

8-2.1 Sprinkler water demand for large-drop sprinklers shall be in accordance with Table 8-1.

8-2.2 A minimum of 500 gpm (1900 L/min) shall be added to the sprinkler demand for combined large and small hose stream demand.

**Table 8-1 Large-Drop Sprinkler Data Pressure and Number of Design Sprinklers Required for Various Hazards for Large-Drop Sprinklers**

Configuration	Commodity Class	Maximum Storage Height		Maximum Building Height		Type of System	Number of Design Sprinklers by Minimum Operating Pressure [psi (bar)] (See 8-2.4.)			Hose Stream Demand		Water Supply Duration hr
		ft	m	ft	m		25 (1.7)	50 (3.4)	75 (5.2)	gpm	L/min	
Palletized	I, II, or III	25	7.6	35	10.7	Wet	15	15	15	500	1900	2
						Dry	25	25	25	—	—	—
Palletized	IV	20	6.1	30	9.1	Wet	20	15	15	500	1900	2
						Dry	NA	NA	NA	—	—	—
Palletized	Cartoned or exposed unexpanded plastics	20	6.1	30	9.1	Wet	25	15	15	500	1900	2
						Dry	NA	NA	NA	—	—	—
Palletized	Cartoned or exposed expanded plastics	18	5.5	26	7.9	Wet	NA	15	15	500	1900	2
						Dry	NA	NA	NA	—	—	—
Palletized	Idle wood pallets	20	6.1	30	9.1	Wet	15	15	15	500	1900	1 1/2
						Dry	25	25	25	—	—	—
Solid Pile	I, II, or III	20	6.1	30	9.1	Wet	15	15	15	500	1900	1 1/2
						Dry	25	25	25	—	—	—
Solid Pile	IV	20	6.1	30	9.1	Wet	NA	15	15	500	1900	1 1/2
						Dry	NA	NA	NA	—	—	—
Solid Pile	Cartoned or exposed unexpanded plastics	20	6.1	30	9.1	Wet	NA	15	15	500	1900	1 1/2
						Dry	NA	NA	NA	—	—	—

Note: NA — Not Allowed.

8-2.3 Water supply duration shall be as specified in Table 8-1.

8-2.4 Where large-drop sprinklers are installed under open wood-joint construction, their minimum operating pressure shall be 50 psi (3.4 bar).

8-2.5 The requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*, that pertain to large-drop sprinklers shall apply.

*Exception: Where modified by this standard.*

8-2.6 For the purpose of applying Table 8-1, preaction systems shall be classified as dry-pipe systems.

*Exception: Where it can be demonstrated that the detection system activating the preaction system will cause water to be discharged from sprinklers as quickly as wet systems.*

8-2.7 For wet-pipe systems, ordinary-temperature, intermediate-temperature, or high-temperature sprinklers shall be used. For dry-pipe systems, high-temperature sprinklers shall be used.

**Chapter 9 Fire Protection — Early Suppression Fast Response (ESFR) Sprinklers**

**9-1\* General.**

9-1.1 ESFR sprinklers shall be permitted to be used for the protection of commodities in accordance with Table 9-1.1.

9-1.2 The maximum ceiling/roof height of a building shall be measured to the underside of the roof deck or ceiling.

9-1.3\* ESFR sprinklers shall be permitted for use in buildings with the following types of roof construction:

- (a) Smooth ceiling
- (b) Bar joist
- (c) Beam and girder
- (d) Panel

9-1.4 Roof slope shall not exceed 2 in. per foot (51 mm per meter).

**9-2\* Water Supplies.**

9-2.1 The design area shall consist of the most hydraulically demanding area, which shall be protected by 12 sprinklers, consisting of 4 sprinklers on each of 3 branch lines. The design shall include a minimum of 960 ft<sup>2</sup> (89.2 m<sup>2</sup>).

9-2.2 A minimum of 250 gpm (946 L/min) shall be added to the sprinkler demand for combined large and small hose streams.

9-2.3 Water supply duration shall be at least 1 hour.

9-2.4 ESFR sprinklers shall be limited to wet-pipe systems.

**9-3 Sprinkler System Design.**

9-3.1 The requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*, shall apply.

*Exception: Where modified by this standard.*

**Table 9-1.1 ESFR Sprinkler Data**

Type of Storage	Commodity	Maximum Height of Storage		Maximum Ceiling/Roof Height of Building		Nominal K Factor	Sprinkler Design Pressure	
		ft	m	ft	m		psi	bar
Palletized and solid pile storage (no open-top containers or solid shelves)	1. Cartoned unexpanded plastic 2. Cartoned expanded plastic 3. Uncartoned unexpanded plastic 4. Class I, Class II, Class III, or Class IV commodities, encapsulated or unencapsulated 5. Idle wood or plastic pallets	25	7.6	30	9.1	13.5-14.5	50	3.4
	1. Cartoned or uncartoned unexpanded plastic 2. Class I, Class II, Class III, or Class IV commodities, encapsulated or unencapsulated 3. Idle wood or plastic pallets	35	10.7	40	12.2	13.5-14.5	75	5.2
	1. Cartoned or uncartoned unexpanded plastic 2. Class I, Class II, Class III, or Class IV commodities, encapsulated or unencapsulated	35	10.7	45	13.7	13.5-14.5	90	27.4
	1. Cartoned unexpanded plastic 2. Class I, Class II, Class III, or Class IV commodities, encapsulated or unencapsulated	20	6.1	25	7.6	11.0-11.5	50	3.4

tion from a small ignition source. High piling substantially increases the challenge to sprinklers and the probability of involving a large number of pallets when fire occurs. Therefore, pallets should be stored outdoors where possible.

A fire in stacks of idle plastic or wooden pallets is one of the greatest challenges to sprinklers. The undersides of the pallets create a dry area on which a fire can grow and spread to other dry or partially wet areas. The process of spreading to other dry, closely located, parallel, combustible surfaces continues until the fire bursts through the top of the stack. Once this happens, very little water is able to reach the base of the fire. The only practical method of stopping a fire in a large concentration of pallets using ceiling sprinklers is by prewetting. In high stacks, prewetting is not possible without abnormally high water supplies. The storage of empty wood pallets should not be permitted in an unsprinklered warehouse that contains other storage.

**A-4.4.1.1** See Table A-4.4.1.1.

**A-4.4.1.2** No additional protection is necessary, provided the requirements of 4-4.1.2(a) and (b) are met.

**A-4.5** For further information, see Chapter 4 of NFPA 30, *Flammable and Combustible Liquids Code*.

**A-5.1.6** The densities and areas provided in Chapters 6 and 7 are based on fire tests using standard response 1/2-in. (12.7-mm) and 17/32-in. (13.5-mm) orifice spray sprinklers.

**A-5.3.1(d)** For further information on adjacent sprinkler systems, see NFPA 13, *Standard for the Installation of Sprinkler Systems*.

**A-5.4** At windowless warehouses and where windows are scant, hydrants should be located at, or in the vicinity of, entrances.

**A-5.5** Manual fire-fighting operations in a storage warehouse are not a substitute for sprinkler operation. The sprinkler sys-

tem should be kept in operation during manual fire-fighting operations until visibility has cleared so that the fire can be seen clearly and until the extent of fire is reduced to the mop-up stage. It is essential that charged hose lines are available before venting is necessary because of a possible increase in fire intensity. Where a sprinkler valve has been closed, a responsible person should remain at the valve so it can be opened promptly if necessary. The water supply for the sprinkler system should be augmented where possible, and care should be exercised so that the water supply for the sprinkler system is not rendered ineffective by the use of excessive hose streams.

Where a private fire brigade is provided, sufficient large hose [2 1/2 in. (64 mm)] and related equipment should be available.

Information on emergency organization and preincident planning is provided in the following publications:

- (a) NFPA *Industrial Fire Brigades Training Manual*
- (b) NFPA 600, *Standard on Industrial Fire Brigades*
- (c) NFPA 1620, *Recommended Practice for Pre-Incident Planning*

**A-5.6** For further information, see NFPA 72, *National Fire Alarm Code*®.

**A-6.1** The following procedure should be followed in determining the proper density and area as specified in Chapter 6:

- (a) Determine the commodity class.
- (b) Select the density and area of application from Figure 6-2.2.2 or Figure 6-2.2.3.
- (c) Adjust the required density for storage height in accordance with Figure 6-2.2.4.
- (d) Increase the operating area by 30 percent in accordance with 6-2.2.5 where a dry-pipe system is used.

**Table A-4.4.1.1 Recommended Clearance Between Outside Idle Pallet Storage and Building**

Wall Construction		Minimum Distance of Wall from Storage					
Wall Type	Openings	Under 50 Pallets		50 to 200 Pallets		Over 200 Pallets	
		ft	m	ft	m	ft	m
Masonry	None	0	0	0	0	0	0
	Wired glass with outside sprinklers and 1-hour doors	0	0	10	3.0	20	6.1
	Wired or plain glass with outside sprinklers and 3/4-hour doors	10	3.0	20	6.1	30	9.1
Wood or metal with outside sprinklers							
Wood, metal, or other		20	6.1	30	9.1	50	15.2

**Notes:**

1. Fire-resistive protection comparable to that of the wall also should be provided for combustible eavelines, vent openings, and so forth.
2. Where pallets are stored close to a building, the height of storage should be restricted to prevent burning pallets from falling on the building.
3. Manual outside open sprinklers generally are not a reliable means of protection, unless the property is constantly attended by plant emergency personnel.
4. Open sprinklers that are controlled by a deluge valve are recommended.



PERMIT NUMBER: \_\_\_\_\_ FEE REQD: \_\_\_\_\_

INSPECTION REPORT PERMIT MONTH: SEPTEMBER 1999

INSPECTION DATE: 7-13-99

LOCATION: 111 BUFFALO RD 01 OWNER: PALLET EXPRESS CORP.  
111 BUFFALO ROAD  
ROCHESTER NY 14611

OCCUPANT: \_\_\_\_\_ TYPE OF OPERATION: \_\_\_\_\_

PERSON CONTACTED: FRANK CERVINI PHONE NO: \_\_\_\_\_ APPOINTMENT: (Y/N) \_\_\_\_\_

(CONDITIONS, SURROUNDINGS AND ARRANGEMENTS FOUND:


CODE	FEE	PERMIT
5412B12A	100	09013 COMPRESSED GAS - OVER 2000 CU FT
5412B17	60	COMBUSTIBLE MATERIAL STORAGE - OVER
<i>3 violations</i>		

DATE VIOLATIONS ISSUED: 7-13 19 99 CORRECTED: 7-20 19 99

DATE OF APPROVAL FOR PERMIT: \_\_\_\_\_ 19 \_\_\_\_\_ SIGNATURE: *J. Jank*

FOR OFFICE USE ONLY

DATE PERMIT ISSUED: \_\_\_\_\_ 19 \_\_\_\_\_ DATE EXPIRED: \_\_\_\_\_ 19 \_\_\_\_\_



# NOTICE OF VIOLATIONS

DATE 7-13-99

Pallet Express Corp.  
Name

111 Buffalo Rd  
Address

Inspection of premises located at 111 Buffalo Rd reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: \_\_\_\_\_

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	<u>INITIAL</u>	<u>FAILURE TO RESPOND</u>
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

- 1.) No Pallet or wood storage next to building shall be 20' away - last warning ok
- 2.) There shall be ample aisle space in between pallet storage ok
- 3.) all grass and weeds shall be cut around perimeter of fenced in area of pallet storage ok

By Order of  
FIRE MARSHAL

INSPECTOR Jenna A. Dudy

DATE OF COMPLIANCE 7-20-99

Inspector Jenna A. Dudy

# FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL  
PUBLIC ED  
PERMIT  
HIGH-RISE

LOCATION *111 Buffalo Blvd.*

DATE RECEIVED IN FIRE SAFETY:

DATE

APPOINTMENT

PERSON CONTACTED

NO ENTRY  
ORDERS ISSUED  
REFERRALS ISSUED  
NO WORK DONE  
SOME WORK DONE

OTHER

OK TO FILE

INSPECTOR

*3-24-99*

*go back 4-20-99*

*JS*

*4-22-99*

*7 corrected 1 to go  
go back Mon.*

*JS*

*4-26-99*

*Propane in glass  
place*

*JS*

*4-27-99*

*talked with glass  
man told to get*


*cage for propane.*

*5-4-99*

*12th*

*all violations corrected*

*JS*



# NOTICE OF VIOLATIONS

DATE 3-25-99

Pallet Express Corp  
Name

111 Buffalo Rd.  
Address

Inspection of premises located at 111 Buffalo Rd. reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: April 20<sup>th</sup> 1999

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

- 1.) Isle space shall be maintained between pallet storage OK
- 2.) There shall be no wood or pallet storage within ~~20'~~ 30' of building OK
- 3.) Maximum height of all pallets on Buffalo Street side shall not exceed fence height OK
- 4.) all storage of pallets shall be in neat piles on level ground. OK
- 5.) all propane shall be kept in a secure area outside the building at least 20' from an exit OK
- 6.) all back rows of pallets shall be piled no more than 10 ft. OK
- 7.) all weeds & wild growth shall be removed around fence area NFPA 231 OK

By Order of  
FIRE MARSHAL

INSPECTOR


James A. Dondz

DATE OF COMPLIANCE

5-4-99

Inspector

James A. Dondz



# NOTICE OF VIOLATIONS

*Buffalo Road Glass & Mirror Inc*

DATE *3-29-99*

*Pallet Express Corp*  
Name

*111 Buffalo Road*  
Address

Inspection of premises located at *111 Buffalo Road* reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: *April 20th 1999*

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	<u>INITIAL</u>	<u>FAILURE TO RESPOND</u>
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

- 1.) Inside fire separation shall be a 1 hour wall. *771 table #*  
*wall needs repair on holes in it and must be taped on both sides*  
*Ceiling must be rated from next to steel inf. OK*

By Order of  
FIRE MARSHAL

INSPECTOR

*James A. Daniels*


DATE OF COMPLIANCE

*4-22-99*

Inspector

*James A. Daniels*





# NOTICE OF VIOLATIONS

DATE 3-28-00  
~~3-28-00~~

Pallet Express  
Name

111 Buffalo Road  
Address

Inspection of premises located at 111 Buffalo Road reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: Immediate Compliance / Respect 4-7-00

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

1.) all pallets or wood product shall be stored (20')  
Twenty feet away from building; OK  
1164.15C

2.) Material should be stored in unit piles as low in height and small in area as is consistent with good practice for the materials stored. The maximum height should be determined by the stability of pile, effective reach of hose streams, combustibility of the commodity. Long narrow piles are preferred over large piles.

Pile Size:

- Fewer than 50 Pallets not needed - 20' ft. Min.
- 50-200 pallets complied with order - 30' ft. Min.
- More than 200 Pallets - 50' ft. Min.

Separation's 1164.15C

You can call Mr. Bill Richardson at 427-9231 for possibly variance for the pallet storage

By Order of  
FIRE MARSHAL

INSPECTOR

James A. Jonda

DATE OF COMPLIANCE 6-6-00

Inspector

J Jonda

# FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL  
PUBLIC ED  
PERMIT  
HIGH-RISE

LOCATION:

111 Buffalo Road

DATE RECEIVED IN FIRE SAFETY:

DATE

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OK TO FILE


INSPECTOR

12-7-99

Issued orders.  
Permit 12/21

1164.15c

JG



# NOTICE OF VIOLATIONS

DATE 12-7-99

Pallet Express Corp.  
Name

111 Buffalo Road  
Address

Inspection of premises located at 111 Buffalo Road reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: Immediate Compliance / Reinspect 12/21/99

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	<u>INITIAL</u>	<u>FAILURE TO RESPOND</u>
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

- 1.) There shall be no wood products or pallet storage a min. of 20' twenty feet away from masonry building
- 2.) all pallets shall be piled no higher than 10' ten feet in height except near roadside fence where height (max) will be fence height.
- 3.) There shall be 20' aisle way in center of storage area from masonry building to back fence.
- 4.) all storage of wood pallets shall be kept in neat piles on level ground.

1191.2a  
NFPA 231

By Order of  
FIRE MARSHAL

INSPECTOR James A. Dond

DATE OF COMPLIANCE 6-6-00

Inspector J. Dond

stored in a single location are not only dependent upon the dollar value of the commodity but also upon the total supply and availability of the material. The impact of the loss of the storage upon the ability to continue production should be considered.

### C-3 Site.

C-3.1 In selecting a site for outdoor storage, preference should be given to a location that can provide the following:

- (a) Adequate municipal fire and police protection;
- (b) An adequate public water system with hydrants suitably located for protection of the storage;
- (c) Adequate all-weather roads for fire department apparatus response;
- (d) Sufficient clear space from buildings or from other combustible storage that constitutes an exposure hazard;
- (e) Absence of flood hazard;
- (f) Adequate clearance space between storage piles and any highways, bridges, railroads, and woodlands;
- (g) Topography as level as possible to provide storage stability.

C-3.2 The entire site should be surrounded by a fence or other suitable means to prevent access of unauthorized persons. An adequate number of gates should be provided in the surrounding fence or other barriers to permit ready access of fire apparatus.

### C-4 Material Piling.

C-4.1 Materials should be stored in unit piles as low in height and small in area as is consistent with good practice for the materials stored. The maximum height should be determined by the stability of pile, effective reach of hose streams, combustibility of the commodity, and ease of pile breakdown under fire or mop-up conditions. Long narrow piles are preferred over large square piles to facilitate manual fire fighting. (The short dimension increases the effectiveness of hose streams and eases pile breakdown.)

C-4.2 Aisles should be maintained between individual piles, between piles and buildings, and between piles and the boundary line of the storage site. Sufficient driveways having the width of at least 15 ft (4.6 m) should be provided to allow the travel of fire equipment to all portions of the storage area. Aisles should be at least twice the pile height to reduce the spread of fire from pile to pile and to allow ready access for fire fighting, emergency removal of material, or salvage purposes.

C-4.3 As the commodity class increases in combustibility or where storage could be ignited easily from radiation, wider aisles should be provided. Smaller unit piles might be an alternative to wider aisles if yard space is limited.

C-4.4 For outdoor idle pallet storage, see Section 4-4 and A-4.4.1.1 of this standard. Separation between piles of idle pallets and other yard storage should be as specified in Table C-4.4.

C-4.5 Boundary posts with signs designating piling limits should be provided to indicate yard area, roadway, and aisle limits.

Table C-4.4 Pile Separation

Pile Size	Minimum Distance ft (m)
Fewer than 50 pallets	20 (6)
50-200 pallets	30 (9.1)
More than 200 pallets	50 (15.2)

### C-5 Buildings and Other Structures.

C-5.1 Yard storage, particularly storage of commodities in the higher heat release category, should have as much separation as is practical from important buildings and structures, but not less than that offered by NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*.

C-5.1.1 As guidance in using NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*, to establish clear spaces, the following Classification of Severity with Commodity Classes of this standard should be used on the basis of 100 percent openings representing yard storage:

- (a) *Light Severity*. Commodity Class I
- (b) *Moderate Severity*. Commodity Class II
- (c) Interpolate between moderate and severe severity for Commodity Class III
- (d) *Severe Severity*. Commodity Class IV and Class A plastics.

NOTE: The guidelines of C-5.1.1 apply to the equivalent commodity classes of this standard. The severity of the exposing building or structure also should be a consideration where establishing a clear space.

### C-6 Yard Maintenance and Operations.

C-6.1 The entire storage site should be kept free from accumulation of unnecessary combustible materials. Vegetation should be kept cut low. Procedures should be provided for weed control and the periodic cleanup of the yard area.

C-6.2 Adequate lighting should be provided to allow supervision of all parts of the storage area at night.

C-6.3 All electrical equipment and installations should conform to the provisions of NFPA 70, *National Electrical Code*.

C-6.4 No heating equipment should be located or used within the storage area. Salamanders, braziers, portable heaters, and other open fires should not be used.

C-6.5 Smoking should be prohibited, except in locations prominently designated as smoking areas. "No Smoking" signs should be posted in prohibited areas.

C-6.6 Welding and cutting operations should be prohibited in the storage area, unless in compliance with NFPA 51B, *Standard for Fire Prevention in Use of Cutting and Welding Processes*.

C-6.7 Tarpaulins used for protection of storage against the weather should be of fire retardant fabric.

C-6.8 Locomotives from which glowing particles could be emitted from exhaust stacks should not be permitted in the yard.

minimum required unobstructed space below sprinklers is maintained. For the evaluation of existing situations, maximum height of storage is the maximum existing height, if space between sprinklers and storage is equal to or greater than required.

**A-1-3 Compartmented.** Cartons used in most of the Factory Mutual-sponsored plastic tests involved an ordinary 200-lb (90.7-kg) test of outside corrugated cartons with five layers of vertical pieces of corrugated carton used as dividers on the inside. There were also single horizontal pieces of corrugated carton between each layer. Other tests sponsored by the Society of Plastics Industry, Industrial Risk Insurers, Factory Mutual, and Kemper used two vertical pieces of carton (not corrugated) to form an "X" in the carton for separation of product. This was not considered compartmented, as the pieces of carton used for separations were flexible (not rigid), and only two pieces were in each carton.

**A-1-3 Container.** The term container includes items such as cartons and wrappings. Fire retardant containers or tote boxes do not of themselves create a need for automatic sprinklers unless coated with oil or grease. Containers can lose their fire retardant properties if washed. For obvious reasons, they should not be exposed to rainfall.

**A-1-3 Pile Stability.** Pile stability performance has been shown to be a difficult factor to judge prior to being subjected to an actual fire. In the test work completed, compartmented cartons (see A-1-2, "Compartmented") have been shown to be stable under fire conditions. Those tests on cartons that were not compartmented tended to be unstable under fire conditions.

**A-2-1.5** The classes of plastics used in this standard basically were derived from a series of large-scale and laboratory-type small-scale fire tests using a variety of expanded and nonexpanded plastic materials. It is recognized that not all plastics in a class exhibit exactly the same characteristics while burning.

**A-3-1.1** With protection installed in accordance with this standard, fire protection of overhead steel and steel columns might not be necessary.

Consideration should be given to subdividing large-area warehouses in order to reduce the amount of merchandise that could be affected by a single fire.

It is recommended that walls or partitions be provided to separate the storage area from mercantile, manufacturing, or other occupancies to prevent the possibility of transmission of fire or smoke between the two occupancies. Door openings should be equipped with automatic-closing fire doors appropriate for the fire resistance rating of the wall or partition.

**A-3-2** Smoke removal is important to manual fire fighting and overhaul. Since most fire tests were conducted without smoke and heat venting, protection specified in Sections 5-1, 6-1, and 7-1 was developed without the use of such venting. However, venting through eave-line windows, doors, monitors, gravity, or mechanical exhaust systems is essential to smoke removal after control of the fire is achieved. (See *NFPA 204M, Guide for Smoke and Heat Venting*.)

**A-4-1.2** Commodities that are particularly susceptible to water damage should be stored on skids, dunnage, pallets, or elevated platforms in order to maintain at least 4 in. (10.2 cm) clearance from the floor.

**A-4-2.2** Protection for exposed steel structural roof members might be needed and should be provided as indicated by the authority having jurisdiction.

**A-4-2.5** Incandescent light fixtures should have shades or guards to prevent the ignition of commodity from hot bulbs where possibility of contact with storage exists.

**A-4-3.2** Storage should be separated by aisles so that piles are not more than 50 ft (15.2 m) wide or 25 ft (7.6 m) wide if they abut a wall. Main and cross aisles should be located opposite window or door openings in exterior walls. This is of particular importance in buildings where few exterior openings exist. Aisle width should be at least 8 ft (2.4 m). In judging the adequacy of existing sprinkler protection, aisle spacing and frequency should be given consideration.

**A-4-4** Idle pallet storage introduces a severe fire condition. Stacking idle pallets in piles is the best arrangement of combustibles to promote rapid spread of fire, heat release, and complete combustion. After pallets are used for a short time in warehouses, they dry out and edges become frayed and splintered. In this condition they are subject to easy ignition from a small ignition source. Again, high piling increases considerably both the challenge to sprinklers and the probability of involving a large number of pallets when fire occurs. Therefore, it is preferable to store pallets outdoors where possible.

**A-4-4.1.1** See Table A-4-4.1.1.

**Table A-4-4.1.1 Recommended Clearance Between Outside Idle Pallet Storage and Building**

Wall Construction		Minimum Distance [ft (m)] of Wall from Storage of		
Wall Type	Openings	Under 50 Pallets	50 to 200 Pallets	Over 200 Pallets
Masonry	None	0	0	0
	Wired glass with outside sprinklers 1-hr doors	0	10 (3.0)	20 (6.1)
	Wired or plain glass with outside sprinklers ¾-hr doors	10 (3.0)	20 (6.1)	30 (9.1)
Wood or metal with outside sprinklers				
Wood, metal, or other		20 (6.1)	30 (9.1)	50

**Notes:**

1. Fire-resistive protection comparable to that of the wall also should be provided for combustible cave lines, vent openings, etc.
2. Where pallets are stored close to a building, the height of storage should be restricted to prevent burning pallets from falling on the building.
3. Manual outside open sprinklers generally are not a reliable means of protection unless property is attended to at all times by plant emergency personnel.
4. Open sprinklers controlled by a deluge valve are preferred.

**A-4-4.2** A fire in stacks of idle plastic and wooden pallets is one of the greatest challenges to sprinklers. The undersides of the pallets create a dry area on which a fire can grow and expand to other dry or partially wet areas. This process of jumping to other dry, closely located, parallel, combustible surfaces continues until the fire bursts through the top of the stack. Once this happens, very little water is able to reach the base of the fire. The only practical method of stopping a fire in a large concentration of

- I. The attendant shall at all times be able to communicate with persons in the dispensing area.
- J. Dispensing nozzles used at self-service stations for the dispensing of flammable and combustible liquids shall be an approved automatic-closing type without a latch-open device.
- K. Self-service stations shall be equipped with automatic fire-extinguishing systems, installed in conformity with nationally recognized good practices and approved by the Fire Marshal.
- L. Emergency controls specified in the New York State Uniform Fire Prevention and Building Code shall be installed at a location acceptable to the Fire Marshal, but the controls shall not be more than fifty (50) feet from the dispensers. [Amended 6-27-1985, Ord. 85-263]
- M. Self-service stations shall be equipped so that the electrical supply to the dispensing units automatically shuts down whenever the fire-extinguishing system is employed.

---

#### **ARTICLE IV, Penalties; Conflicts; Severability**

---

##### **§ 54-24. Penalties for offenses. [Amended 8-9-1983, Ord. 83-345]**

Any person, firm or corporation violating any of the provisions of this chapter of the Municipal Code, known as the "Fire Prevention Code," shall be punished, upon conviction, by a fine not exceeding five hundred dollars (\$500.) or by imprisonment not exceeding fifteen (15) days, or by both such fine and imprisonment; or by a penalty of not less than twenty-five dollars (\$25.) nor more than five hundred dollars (\$500.) to be recovered by the City of Rochester in a civil action. Each day's violation shall be considered as a separate offense. Violations of this code which do not pose immediate and serious safety problems may be referred to the Municipal Code Violations Bureau and shall be subject to the penalties set forth in § 13A-11 of the Municipal Code. Referral to the Municipal Code Violations Bureau shall not preclude subsequent referral to City Court or to Housing Court of charges arising out of the same violation, and in said instances the courts shall have concurrent jurisdiction.

##### **§ 54-25. Conflicting provisions.**

The Fire Prevention Code shall be construed in accordance with the laws of the State of New York and the City of Rochester. In the event of conflict between this code and any other code applicable in the City of Rochester, that provision that provided a greater level of safety to the occupants, users or beneficiaries shall apply.

##### **§ 54-26. Severability.**

The provisions of this Fire Prevention Code and the applicability thereof to any persons, property or circumstances shall be construed to be independent and severable, and if any one (1) or more sections, clauses, sentences, provisions, portions or parts of this code, or the applicability thereof to any persons, properties or circumstances, shall be adjudged unconstitutional or invalid,

Is your RETURN ADDRESS completed on the reverse side?

**SENDER:**

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- 1.  Addressee's Address
- 2.  Restricted Delivery

3. Article Addressed to:  
*Pallet Express Inc.*  
*111 Buffalo Road*  
*Rochester, N.Y. 14611*

4a. Article Number

- 4b. Service Type
- Registered
  - Express Mail
  - Return Receipt for Merchandise
  - Certified
  - Insured
  - COD

7. Date of Delivery

8. Addressee's Address (Only if requested and fee is paid)

5. Received By: (Print Name)

6. Signature (Addressee or Agent)

Thank you for using Return Receipt Service.

# City of Rochester



Office of the Fire Marshal  
Fire Department

Room 305  
Public Safety Building  
Civic Center Plaza  
Rochester, New York 14614  
(716) 428-7037

## VOID REQUEST FOR MUNICIPAL CODE VIOLATIONS BUREAU TICKET

TICKET NUMBER: 205183

PROPERTY ADDRESS: 111 Buffalo Road


DEFENDANT'S NAME: Pallet Express

DEFENDANT'S ADDRESS: Same

REASON FOR VOID: Compliance

VOIDED BY: Jen Darch ID No. 1144

DATE: 5-6-00

  
FIRE MARSHAL

# City of Rochester



Office of the Fire Marshal  
Fire Department

Room 305  
Public Safety Building  
Civic Center Plaza  
Rochester, New York 14614  
(716) 428-7037

## VOID REQUEST FOR MUNICIPAL CODE VIOLATIONS BUREAU TICKET

TICKET NUMBER: 205184

PROPERTY ADDRESS: 111 Buffalo Road

DEFENDANT'S NAME: Pallet Express

DEFENDANT'S ADDRESS: Ferne

REASON FOR VOID: Compliance

VOIDED BY: Jim Daniels ID No. 1144

DATE: 5-6-00

  
FIRE MARSHAL









# FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL  
PUBLIC ED  
PERMIT  
HIGH-RISE

LOCATION: *111 Buffalo Rd. (Pallet Express Corp) 235-8590*

DATE RECEIVED IN FIRE SAFETY:

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

*PZAMIT*  
OTHER

OK TO FILE

INSPECTOR

**FILE**

DATE

*7/1/98*

*FRANK CORVINI*

*8*

*J.*

*7/24/98*

*RE*

*EMERGENCY #  
746-0543*

*8/28/98*

*5*

*MS*

*9/17/98*

*1*

*-HOLD-*

*MS*

*11/23/98*

*X*

*MS*

CITY OF ROCHESTER  
FIRE DEPARTMENT

APPLICATION FOR PERMIT

To use, maintain, store, manufacture, transport, install, conduct processes or carry on operations involving or creating conditions deemed hazardous to life or property.

To Fire Marshal, City of Rochester, N. Y.

Application is hereby made by the undersigned for a Permit to

Use  
Install  
Operate  
Conduct

Maintain  
Store  
Manufacture  
Transport

PALLET EXPRESS CORP. 111 BUFFALO RD

for the following materials, processes or operations.

(Describe briefly what is to be done and state what hazardous materials are to be used.)

5412 B 12 A FLAMMABLE COMPRESSED GAS #100 CO

5412 B 17 COMBUSTIBLE MATERIAL STORAGE CO CO

Conditions, surroundings and arrangements to be in accordance with the Fire Prevention Code and Rulings of the Fire Safety Division of the City of Rochester.

This application is  approved insofar as Zoning and Building Ordinances are concerned.

Zoning Administrator

Director of Buildings

FRANK CERVINI / PALLET EXPRESS CORP.

Name of Applicant

111 BUFFALO RD

Address of Applicant

ROCK NY 14611

(Insert mailing address also, if different from above)

7/2/98

Date

Complete plans and construction details must be filed on all major projects and when requested by the Fire Commissioner and/or the Fire Marshal.

**INSPECTION REPORT**

Location 111 Buffalo Rd Date 7/2/98  
Owner FERRUCARINI  
Occupant \_\_\_\_\_ Type of Operation PALETT, SALES, REPAIR STORAGE

Conditions, surroundings and arrangements found: \_\_\_\_\_

VIOLATION ISSUED SEE NOTICE ATTACHED

Required permit(s) with fee(s) SEE FRONT

Date Violations Issued 7/1/98 19 \_\_\_\_ ; Corrected \_\_\_\_\_ 19 \_\_\_\_

Date of Approval for Permit \_\_\_\_\_ 19 \_\_\_\_

Fire Safety Inspector

----- (For Office Use Only) -----

Date Permit Issued \_\_\_\_\_ Date Approved \_\_\_\_\_

Permit Number \_\_\_\_\_ Fee Required \_\_\_\_\_

Fire Marshal





minimum required unobstructed space below sprinklers is maintained. For the evaluation of existing situations, maximum height of storage is the maximum existing height, if space between sprinklers and storage is equal to or greater than required.

**A-1-3 Compartmented.** Cartons used in most of the Factory Mutual-sponsored plastic tests involved an ordinary 200-lb (90.7-kg) test of outside corrugated cartons with five layers of vertical pieces of corrugated carton used as dividers on the inside. There were also single horizontal pieces of corrugated carton between each layer. Other tests sponsored by the Society of Plastics Industry, Industrial Risk Insurers, Factory Mutual, and Kemper used two vertical pieces of carton (not corrugated) to form an "X" in the carton for separation of product. This was not considered compartmented, as the pieces of carton used for separations were flexible (not rigid), and only two pieces were in each carton.

**A-1-3 Container.** The term container includes items such as cartons and wrappings. Fire retardant containers or tote boxes do not of themselves create a need for automatic sprinklers unless coated with oil or grease. Containers can lose their fire retardant properties if washed. For obvious reasons, they should not be exposed to rainfall.

**A-1-3 Pile Stability.** Pile stability performance has been shown to be a difficult factor to judge prior to being subjected to an actual fire. In the test work completed, compartmented cartons (see A-1-2, "Compartmented") have been shown to be stable under fire conditions. Those tests on cartons that were not compartmented tended to be unstable under fire conditions.

**A-2-1.5** The classes of plastics used in this standard basically were derived from a series of large-scale and laboratory-type small-scale fire tests using a variety of expanded and nonexpanded plastic materials. It is recognized that not all plastics in a class exhibit exactly the same characteristics while burning.

**A-3-1.1** With protection installed in accordance with this standard, fire protection of overhead steel and steel columns might not be necessary.

Consideration should be given to subdividing large-area warehouses in order to reduce the amount of merchandise that could be affected by a single fire.

It is recommended that walls or partitions be provided to separate the storage area from mercantile, manufacturing, or other occupancies to prevent the possibility of transmission of fire or smoke between the two occupancies. Door openings should be equipped with automatic-closing fire doors appropriate for the fire resistance rating of the wall or partition.

**A-3-2** Smoke removal is important to manual fire fighting and overhaul. Since most fire tests were conducted without smoke and heat venting, protection specified in Sections 5-1, 6-1, and 7-1 was developed without the use of such venting. However, venting through eave-line windows, doors, monitors, gravity, or mechanical exhaust systems is essential to smoke removal after control of the fire is achieved. (See NFPA 204M, *Guide for Smoke and Heat Venting*.)

**A-4-1.2** Commodities that are particularly susceptible to water damage should be stored on skids, dunnage, pallets, or elevated platforms in order to maintain at least 4 in. (10.2 cm) clearance from the floor.

**A-4-2.2** Protection for exposed steel structural roof members might be needed and should be provided as indicated by the authority having jurisdiction.

**A-4-2.5** Incandescent light fixtures should have shades or guards to prevent the ignition of commodity from hot bulbs where possibility of contact with storage exists.

**A-4-3.2** Storage should be separated by aisles so that piles are not more than 50 ft (15.2 m) wide or 25 ft (7.6 m) wide if they abut a wall. Main and cross aisles should be located opposite window or door openings in exterior walls. This is of particular importance in buildings where few exterior openings exist. Aisle width should be at least 8 ft (2.4 m). In judging the adequacy of existing sprinkler protection, aisle spacing and frequency should be given consideration.

**A-4-4** Idle pallet storage introduces a severe fire condition. Stacking idle pallets in piles is the best arrangement of combustibles to promote rapid spread of fire, heat release, and complete combustion. After pallets are used for a short time in warehouses, they dry out and edges become frayed and splintered. In this condition they are subject to easy ignition from a small ignition source. Again, high piling increases considerably both the challenge to sprinklers and the probability of involving a large number of pallets when fire occurs. Therefore, it is preferable to store pallets outdoors where possible.

**A-4-4.1.1** See Table A-4-4.1.1.

**Table A-4-4.1.1 Recommended Clearance Between Outside Idle Pallet Storage and Building**

Wall Construction		Minimum Distance [ft (m)] of Wall from Storage of		
Wall Type	Openings	Under 50 Pallets	50 to 200 Pallets	Over 200 Pallets
Masonry	None	0	0	0
	Wired glass with outside sprinklers 1-hr doors	0	10 (3.0)	20 (6.1)
	Wired or plain glass with outside sprinklers ¾-hr doors	10 (3.0)	20 (6.1)	30 (9.1)
Wood or metal with outside sprinklers				
Wood, metal, or other		20 (6.1)	30 (9.1)	50 (15.2)

**Notes:**

1. Fire-resistive protection comparable to that of the wall also should be provided for combustible eave lines, vent openings, etc.
2. Where pallets are stored close to a building, the height of storage should be restricted to prevent burning pallets from falling on the building.
3. Manual outside open sprinklers generally are not a reliable means of protection unless property is attended to at all times by plant emergency personnel.
4. Open sprinklers controlled by a deluge valve are preferred.

**A-4-4.2** A fire in stacks of idle plastic and wooden pallets is one of the greatest challenges to sprinklers. The undersides of the pallets create a dry area on which a fire can grow and expand to other dry or partially wet areas. This process of jumping to other dry, closely located, parallel, combustible surfaces continues until the fire bursts through the top of the stack. Once this happens, very little water is able to reach the base of the fire. The only practical method of stopping a fire in a large concentration of

stored in a single location are not only dependent upon the dollar value of the commodity but also upon the total supply and availability of the material. The impact of the loss of the storage upon the ability to continue production should be considered.

### C-3 Site.

**C-3.1** In selecting a site for outdoor storage, preference should be given to a location that can provide the following:

- (a) Adequate municipal fire and police protection;
- (b) An adequate public water system with hydrants suitably located for protection of the storage;
- (c) Adequate all-weather roads for fire department apparatus response;
- (d) Sufficient clear space from buildings or from other combustible storage that constitutes an exposure hazard;
- (e) Absence of flood hazard;
- (f) Adequate clearance space between storage piles and any highways, bridges, railroads, and woodlands;
- (g) Topography as level as possible to provide storage stability.

**C-3.2** The entire site should be surrounded by a fence or other suitable means to prevent access of unauthorized persons. An adequate number of gates should be provided in the surrounding fence or other barriers to permit ready access of fire apparatus.

### C-4 Material Piling.

**C-4.1** Materials should be stored in unit piles as low in height and small in area as is consistent with good practice for the materials stored. The maximum height should be determined by the stability of pile, effective reach of hose streams, combustibility of the commodity, and ease of pile breakdown under fire or mop-up conditions. Long narrow piles are preferred over large square piles to facilitate manual fire fighting. (The short dimension increases the effectiveness of hose streams and eases pile breakdown.)

**C-4.2** Aisles should be maintained between individual piles, between piles and buildings, and between piles and the boundary line of the storage site. Sufficient driveways having the width of at least 15 ft (4.6 m) should be provided to allow the travel of fire equipment to all portions of the storage area. Aisles should be at least twice the pile height to reduce the spread of fire from pile to pile and to allow ready access for fire fighting, emergency removal of material, or salvage purposes.

**C-4.3** As the commodity class increases in combustibility or where storage could be ignited easily from radiation, wider aisles should be provided. Smaller unit piles might be an alternative to wider aisles if yard space is limited.

**C-4.4** For outdoor idle pallet storage, see Section 4-4 and A-4.4.1.1 of this standard. Separation between piles of idle pallets and other yard storage should be as specified in Table C-4.4.

**C-4.5** Boundary posts with signs designating piling limits should be provided to indicate yard area, roadway, and aisle limits.

**Table C-4.4 Pile Separation**

File Size	Minimum Distance ft (m)
Fewer than 50 pallets	20 (6)
50-200 pallets	30 (9.1)
More than 200 pallets	50 (15.2)

### C-5 Buildings and Other Structures.

**C-5.1** Yard storage, particularly storage of commodities in the higher heat release category, should have as much separation as is practical from important buildings and structures, but not less than that offered by NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*.

**C-5.1.1** As guidance in using NFPA 80A, *Recommended Practice for Protection of Buildings from Exterior Fire Exposures*, to establish clear spaces, the following Classification of Severity with Commodity Classes of this standard should be used on the basis of 100 percent openings representing yard storage:

- (a) *Light Severity*. Commodity Class I
- (b) *Moderate Severity*. Commodity Class II
- (c) Interpolate between moderate and severe severity for Commodity Class III
- (d) *Severe Severity*. Commodity Class IV and Class A plastics.

NOTE: The guidelines of C-5.1.1 apply to the equivalent commodity classes of this standard. The severity of the exposing building or structure also should be a consideration where establishing a clear space.

### C-6 Yard Maintenance and Operations.

**C-6.1** The entire storage site should be kept free from accumulation of unnecessary combustible materials. Vegetation should be kept cut low. Procedures should be provided for weed control and the periodic cleanup of the yard area.

**C-6.2** Adequate lighting should be provided to allow supervision of all parts of the storage area at night.

**C-6.3** All electrical equipment and installations should conform to the provisions of NFPA 70, *National Electrical Code*.

**C-6.4** No heating equipment should be located or used within the storage area. Salamanders, braziers, portable heaters, and other open fires should not be used.

**C-6.5** Smoking should be prohibited, except in locations prominently designated as smoking areas. "No Smoking" signs should be posted in prohibited areas.

**C-6.6** Welding and cutting operations should be prohibited in the storage area, unless in compliance with NFPA 51B, *Standard for Fire Prevention in Use of Cutting and Welding Processes*.

**C-6.7** Tarpaulins used for protection of storage against the weather should be of fire retardant fabric.

**C-6.8** Locomotives from which glowing particles could be emitted from exhaust stacks should not be permitted in the yard.

CITY OF ROCHESTER  
FIRE DEPARTMENT

APPLICATION FOR PERMIT

To use, maintain, store, manufacture, transport, install, conduct processes or carry on operations involving or creating conditions deemed hazardous to life or property.

To Fire Marshal, City of Rochester, N. Y.

Application is hereby made by the undersigned for a Permit to

- Use
- Install
- Operate
- Conduct
- Maintain
- Store
- Manufacture
- Transport

PALLET EXPRESS CORP. 111 BUFFALO RD

for the following materials, processes or operations.

(Describe briefly what is to be done and state what hazardous materials are to be used.)

- 5412 B 12 A FLAMMABLE COMPRESSED GAS #100 CO
- 5412 B 17 COMBUSTIBLE MATERIAL STORAGE 60 CO

Conditions, surroundings and arrangements to be in accordance with the Fire Prevention Code and Rulings of the Fire Safety Division of the City of Rochester.

This application is  approved insofar as Zoning and Building Ordinances are concerned.

is not

\_\_\_\_\_  
Zoning Administrator

\_\_\_\_\_  
Director of Buildings

FRANK CERVINI / PALLET EXPRESS CORP.  
Name of Applicant

111 BUFFALO RD  
Address of Applicant

ROCK NY 14611  
(Insert mailing address also, if different from above)

7/2/98  
Date

Complete plans and construction details must be filed on all major projects and when requested by the Fire Commissioner and/or the Fire Marshal.

INSPECTION REPORT

Location 111 Buffalo Rd Date 7/2/98  
Owner FRANK CARVINI  
Occupant \_\_\_\_\_ Type of Operation PAUET, SALES, REPAIR STORAGE

Conditions, surroundings and arrangements found:  
VIOLATION ISSUED SEE NOTICE ATTACHED

Required permit(s) with fee(s) SEE FRONT

Date Violations Issued 7/1/98 19\_\_ ; Corrected \_\_\_\_\_ 19\_\_

Date of Approval for Permit \_\_\_\_\_ 19\_\_  
Fire Safety Inspector

(For Office Use Only)

Date Permit Issued \_\_\_\_\_ Date Approved \_\_\_\_\_

Permit Number \_\_\_\_\_ Fee Required \_\_\_\_\_  
Fire Marshal



# NOTICE OF VIOLATIONS

DATE 7/1/98

Pallet Express Corp.

Name

Address

Inspection of premises located at 111 BUFFALO RD reveals  
violations of the Fire Prevention Code/Orders are hereby issued for correction of hazards listed  
herewith on or before: 7/24/98

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with  
following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

(1191a) ISLE SPACE SHALL BE MAINTAINED BETWEEN PALLET  
PILES. BUSINESS SIGNAGE

Pallet Piles SHALL NOT EXCEED 20' IN HEIGHT

PALLETS SHALL BE KEPT AT LEAST 20' FROM  
THE BLDG.

PERMITS SHALL BE ISSUED FOR COMPRESSED FLAMMABLE  
GAS AND COMBUSTIBLE STORAGE OUT.

(d-2) BUSINESS IDENTIFICATION SIGNS SHALL BE IN PLACE

(11751d)(1191a) ALSO ADDRESS #'S

FIRE SAFETY SIGNAGE SHALL BE IN PLACE FOR THE PROPER  
STORAGE AND STORAGE OF FLAMMABLE GAS ALSO MAINTAINANCE

By Order of  
FIRE MARSHAL

INSPECTOR

John J. Parvitz

Over

DATE OF COMPLIANCE \_\_\_\_\_

Inspector \_\_\_\_\_

# FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL  
PUBLIC ED  
PERMIT  
HIGH-RISE

LOCATION

*111 Buffalo Rd*

*New Business*

DATE RECEIVED IN FIRE SAFETY:

*6-25-97*

DATE

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OK TO FILE

INSPECTOR

*Fire extinguisher  
Seal on Cabinet*

*7-28-97*

*corrected*

*Y HRF*



BUILDING INSPECTION / COMPLAINT FORM



COMPANY 095 ADDRESS BUFFALO RD FROM / TO 111 INSPECTION # 01072 TAX ACCT #

PROPERTY OWNER DIMITRIOS TAMOUTSELIS ADDRESS 111 BUFFALO RD PHONE 235-8560  
CITY ROCHESTER STATE NY ZIP 14611

MAILING NAME BUFFALO ROAD GLASS & MIRROR CO ADDRESS 111 BUFFALO RD PHONE 0  
CITY ROCHESTER STATE NY ZIP 14611

EMERGENCY CONTACT DIMITRIOS TAMOUTSELIS ADDRESS 394 WHITTIER RD PHONE 594-1417  
CITY SPENCERTOWN STATE NY ZIP 14557

NFPA 901 CODES GENERAL PROPERTY USE 52 SPECIFIC PROPERTY USE 765 STRUCTURE TYPE 2 STRUCTURE STATUS 2

NO ENTRY DATES: 7-89

BUSINESS NAME DAVID SAILE PHONE 525-3898 DISPOSITION BY FIRE SAFETY: X

BUSINESS OWNER CHUCK KINNEL ADDRESS 2768 W. RIDGE RD CITY ROCHESTER STATE NY ZIP 14611

BUSINESS EMERGENCY SAME ADDRESS 24 POTTER ST PHONE 436-2735

A = ATTIC  
C = CELLAR  
G = GARAGE  
O = OUTSIDE  
# = FLOOR #

SPECIAL INSTRUCTIONS:

SPECIAL HAZARDS OR CONSTRUCTION:

DIRECTION ROOM #, ETC. COMPLAINT 54

<input type="checkbox"/>	NO VIOLATIONS NOTED AT THIS TIME	REFERRED ORDERS ISSUED CORRECTED NOT REQUIRED
	FSA - MAKE NOTE OF NAME CHANGE	
	Frag. extinguishers	
	Seam	
	Flammable Liquid	
	acetylene	

*Robert Saile*

OFFICER PREPARING REPORT: Carl D. Bagley COMPANY 05 DISTRICT 3 GROUP 3 DATE 6-12-97

BUS/PROP REPRESENTATIVE: X POSITION / TITLE OWNER DATE OF REINSPECTION

FIRE SAFETY INSPECTOR: DATE

RFID 501 REV. 1/97

Fire Dept.  
Fire Safety Division  
Public Safety Bldg.  
Rochester, N.Y. 14614



OFFICE OF THE  
FIRE MARSHAL  
TELEPHONE: 428-7037

# NOTICE OF VIOLATIONS

DATE 11-21-97

Buffford Collision  
Name

111 BUFFORD RD  
Address

Inspection of premises located at \_\_\_\_\_ reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 11-28-97

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

2 FIRE EXTINGUISHER

FLAMMABLE LIQUID SIGN ON CABINET

corrected

By Order of  
FIRE MARSHAL

INSPECTOR

AJ Flynn

DATE of COMPLIANCE

11-28-97

Inspector



BUILDING INSPECTION / COMPLAINT FORM

COMPANY **Q05** INSPECTION # **74589**  
 ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT # **087245-01.0**  
 PROPERTY OWNER **DIMITRIOS TAMOUTSELIS** ADDRESS **111 BUFFALO RD** PHONE **235-8560**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 MAILING NAME **BUFFALO ROAD GLASS & MIRROR C** ADDRESS **111 BUFFALO RD** PHONE **0**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 EMERGENCY CONTACT **KOSTANTINOS TAMOUTSELIS** ADDRESS **1562 VROOM RD** PHONE **594-1349**  
 CITY **SPENCERFORT** STATE **NY** ZIP **14559**

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **682** STRUCTURE TYPE **P** STRUCTURE STATUS **2**

A = ATTIC  
C = CELLAR  
G = GARAGE  
O = OUTSIDE  
# = FLOOR #

BUSINESS NAME **BUFFALO ROAD GLASS & MIRROR** PHONE  
 BUSINESS OWNER  
 ADDRESS **SAME** PHONE  
 BUSINESS EMERGENCY ADDRESS PHONE  
 SPECIAL INSTRUCTIONS:  
 SPECIAL HARZARDS OR CONSTRUCTION  
 DIRECTION ROOM #, ETC. COMPLAINT  
**NO-VIOLATIONS AT THIS TIME**

DISPOSITION by FIRE SAFETY:  
 REFERRED  
 ORDERS ISSUED  
 CORRECTED  
 NOT REQUIRED

**FILE**

OFFICER PREPARING REPORT: *[Signature]* COMPANY *[Signature]* DISTRICT *[Signature]* GROUP *[Signature]* DATE **4/6/96**  
 BUS/PROP REPRESENTATIVE: POSITION / TITLE DATE  
 FIRE SAFETY INSPECTOR: DATE

BUILDING INSPECTION / COMPLAINT FORM



COMPANY 005 INSPECTION # 74590  
 ADDRESS BUFFALO RD FROM / TO 111 TAX ACCT # 087245-01.0  
 PROPERTY OWNER DIMITRIOS TAMOUTSELIS ADDRESS 111 BUFFALO RD PHONE 235-8560  
 CITY ROCHESTER STATE NY ZIP 14611  
 MAILING NAME BUFFALO ROAD GLASS & MIRROR C ADDRESS 111 BUFFALO RD PHONE 0  
 CITY ROCHESTER STATE NY ZIP 14611  
 EMERGENCY CONTACT DIMITRIOS TAMOUTSELIS ADDRESS 394 WHITTER RD PHONE 594-1419  
 CITY SPENCERPORT STATE NY ZIP 14559

NFPA 901 CODES GENERAL PROPERTY USE 52 SPECIFIC PROPERTY USE 965 STRUCTURE TYPE 2 STRUCTURE STATUS 2

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME VEHICLES UNLIMITED PHONE 328-1100 DISPOSITION by FIRE SAFETY:  
 BUSINESS OWNER MARK BARBATO DALTON AUTO SALES  
 ADDRESS 111 BUFFALO RD ROCHESTER NY 14611  
 BUSINESS EMERGENCY MARK BARBATO PHONE 247-5519  
 ADDRESS 72 PENNICOTT CIR PENFIELD NY 14526  
4768 Ridge Rd West PHONE 688-9506

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

SPECIAL INSTRUCTIONS:  
 SPECIAL HARZARDS OR CONSTRUCTION

DIRECTION ROOM #, ETC.

COMPLAINT

NEW BUSINESS / MOVING IN

**FILE**

OFFICER PREPARING REPORT: [Signature] COMPANY 01 DISTRICT 2 GROUP 7 DATE 6/6/87  
 BUS/PROP REPRESENTATIVE: [Signature] POSITION / TITLE [Signature] DATE 6/6/87  
 FIRE SAFETY INSPECTOR: DATE [Signature]

# FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL  
 PUBLIC ED  
 PERMIT  
 HIGH-RISE

LOCATION

111 BUFFALO RD.

DATE RECEIVED IN FIRE SAFETY:

10-18-95

DATE

2-2-96

2-9-96

APPOINTMENT

PERSON CONTACTED

NO ENTRY  
 ORDERS ISSUED  
 REFERRALS ISSUED  
 NO WORK DONE  
 SOME WORK DONE

OTHER

OK TO FILE

INSPECTOR

OUT OF BUSINESS  
 URGENT customer  
 WILL TAKE CARE OF IT  
 corrected

JP  
 ✓ JP

## NEW INFORMATION

**FILE**



# FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL  
PUBLIC ED  
PERMIT  
HIGH-RISE

LOCATION

*161 Buffalo Rd*

DATE RECEIVED IN FIRE SAFETY:

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OK TO FILE

INSPECTOR

DATE

*4/26/95*

*2 connections*

*[Signature]*

**NEW  
INFORMATION**

**FILE**



BUILDING INSPECTION / COMPLAINT FORM



05434

COMPANY **Q05** INSPECTION # **05434**  
 ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT # **087245-01.0**  
 PROPERTY OWNER **DIMITRIOS TAMOUTSELIS** ADDRESS **111 BUFFALO RD** PHONE **235-8560**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 MAILING NAME **BUFFALO ROAD GLASS & MIRROR C** ADDRESS **111 BUFFALO RD** PHONE **0**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 EMERGENCY CONTACT **DIMITRIOS TAMOUTSELIS** ADDRESS **394 WHITTIER RD** PHONE **1349**  
**KOSTANTINOS** CITY **SPENCERPORT** STATE **NY** ZIP **14559**  
**1562 VROOM RD**

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **682** STRUCTURE TYPE **F** STRUCTURE STATUS **2**

NO ENTRY DATES:

BUSINESS NAME <b>BUFFALO ROAD GLASS &amp; MIRR</b> PHONE	DISPOSITION by FIRE SAFETY:
BUSINESS OWNER ADDRESS PHONE	
BUSINESS EMERGENCY ADDRESS PHONE	REFERRED
SPECIAL INSTRUCTIONS:	ORDERS ISSUED
SPECIAL HAZARDS OR CONSTRUCTION	CORRECTED
	NOT REQUIRED

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

DIRECTION ROOM #, ETC.	COMPLAINT	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
1st Floor GARAGE	Extinguisher mounted to High; Also NEED Inspection			✓	✓
	RE INSPECTED 10/17/94 VIOLATION NOT CORRECTED HI-MC				
	TO RES				

OFFICER PREPARING REPORT: *[Signature]* COMPANY **QMS** DISTRICT **2** GROUP **2** DATE **8/17/94**  
 BUS/PROP REPRESENTATIVE: *[Signature]* POSITION / TITLE DATE  
 FIRE SAFETY INSPECTOR: *[Signature]* DATE **4/26/95**

RFD 501 REV. 12/80

BUILDING INSPECTION / COMPLAINT FORM



05435

COMPANY **Q05** INSPECTION #

ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT # **087245-01.0**

PROPERTY OWNER **DIMITRIOS TAMOUTSELIS** ADDRESS **111 BUFFALO RD** PHONE **235-8560**

CITY **ROCHESTER** STATE **NY** ZIP **14611**

MAILING NAME **BUFFALO ROAD GLASS & MIRROR C** ADDRESS **111 BUFFALO RD** PHONE **0**

CITY **ROCHESTER** STATE **NY** ZIP **14611**

EMERGENCY CONTACT **DIMITRIOS TAMOUTSELIS** ADDRESS **394 WHITTER RD** PHONE **594-1419**

CITY **SPENCERPORT** STATE **NY** ZIP **14559**

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **965** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

NO ENTRY DATES:

BUSINESS NAME **VEHICLES UNLIMITED** PHONE

BUSINESS OWNER **MARK BARBATO**

ADDRESS **111 BUFFALO RD ROCHESTER NY 14611**

PHONE ~~320-6266~~

BUSINESS EMERGENCY **MARK BARBATO** **247-5510**

ADDRESS **72 PENNICOTT CIR PENFIELD NY 14526**

PHONE **381 9506**

DISPOSITION by FIRE SAFETY:

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

REFERRED  
ORDERS ISSUED  
CORRECTED  
NOT REQUIRED

SPECIAL INSTRUCTIONS:

SPECIAL HAZARDS OR CONSTRUCTION

DIRECTION ROOM #, ETC.

COMPLAINT

*THIS LOCATION IS VACANT*

**FILE**

OFFICER PREPARING REPORT: *[Signature]* COMPANY **Q05** DISTRICT **B2** GROUP **2** DATE **9/12/94**

BUS/PROP REPRESENTATIVE: POSITION / TITLE DATE

FIRE SAFETY INSPECTOR: DATE



BUILDING INSPECTION / COMPLAINT FORM



COMPANY **005** INSPECTION # **09761**  
 ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT # **087245-01.0**  
 PROPERTY OWNER **DIMITRIOS TAMOUTSELIS** ADDRESS **111 BUFFALO RD** PHONE **235-8560**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 MAILING NAME **BUFFALO ROAD GLASS & MIRROR C** ADDRESS **111 BUFFALO RD** PHONE **0**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 EMERGENCY CONTACT **DIMITRIOS TAMOUTSELIS** ADDRESS **394 WHITTER RD** PHONE **594-1419**  
 CITY **SPENCERPORT** STATE **NY** ZIP **14559**

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **682** STRUCTURE TYPE **F** STRUCTURE STATUS **2**

NO ENTRY DATES:	BUSINESS NAME BUSINESS OWNER ADDRESS PHONE	DISPOSITION by FIRE SAFETY:	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
	<b>BUFFALO ROAD GLASS &amp; MIRR</b> <i>Some as above</i>					
	<b>SPECIAL INSTRUCTIONS:</b>					
	<b>SPECIAL HAZARDS OR CONSTRUCTION</b> <b>BAR JOIST TRUSS ROOF</b>					
	<b>DIRECTION ROOM #, ETC.</b>	<b>COMPLAINT</b>				
<b>0 FRONT</b>	<b>NEEDS NUMBERS for ADDRESS.</b>					
<b>1 UTILITY RM</b>	<b>2 COVERS NEEDED for JUNCTION BOXES</b>					
	<b>Reinspected 8-5-93</b> <b>Violation not corrected</b> <i>[Signature]</i>					

OFFICER PREPARING REPORT: *[Signature]* COMPANY **005** DISTRICT **2** GROUP **1** DATE **6/30/93**  
 BUS/PROP REPRESENTATIVE: *[Signature]* POSITION / TITLE DATE  
 FIRE SAFETY INSPECTOR: *[Signature]* DATE **10-13-93**

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q05** INSPECTION # **09762**  
 ADDRESS FROM / TO TAX ACCT #  
**BUFFALO RD 111 087245-01.0**  
 PROPERTY OWNER ADDRESS PHONE  
**DIMITRIOS TAMOUTSELIS 111 BUFFALO RD 235-8560**  
 CITY ROCHESTER STATE NY ZIP 14611  
 MAILING NAME ADDRESS PHONE  
**BUFFALO ROAD GLASS & MIRROR C 111 BUFFALO RD 0**  
 CITY ROCHESTER STATE NY ZIP 14611  
 EMERGENCY CONTACT ADDRESS PHONE  
**DIMITRIOS TAMOUTSELIS 394 WHITTER RD 594-1419**  
 CITY SPENCERPORT STATE NY ZIP 14559

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **265** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

NO ENTRY DATES:		BUSINESS NAME <b>VEHICLES UNLIMITED</b>		PHONE <b>328-6266</b>		DISPOSITION by FIRE SAFETY:	
		BUSINESS OWNER <b>JOHN OLIVER MARK BARBATO</b>		ADDRESS <b>111 BUFFALO RD ROCHESTER NY 14611</b>		REFERRED	
		BUSINESS EMERGENCY <b>JOHN OLIVER MARK BARBATO</b>		PHONE <b>328-5977</b>		CORRECTED	
		ADDRESS <b>463 SILVERFOX CL ROCHESTER PENFIELD NY 14612</b>		PHONE <b>392-4805-381-9506</b>		ORDERS ISSUED	
		ADDRESS <b>72 PENNICOTT CIR.</b>				NOT REQUIRED	
SPECIAL INSTRUCTIONS:		SPECIAL HAZARDS OR CONSTRUCTION <b>BAR JOIST TRUSS ROOF</b>		COMPLAINT			
A = ATTIC							
C = CELLAR							
G = GARAGE							
O = OUTSIDE							
# = FLOOR #							
	DIRECTION ROOM #, ETC.						
	<b>1 GARAGE AREA</b>	<b>HOT WATER TANK NEEDS PIPE OR PRESSURE RELIEF VALVE.</b>					<b>X</b>
		<b>Reinspection 8-5-93 [Signature]</b>					
		<b>Violations corrected</b>					

OFFICER PREPARING REPORT: **[Signature]** COMPANY **Q05** DISTRICT **2** GROUP **1** DATE **6/30/93**  
 BUSINESS REPRESENTATIVE: **[Signature]** POSITION / TITLE DATE  
 FIRE SAFETY INSPECTOR: DATE

RFD 501 REV. 12/90

BUILDING INSPECTION / COMPLAINT FORM



06955

COMPANY 005	FROM / TO 111	INSPECTION #	06955
ADDRESS BUFFALO RD		TAX ACCT #	087245-01.0
PROPERTY OWNER DIMITRIOS TAMOUTSELIS	ADDRESS 111 BUFFALO RD	PHONE 235-8560	
	CITY ROCHESTER	STATE NY	ZIP 14611
MAILING NAME BUFFALO ROAD GLASS & MIRROR C	ADDRESS 111 BUFFALO RD	PHONE 0	
	CITY ROCHESTER	STATE NY	ZIP 14611
EMERGENCY CONTACT DIMITRIOS TAMOUTSELIS	ADDRESS 394 WHITTER RD	PHONE 594-1419	
	CITY SPENCERPORT	STATE NY	ZIP 14559

NFPA 901 CODES	GENERAL PROPERTY USE 52	SPECIFIC PROPERTY USE 965	STRUCTURE TYPE F	STRUCTURE STATUS 2
----------------	----------------------------	------------------------------	---------------------	-----------------------

NO ENTRY DATES:	BUSINESS NAME OLIVER J AUTO SALES	PHONE	DISPOSITION by FIRE SAFETY:				
	BUSINESS OWNER JOHN OLIVER		PERMITS				
	ADDRESS 111 BUFFALO RD	ROCHESTER NY14611	PHONE 328 5977	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
	BUSINESS EMERGENCY JOHN OLIVER						
A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	ADDRESS 163 SILVERFOX CL	ROCHESTER NY14612	PHONE 392 4805				
	SPECIAL INSTRUCTIONS:						
	SPECIAL HAZARDS OR CONSTRUCTION						
DIRECTION ROOM #, ETC.	COMPLAINT						
	<i>No Violations</i>						

OFFICER PREPARING REPORT: <i>Michael J. ...</i>	COMPANY MS	DISTRICT 2	GROUP 2	DATE 3/29/92
BUS/PROP REPRESENTATIVE: <i>John Oliver</i>	POSITION / TITLE Renter			DATE 5-29-92
FIRE SAFETY INSPECTOR:				DATE

RFD 501 REV. 12/90

BUILDING INSPECTION / COMPLAINT FORM



06954

COMPANY	005	INSPECTION #	06954		
ADDRESS	BUFFALO RD	FROM / TO	111	TAX ACCT #	087245-01.0
PROPERTY OWNER	DIMITRIOS TAMOUTSELIS	ADDRESS	111 BUFFALO RD	PHONE	235-8560
		CITY	ROCHESTER	STATE	NY
		ZIP	14611		
MAILING NAME	BUFFALO ROAD GLASS & MIRROR C	ADDRESS	111 BUFFALO RD	PHONE	0
		CITY	ROCHESTER	STATE	NY
		ZIP	14611		
EMERGENCY CONTACT	DIMITRIOS TAMOUTSELIS	ADDRESS	394 WHITTER RD	PHONE	594-1419
		CITY	SPENCERPORT	STATE	NY
		ZIP	14559		

NFPA 901 CODES	GENERAL PROPERTY USE	SPECIFIC PROPERTY USE	STRUCTURE TYPE	STRUCTURE STATUS
	52	682	F	2

NO ENTRY DATES:	BUSINESS NAME	BUFFALO ROAD GLASS & MIRR	PHONE		DISPOSITION by FIRE SAFETY:	PERMITS	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
	BUSINESS OWNER									
	ADDRESS									
	BUSINESS EMERGENCY									
	ADDRESS									
	PHONE									
	SPECIAL INSTRUCTIONS:									
	SPECIAL HAZARDS OR CONSTRUCTION									
	DIRECTION ROOM #, ETC.	COMPLAINT								
		NO Violations								

OFFICER PREPARING REPORT:	COMPANY	DISTRICT	GROUP	DATE
<i>Nathaniel Sweney</i>	M5	2	2	5/29/92
BUS/PROP REPRESENTATIVE:	POSITION / TITLE			DATE
<i>John G. Oliver</i>	Renter			5-29-92
FIRE SAFETY INSPECTOR:				DATE



BUILDING INSPECTION / COMPLAINT FORM



08194

COMPANY **Q05** INSPECTION # **08194**  
 ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT # **087245-01.0**  
 PROPERTY OWNER **DIMITRIOS TAMOUTSELIS** ADDRESS **111 BUFFALO RD** PHONE **235-8560**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 MAILING NAME **BUFFALO ROAD GLASS & MIRROR C.** ADDRESS **111 BUFFALO RD** PHONE **0**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 EMERGENCY CONTACT **DIMITRIOS TAMOUTSELIS** ADDRESS **394 WHITTER RD** PHONE **594-1419**  
 CITY **SPENCERPORT** STATE **NY** ZIP **14559**

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **965** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

NO ENTRY DATES:	BUSINESS NAME <b>OLIVER J AUTO SALES</b> PHONE <b></b>	DISPOSITION by FIRE SAFETY:	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
	ADDRESS <b>111 BUFFALO RD</b> <b>ROCHESTER NY 14611</b> PHONE <b>328 5977</b>					
	BUSINESS EMERGENCY <b>JOHN OLIVER</b> <b>14612</b> ADDRESS <b>163 SILVERFOX CL</b> <b>ROCHESTER NY</b> PHONE <b>392 5549 4805</b>					
	SPECIAL INSTRUCTIONS:					
	SPECIAL HAZARDS OR CONSTRUCTION <b>Truss Construction</b>					
	DIRECTION ROOM #, ETC.					
	COMPLAINT					
	<b>NO violations at time of inspection</b>					

OFFICER PREPARING REPORT: **F.F. Robert G. McKealy** COMPANY **Q05** DISTRICT **2** GROUP **3** DATE **6-5-91**  
 BUS/PROP REPRESENTATIVE: **John A. Oliver** POSITION / TITLE  DATE   
 FIRE SAFETY INSPECTOR:  DATE

FRD 501 REV. 12/90

BUILDING INSPECTION / COMPLAINT FORM



COMPANY R05 INSPECTION # 67882  
 ADDRESS BUFFALO RD FROM / TO 111 TAX ACCT # 087245-01.0  
 PROPERTY OWNER ~~DEMETRIOS TAMOUTSELIS~~ ADDRESS 111 BUFFALO RD PHONE 235-8560  
~~DEMETRIOS TAMOUTSELIS~~ CITY ROCHESTER STATE NY ZIP 14611  
 MAILING NAME DEMETRIOS TAMOUTSELIS ADDRESS 111 BUFFALO RD PHONE 0  
Buff CITY ROCHESTER STATE NY ZIP 14611  
 EMERGENCY CONTACT DEMETRIOS TAMOUTSELIS ADDRESS 394 WHITTER RD PHONE 594-1419  
 CITY SPENCERPORT STATE NY ZIP 14559

NFPA 901 CODES GENERAL PROPERTY USE 52 SPECIFIC PROPERTY USE 965 STRUCTURE TYPE 2 STRUCTURE STATUS 2

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME OLIVER J AUTO SALES PHONE   
 BUSINESS OWNER JOHN OLIVER  
 ADDRESS 111 BUFFALO RD ROCHESTER NY 14611  
 PHONE 328 5977  
 BUSINESS EMERGENCY JOHN OLIVER  
 ADDRESS ~~15 GLOUCESTER CR~~ ROCHESTER NY 14623  
163 Silverox Circle PHONE ~~392 4988~~ 392 4865

DISPOSITION by FIRE SAFETY:			
REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED

SPECIAL INSTRUCTIONS:  
 SPECIAL HARZARDS OR CONSTRUCTION

DIRECTION ROOM #, ETC.

COMPLAINT

*No Violations found at this time*

OFFICER PREPARING REPORT: <i>[Signature]</i>	COMPANY <u>R05</u>	DISTRICT	GROUP <u>4</u>	DATE <u>6-11-90</u>
BUS/PROP REPRESENTATIVE: <i>Ronald B. [Signature]</i>	POSITION / TITLE <u>P.O.A.</u>			DATE <u>6-11-90</u>
FIRE SAFETY INSPECTOR:				DATE





BUILDING INSPECTION / COMPLAINT FORM

COMPANY **Q05** INSPECTION # **53275**  
 ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT # **087245-01.0**  
 PROPERTY OWNER **DEMETRIOS TAMOUTSELIS** ADDRESS **111 BUFFALO RD** PHONE **235-9560**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 MAILING NAME **BUFFALO ROAD GLASS & MIRROR C** ADDRESS **111 BUFFALO RD** PHONE **0**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 EMERGENCY CONTACT **DEMETRIOS TAMOUTSELIS** ADDRESS **394 WHITTER RD** PHONE **594-1419**  
 CITY **SPENCERPORT** STATE **NY** ZIP **14559**

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **965** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **OLIVER J AUTO SALES** PHONE **328-5977**  
 BUSINESS OWNER **JOHN OLIVER**  
 ADDRESS **111 BUFFALO RD** **ROCHESTER NY 14611**  
 PHONE **328 5977**  
 BUSINESS EMERGENCY **JOHN OLIVER**  
 ADDRESS **15 GLOUCESTER CR** **ROCHESTER NY 14623**  
 PHONE **328-7487**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

SPECIAL INSTRUCTIONS: **392-4908**

DIRECTION ROOM #, ETC.

COMPLAINT

*no violations at this time*

OFFICER PREPARING REPORT: *[Signature]* COMPANY **Q5** DISTRICT **2** GROUP **1** DATE **8/3/89**  
 BUSINESS REPRESENTATIVE: *[Signature]* POSITION / TITLE DATE  
 FIRE SAFETY INSPECTOR: DATE



BUILDING INSPECTION / COMPLAINT FORM

COMPANY **Q05** INSPECTION # **53274**  
 ADDRESS **BUFFALO RD** FROM / TO **111** TAX ACCT # **087245-01.0**  
 PROPERTY OWNER **DEMETRIOS TAMOUTSELIS** ADDRESS **111 BUFFALO RD** PHONE **235-8560**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 MAILING NAME **BUFFALO ROAD GLASS & MIRROR C** ADDRESS **111 BUFFALO RD** PHONE **0**  
 CITY **ROCHESTER** STATE **NY** ZIP **14611**  
 EMERGENCY CONTACT **DEMETRIOS TAMOUTSELIS** ADDRESS **394 WHITTER RD** PHONE **594-1419**  
 CITY **SPENCERPORT** STATE **NY** ZIP **14559**

NFPA 901 CODES GENERAL PROPERTY USE **52** SPECIFIC PROPERTY USE **682** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **BUFFALO ROAD GLASS & MIRROR** PHONE **235-8560**  
 BUSINESS OWNER **DEMETRIOS TAMOUTSELIS** PHONE **235-8560**  
 ADDRESS **DEMETRIOS TAMOUTSELIS**  
 BUSINESS EMERGENCY ADDRESS **394 WHITTER RD** PHONE **594-1419**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED

SPECIAL INSTRUCTIONS:  
 COMPLAINT

DIRECTION ROOM #, ETC.

*No violations at Time of Inspection*

OFFICER PREPARING REPORT: <i>FF Robbie Bronzo</i>	COMPANY <b>Q05</b>	DISTRICT <b>2</b>	GROUP <b>I</b>	DATE <b>8-3-89</b>
BUS/PROP REPRESENTATIVE: <i>Natalie Tamoutselis</i>	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE













INSPECTION / COMPLAINT FORM



INSPECTION # 8,603205

11111 Buffalo Rd 11

John Oliver ADDRESS 15 Gloucester Cr PHONE 334 7417

AGENCY ACT Same ADDRESS PHONE

TAMOUTSELIS DEMETRIOS 394 WHITTIER RD

COMPLAINANT ADDRESS Spencerport 14559 PHONE

87245-01.0

NFPA 901 CODES GENERAL PROPERTY USE 9.6.5 SPECIFIC PROPERTY USE 9.6 STRUCTURE TYPE L1 STRUCTURE STATUS 2

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS: NAME J. Oliver Auto Sales PHONE 328 5977  
 OWNER J Oliver  
 ADDRESS 15 Gloucester Cr PHONE 328 5977

DISPOSITION by FIRE SAFETY:  
 NOT REQUIRED  
 CORRECTED  
 ORDERS ISSUED  
 REFERRED

DIRECTION, ROOM #, ETC.

NATURE of VIOLATION or COMPLAINT

No Violations AT present Time

OFFICER PREPARING REPORT: <u>Capt R. Volkmann</u>	COMPANY <u>Q5</u>	GROUP <u>III</u>	DATE <u>5/2/86</u>
BUS/PROP REPRESENTATIVE: <u>John A. Oliver</u>	POSITION/TITLE <u>Owner</u>		DATE <u>5/2/86</u>
FIRE SAFETY INSPECTOR:			DATE







*Jordan E. Pappas*  
*Attorney and Counselor at Law*

*17 Main Street East*  
*Rochester, New York 14614*

*(716) 232-1292*

August 16, 1984

Fire Department  
Fire Safety Division  
Public Safety Building  
Rochester, NY 14614

Attention: Lt. R. DiLaura


Re: 111 Buffalo Road

Dear Lt. DiLaura:

This will confirm our telephone conversation this date concerning removal of tanks at the above-entitled property. Would you please send us a copy of the original Notice of Violations sent to Alphonse Florio regarding same.

Your cooperation in this matter would be most appreciated.


Very truly yours,



Eileen Solimano,  
Secretary to Jordan E. Pappas

/es

*Sent Copy to Lawyer*  
*Permission given by Jeff Eicher through Chief Gordon to send*  
*Copy to Lawyer on 8-20-84*  
*R. DiLaura*



# NOTICE OF VIOLATIONS

DATE 5-29-84

Buffalo Road Glass and Mirror 111 Buffalo Rd.  
Name Address

Inspection of premises located at 111 Buffalo Rd reveals  
violations of the Fire Prevention Code. Orders are hereby issued for correction of  
hazards listed herewith on or before: Aug. 29, 1984

Failure to comply with these orders may result in issuance of Municipal Code Violation  
Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

Dimitrios Lamoutselis - owner - 594-1419

Underground flammable and combustibile liquids storage tank[s] discontinued  
from service to be removed from the site within ninety [90] days.

Dispensing unit[s] servicing underground tank[s] shall be removed  
immediately and all piping capped. (FPC 54-22j)

A permit for removal shall be obtained from the Building Bureau and all  
work done by a certified contractor.

By Order of  
FIRE MARSHAL

INSPECTOR A. R. DiLaura

DATE of COMPLIANCE \_\_\_\_\_

Inspector \_\_\_\_\_

ENR06

FD570

# FIRE SAFETY INSPECTION RECORD

LICENSE  
 TANK REMOVAL

GENERAL  
 PUBLIC ED.  
 PERMIT

LOCATION: 111 BUFFALO RD

BUFFALO ROAD GLASS & MIRROR

DATE RECEIVED IN FIRE SAFETY:

DATE

APPOINTMENT

PERSON CONTACTED

NO ENTRY ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OK TO FILE INSPECTOR

*1 Cov*

5-29-84

DTI AURA

8-29-84

~~8-20-84~~

*Tanks were removed on 6-19-84*

*By Jeff Brongo 6 tanks 7 hours*

*X Gallie*



**POST IN A CONSPICUOUS PLACE**

**Permit for the Storage and Sale of Explosives and Combustibles**

DEPARTMENT OF PUBLIC SAFETY

BUREAU OF BUILDINGS

**Nº 13132**

Plat Plan No. **45**.....

Rochester, N. Y., **Mar. 1st 1938** 193 ..

Permission is hereby granted to **Doyle Gasoline & Oil Co.** of

**45 Exchange St.**..... Rochester, N. Y., to sell and store GASOLINE.....

at No. **111 Buffalo Road** ( )..... Street. This Permit will expire **Mar 1** 193 **9**.

Public Station? Bulk? Wholesale? or Private Use?..... **Public**.....

If for Renewal, Transfer, or Additional Storage, give former Permit No. **12860**.....

Number and Capacity of Tanks **3 5-1000 (2-500 A. J. C. Tanks)**.....

Total Quantity **4000 1000** Gallons. Number of Pumps **5**.....

**Thomas C. Woods**  
Commissioner of Public Safety.

**Walker S. Lee**  
Superintendent of Buildings.

This Permit is granted on the express condition that the said Explosives or Combustibles are kept in an approved receptacle or apartment used exclusively for that purpose, approved by the Bureau, and not in proximity to Gas, Oil, Arc Lights or Stoves or any open flame; that signs "NO SMOKING," be placed in a conspicuous place on the premises where said Explosives or Combustibles are kept; that for other than Private Use approved foam extinguishment shall be provided.

**Renewal, Additional Storage, Transfer**

Permit Number      Date      Number and Capacity of Tanks      Number of Pumps

Permit Number	Date	Number and Capacity of Tanks	Number of Pumps
14694	MAR 13 1939	3-1000 2-500	5
15177	MAR 5 1940	Kittelberger Bros.	
16844	MAR 4 1941		
17814	MAR 3 1942		
18831	MAR 1 1943		
20129	MAR 1 1944		
21236	MAR 2 1945		
22116	MAR 1 1946		
23074	MAR 1 1947	R W KITTELBERGER, 58 STANTON ST	
25074	APR 28 1948	GULF OIL CORP., 755 BROOKS AVE	
25672	MAR 1 1949	3 2-3000 2-2000	3
26694	MAR 1 1950		
27575	MAR 7 1951		
28587	MAR 1- 1952		

Fire Dept.  
Fire Safety Division  
Public Safety Bldg.  
Rochester, N.Y. 14614



OFFICE OF THE  
FIRE MARSHAL

TELEPHONE: 428-7037

**NOTICE OF VIOLATIONS**

Date August 15, 1912

Name Crone Gas

Address 111 Buffalo St

Inspection of premises at Crone Gas

reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before:

August 15 1912

**NOTE: Penalties for failing to comply listed on opposite side of this report.**

Remove all tanks not  
in use 3 Tanks not in use  
54-22-J Diesel + Kerosene  
2-4000  
1-1000

FD-206

By Order of  
FIRE MARSHAL

[Signature]  
Inspector

DATE of COMPLIANCE \_\_\_\_\_

Over \_\_\_\_\_



NOTICE OF VIOLATIONS

AUG 11 1982  
*sent [signature]*

*235-9191*  
Sandra Scofero Name 11 Nova Lane Address  
Date August 5, 1982

Inspection of premises located at 111 Buffalo  
reveals violations of the Fire Prevention Code. Orders are hereby issued for for correc-  
tion of hazards listed herewith on or before: Nov. 5 1982 19 82

54-22-J

Underground flammable and combustible liquids storage tanks discontinued from service are to be removed from the site within ninety (90) days. The method of removal shall be prescribed by the Fire Marshal. In the event of the discontinuance of a business for which a license has been issued pursuant to the provisions of this Chapter, the licensee shall notify the Fire Marshal at least twenty-four (24) hours before the time such discontinuance takes effect. Dispensing units servicing underground tanks shall be removed immediately and all piping capped, and any electrical supply line shall be discontinued at the panel box.

FD506

By Order of  
FIRE MARSHAL

R. Pratt  
Inspector

DATE of COMPLIANCE \_\_\_\_\_ Inspector \_\_\_\_\_

Location 111 BUFFALO Rd.

Construction FIRE RESISTIVE

Stories 1

Length 65'

Width 25'

Use of Bldg. GASOLINE SERVICE STATION

Fire Extinguishers: No. and Kind (2) PRESSURIZED WATER (2) DRY CHEMICAL

Floor Openings Other Than Stairs or Elevators: NONE

How Protected? \_\_\_\_\_

Heating Apparatus: Type OIL

Location of Floor Drains: SERVICE STATION FLOOR

How Can Access Be Gained to Basement? NO BASEMENT

Main Electrical Switch: SOUTH WEST CORNER (UTILITY ROOM)

Water Main Shut Off: SOUTH WEST CORNER (UTILITY ROOM)

Gas Shut Off: NO GAS SERVICE

Air Conditioning Shut Off: NONE

Special Conditions: \_\_\_\_\_

