Address 311 Alexander St.

INSPECTION RECOR

DATE OF INSPECTION	INSPECTOR	CO.	Gr	PERSON INTERVIEWED	VIOLATIONS	DISPOSITION
10- 8-69	Lt. Mars			S. Goodwin		
4-22-71	Capt. Luciano	E-1	IV	K. LeClair	1. Cap on flue pipe for water heater/2. Fire extinguisher needs recharging/3. Bsmt. needs cleaning	OK on Reinsp. 6-11-71
4-19-73	Lt. Fair	E-1	I	Cheryl Lightfoote	1. Install exit signs w/ arrow pointing to exits, 2nd, 3rd & 4th floors. (OVER)	O. I. 5- 7-73 O. K. 7-23-73
2-25-74	F. S. Complaint				Wall collasped & not removed. Basement cluttered w/debris.	No Cause 2-26-74
6-11-74	Capt. Luciano	E-1	IV	Cheryl Lightfoote	1. All fire extinguishers are to be sent out to be properly checked, recharged & updated. (OVER)	O. I. 8-27-74 O. K. 9-24-74

DATE OF INSPECTION	VIOLATIONS CONT'D
4-19-73	2. Install self-closer on fire doors on 2nd floor near stairwell. 3. Fire extinguishers are to be recharged & up-~~xxxxxxxxx~~ dated, hang on wall fire extinguisher on 4th floor. 4. All flammable materials are to be ~~taken~~ moved away from heating unit. 5. Boiler Room and Storage Room in cellar in need of cleaning, remove all articles of no value & properly dispose of them.