

JAYC Fire Equipment Co.
210 Delamaine Drive, Rochester, NY 14621

585-509-8235
E-Mail: jaycfire@rochester.rr.com

RESTAURANT FIRE SYSTEM INSPECTION REPORT

Service Tech: Chuck Fenell/Steph Date: 1/26/2012
Customer Name: Fair Fish Market
Street/PO Box: 330 North Goodman
City: Rochester State: NY Zip Code: 14609 Contact:

Mfg. of System: Model #: Ansul Interval Annual [ ] Type: Wet [x]
Local AHJ: Rochester Semi-Annual [x] Dry [ ]
Size of System: 3 GAL Other [ ]
Last 6-year Maint.:
Last Hydrostatic Test: 2010

Type of Fuel Shutdown Device:
Mechanical Gas Shut Down Valve: Yes Electrical Contact Shut Down: N/A
Electric Gas Shut Off Valve w/ Reset Relay: N/A
Manual Release present? (Y/N): Accessible Control Head: Yes

Is System Connected to Building Fire Alarm? (Y/N)
Number of Fusible Links - 360F
450F (2)
Other
Number of Ducts: 1
Size of Ducts: 1 1/2" Rector
Plenum Size: 7 1/2"

Table with 4 columns: List of Appliances (Left to Right), Size, Nozzle Type, Nozzle Quantity. Rows include Wok, Fryer, Fryer.

INSPECTION PROCEDURE - VERIFY SERVICE WITH PROPER AUTHORITY

- CHECK PROPER OPERATION OF
Fusible Link Line [x] Remote Pull Station [x] Control Head [x] Gas Shut Off [x]
- CHECK NOZZLES, CAPS, AND PIPING
No Obstructions [x] Proper Coverage [x] Caps in place [x] Meets Code (Y/N) YES
- CHECK CYLINDER
Pressure in Range [x] No Dents [x] Tank Full [x] No Rust/Corrosion [x]
Fusible Links Replaced Yes CO2 Cartridge Replaced (if applicable)
For Wet Chemical Systems: K Class Fire Extinguisher Present? (Y/N)
Does System meet UL300 Standards? (Y/N) Does System meet Per NFPA 10/17A Standards? (Y/N)

CONDITION OF HOOD:
Hood, Duct and Filters Clean? (Y/N) All Seams Welded and/or Properly Sealed? (Y/N)
Hood & Duct Penetrations Properly Sealed? (Y/N) Baffle Filters (Mesh does not meet code)? (Y/N)
Hood and Duct Meet NFPA 96 Standards? (Y/N)

RECOMMENDATIONS:
1. Additional Nozzles Needed for:
2. Additional Fusible Links Needed for:
3. Fuel Shut Off Needed for: Gas Electric
4. Cylinder Due for: 6 Year Maint. Hydrostatic Test
5. Hood, Duct, and Plenum Require Cleaning \* Yes
6. Filters Require Cleaning (Y/N)
7. Wet Chemical System Needs K Class Extinguisher
8. Other

RECOMMEND SYSTEM UPGRADE? (Y/N)
REASON:

Per New York State Code: A Copy of this report will be sent to the local authority having jurisdiction for their review

At JayC Fire Equipment, we strive to ensure that your fire suppression system will meet all current codes for your protection. Any Recommendations made are for the purpose of meeting NFPA and UL 300 Codes. It is the responsibility of your establishment to authorize upgrades as recommended.

Signature: X Samy Pyle
Date: X Samy Pyle