



City of Rochester FIRE DEPARTMENT

FIRE SAFETY DIVISION
185 Exchange Blvd., Suite 665
Rochester, New York 14614
(585) 428-7037

PERMIT

DATE: 05/1/2013

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN

By Virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

GOODAMN PIZZA – MO JOE’S
836 N GOODMAN ST

PERMIT NUMBER: 14-04188

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and the PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B16D	COMM'L COOK-OVEN AND APPL	\$ 70

TOTAL: \$ 70

This PERMIT is issued and accepted on condition that all Fire Prevention Code provisions now adopted, or that may hereafter be adopted, shall be complied with, and said PERMIT will become valid only after receipt of total fee payment.

THIS PERMIT EXPIRES: 04/30/14

This permit does not take the place of any License required by law and is not transferable. Any change in the use of occupancy of premises shall require a new permit.

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE


Fire Marshal

Return this part with payment – please write permit number on your check or money order.

MAKE YOUR CHECK OR MONEY ORDER, PAID IN FULL,
PAYABLE TO CITY TRESURER AND MAIL TO:

ROCHESTER FIRE DEPARTMENT
ATTENTION: ACCOUNTS RECEIVABLE
185 EXCHANGE BLVD., SUITE 663
ROCHESTER, NEW YORK 14614

PERMIT NUMBER: 14-04188
PERMIT ADDRESS: 00836 N GOODMAN ST
INVOICE DATE: 05/01/2013
DATE PAID: 05/01/2013
AMOUNT PAID: \$ 70

GOODMAN PIZZA – MO JOE’S
836 N GOODMAN ST # 8
ROCHESTER NY 14609

*pd. cash for
6/12/13*



City of Rochester FIRE DEPARTMENT

FIRE SAFETY DIVISION

185 Exchange Blvd., Suite 665
Rochester, New York 14614
(585) 428-7037

PERMIT

DATE 05/21/13

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

MOJOE'S GOODMAN PIZZA
836 GOODMAN ST N

14-05052	PERMIT NUMBER
----------	---------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B16D	COMM'L COOK-OVEN AND APPL	\$ 70
<i>Delete Duplicate No 1404/88</i>		
TOTAL		\$ 70

This PERMIT is issued and accepted on condition that all Fire Prevention Code provisions now adopted, or that may hereafter be adopted, shall be complied with, and said PERMIT will become valid only after receipt of total fee payment.

THIS PERMIT EXPIRES 05/31/14

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.


FIRE MARSHAL

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

Please return this part with payment

MAKE YOUR CHECK OR MONEY ORDER, PAID IN FULL, PAYABLE TO CITY TREASURER AND MAIL TO:

ROCHESTER FIRE DEPARTMENT
ATTENTION: ACCOUNTS RECEIVABLE
185 EXCHANGE BLVD., SUITE 663
ROCHESTER, NEW YORK 14614

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK OR MONEY ORDER

00836 GOODMAN ST N

14-05052	PERMIT NUMBER
05/21/13	INVOICE DATE
06/21/13	DUE DATE
\$ 70	AMOUNT DUE

MOJOE'S GOODMAN PIZZA
836 N GOODMAN ST
ROCHESTER NY 14609

Exhaust Hood and Duct Installation

SERVICE COMPANY

LAKESIDE FIRE PROTECTION



210 N. LACKAWANNA ST.
WAYLAND, NY 14572
(716) 728-9507

CUSTOMER

Name Donut Diner

Address 936 W. Goodman St

City Rochester NY

Telephone _____ Store No. _____

Owner or Manager _____

PERMIT NO.

Installation Date _____

--	--	--	--	--	--	--	--	--	--

COOKING APPLIANCE LOCATIONS: LEFT TO RIGHT

<u>24" Fryer</u>	<u>48" Griddle</u>	<u>2 burner range</u>	
------------------	--------------------	-----------------------	--

HOOD SIZE (S)

~~_____ ' X _____" Length~~

~~_____ ' X _____" Width~~

~~_____ ' X _____" Depth~~

DUCT SIZE (S)

~~_____ ' X _____"~~

~~_____ ' X _____"~~

~~_____ ' X _____"~~

Type of system Rivrollen

Size PL-460

Maximum Flow Pts. 15

Total Flow Pts. 12

Number of transitions: _____

- | | |
|---|---|
| <ol style="list-style-type: none"> 1. All appliances properly covered w/correct nozzles <u>YES</u> 2. Duct and plenum covered w/correct nozzles <u>YES</u> 3. System installed in accordance w/MFG UL listing <u>YES</u> 4. Hood/duct penetrations sealed w/weld or UL device <u>YES</u> 5. Fan warning sign on hood <u>YES</u> 6. All seams have been welded as per code <u>YES</u> 7. Curbs for exhaust fan welded and properly secured <u>YES</u> 8. Exhaust duct fabricated @ minimum 16 gauge <u>NA</u> 9. Exhaust hood fabricated @ minimum 18 gauge <u>YES</u> 10. UL Baffle Style Filters installed in hood <u>YES</u> 11. Clean out has been placed in duct work for steam cleaning purposes <u>YES</u> | <ol style="list-style-type: none"> 12. If less than 18" from top of ceiling or combustible walls, UL listed insulated panels have been installed to UL specifications <u>YES</u> 13. Exhaust duct less than 18" from combustible materials has been wrapped with UL listed fire watch insulated fiber blanket to UL specifications <u>YES</u> 14. Exhaust hood installed at 6'6" from floor to bottom of hood (typical). With a minimum of 18" clearance from top of hood to ceiling and adjacent combustible walls with 3" airspace behind hood <u>YES</u> 15. Exhaust duct(s) and fan are at least 10' minimum from adjacent property lines as per customer's specifications/survey <u>YES</u> 16. C.F.M.'s of exhaust fan(s) <u>1725</u> M.U.A. _____ |
|---|---|

NOTE DISCREPANCIES OR DEFICIENCIES BELOW

COMMENTS: 1) Pico Chem PCL-4600 inspected - 605.00

2) Hip fire extinguisher inspected - 5.20

70.20

paid in cash

<u>Eugene J. Ball</u>	<u>400901</u>	<u>9/16/10</u>			<u>[Signature]</u>
SERVICE TECHNICIAN	LICENSE NO.	DATE	TIME	AM PM	CUSTOMERS AUTHORIZED AGENT

The above service technician certifies that the system was personally inspected and found conditions to be as indicated on this report. The above said exhaust hood and duct system has been installed to N.F.P.A. 96 Fire Code.



City of Rochester

185 Exchange Boulevard, Suite 665
Rochester, New York 14614-2124
Phone: 585.428.6739
Fax: 585.428.6785
TTY: 585.428.6054
www.cityofrochester.gov



FAX TRANSMISSION COVER SHEET

To: Ed Greer

Company/ Dept.: Family Dollar

Phone #: 1

Fax #: 1888 491 3473

From: Ernest & Flagler-Mitchell

Date: 4/10/13

of Pages: 2 (Page count includes this cover sheet)

Reference: _____

Urgent

Reply ASAP

Please Comment

For Your Records

Fax #
1-888-491-3473
Att: Ed Greer
Family Dollar



City of Rochester

Fire Department
185 Exchange Blvd., Ste 665
Rochester, New York 14614-2124
www.cityofrochester.gov



Fire Safety
Division

COPY

March 4, 2013

Family Dollar # 1806
Attention: Erica Parker
836 N Goodman Street
Rochester, NY 14609

Reference: **FAMILY DOLLAR # 1806 – 836 N GOODMAN STREET**

On February 27, 2013 an inspection was conducted as part of the application process for your Fire Department Permit. The following violation of the New York State Fire Code was found and must be corrected before your permit can be approved. Orders are hereby issued for **immediate correction** of violations listed herein. Compliance shall be verified by the Fire Marshal.

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1 st Offense	\$75.00	\$150.00
2 ND Offense	\$150.00	\$300.00
3 RD & Subsequent	\$375.00	\$750.00

~~Violation Code: 907.3.2~~ *Etc*
~~Violation Description: Smoke detector(s) lacking.~~
~~Violation Summary/Location: Throughout the store.~~

you don't need smoke detectors

Violation Code: 703.1
Violation Description: Fire rated construction: trough penetrations not sealed.
Violation Summary/Location: In the back area of the store.

Violation Code: 605.1
Violation Description: Electrical fixtures: (potential source of ignition) hanging wires etc.
Violation Summary/Location: In the back area of the store.

If you have any questions regarding this inspection or any other Fire Safety issue, please contact Fire Safety Inspector Thomas Tambe at (585)428-3685.

BY ORDER OF
FIRE MARSHAL

, Fire Safety Inspector

XC:

Family Dollar #1806
Store Service
PO Box 1017
Charlotte, NC 28201





City of Rochester
FIRE DEPARTMENT

FIRE SAFETY DIVISION
185 Exchange Blvd., Suite 665
Rochester, New York 14614
(585) 428-7037

PERMIT

DATE: 09/16/2013

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN

By Virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

FAMILY DOLLAR STORE #1806
836 N GOODMAN ST

PERMIT NUMBER: 14-03044

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and the PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10C1	FLAM/COMB LQD CLS I, II, III	\$ 80
5412B17	CMBSTBL MAT'L STORGE-OVER 2500 CU FT	\$ 100


TOTAL: \$ 180

This PERMIT is issued and accepted on condition that all Fire Prevention Code provisions now adopted, or that may hereafter be adopted, shall be complied with, and said PERMIT will become valid only after receipt of total fee payment.

THIS PERMIT EXPIRES: 03/31/14

This permit does not take the place of any License required by law and is not transferable. Any change in the use of occupancy of premises shall require a new permit.

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE


Fire Marshal

Return this part with payment - please write permit number on your check or money order.

MAKE YOUR CHECK OR MONEY ORDER, PAID IN FULL,
PAYABLE TO CITY TRESURER AND MAIL TO:

ROCHESTER FIRE DEPARTMENT
ATTENTION: ACCOUNTS RECEIVABLE
185 EXCHANGE BLVD., SUITE 663
ROCHESTER, NEW YORK 14614

PERMIT NUMBER: 14-03044
PERMIT ADDRESS: 00836 N GOODMAN ST
INVOICE DATE: 09/16/2013
DATE DUE: 10/16/2013
AMOUNT DUE: \$ 180

FAMILY DOLLAR STORE #1806
STORE SERVICE
PO BOX 1017
CHARLOTTE NC 28201

pd. 10/16/13




**City of Rochester
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

185 Exchange Blvd., Suite 665
Rochester, New York 14614
(585) 428-7037

PERMIT

DATE 05/01/13

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

DONUT DINER
836 GOODMAN ST N

14-04067	PERMIT NUMBER
----------	---------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B16C	COMM'L COOK-APPL PROD GREASE/VAPOR	\$ 70
		TOTAL \$ 70

This PERMIT is issued and accepted on condition that all Fire Prevention Code provisions now adopted, or that may hereafter be adopted, shall be complied with, and said PERMIT will become valid only after receipt of total fee payment.

THIS PERMIT EXPIRES 04/30/14

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

[Signature]
FIRE MARSHAL

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

Please return this part with payment

MAKE YOUR CHECK OR MONEY ORDER, PAID IN FULL, PAYABLE TO CITY TREASURER AND MAIL TO:

ROCHESTER FIRE DEPARTMENT
ATTENTION: ACCOUNTS RECEIVABLE
185 EXCHANGE BLVD., SUITE 663
ROCHESTER, NEW YORK 14614

PLEASE WRITE PERMIT NUMBERS

ON YOUR CHECK OR MONEY ORDER

00836 GOODMAN ST N

14-04067	PERMIT NUMBER
05/01/13	INVOICE DATE
06/01/13	DUE DATE
\$ 70	AMOUNT DUE

pd: 5/9/13
JA

DONUT DINER
836 N GOODMAN ST
ROCHESTER NY 14609

Permit fee payments not received by the due date will be considered delinquent.

These delinquent properties operating with invalid permits will be subject to the issuance of a Municipal Code Violations Summons pursuant to Chapter 54-10 of the Municipal Code.

Municipal Code Summons Schedule

	Initial	Default
1st Offense, or after 30 days	\$ 75.00	\$150.00
2nd Offense, or after 60 days	\$150.00	\$300.00
3rd Offense, or after 90 days	\$375.00	\$750.00



City of Rochester

Fire Department
 185 Exchange Boulevard, Suite 665
 Rochester, New York 14614-2124
 www.cityofrochester.gov



Fire Safety
 Division

Ro

May 2013

PERMIT APPLICATION

Business Name on permit: Goodman Pizzeria (no Joe's) Business Phone: (585) 288-4727

Type of Operation: _____

Permit Location / Job Site 836 W. Goodman St Rochester Westwood
 Street Address Suite/Room City/State/Zip 14609

Mailing Address (if different): _____
 Street Address Suite/Room City/State/Zip

Contact Person's Name: Fadil Saleh Contact Phone: (585) 406-8411

Emergency Contact: _____ Contact Phone: () _____

To use, maintain, store, manufacture, transport, stall, conduct processes or carry on operations involving or creating conditions deemed hazardous to life or property. Application is hereby made by the undersigned for a permit to use, maintain, install, store, operate, manufacture, conduct or transport the following materials, processes or operations.

Permit Code	Description	Fee
<u>5412B16D</u>	<u>Combination of BOC</u>	<u>70</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

	Y	N
Sprinkler System		/
Alarm Permit		/
Cooking Hood	/	
Fire Alarm System		/
Standpipe System		/
Cooking System	/	
Bars/Wires on Windows	/	
Lock Box		/
NFPA 901 Type		
Building Const Type		
Number of Stories		
Posted Occupancy		

Conditions, surroundings and arrangements shall be in accordance with the Fire Code of New York State and the Policies and Procedures of the Fire Marshal's Office. Complete plans and construction details must be filed on all major projects and when requested by the Fire Marshal.

Applicant's Name: _____

Applicant's Signature: Fadil Saleh
 (Please Print Clearly)

Fire Inspectors Name: Fadil Saleh Date: 4-24-13
Flagler-Mizwell

FOR OFFICE USE ONLY

DATE PERMIT ISSUED: _____ 20 _____ DATE EXPIRES: 5-31

PERMIT NUMBER: _____ FEE TOTAL: \$ 70

