



City of Rochester
 FIRE DEPARTMENT
 OFFICE OF THE FIRE MARSHAL

Room 300
 Public Safety Building
 Civic Center Plaza
 Rochester, New York 14614
 (716) 428-7037

NOTICE OF VIOLATIONS

December 12, 1989

COPY

Wilkins Construction
 176 Anderson Avenue
 Rochester, New York 14607

PLEASE TAKE NOTICE THAT an inspection at

176 ANDERSON AVENUE ROCHESTER NEW YORK

reveals violation(s) of the Fire Prevention Code of the City of Rochester and/or the Codes, Rules and Regulations of the State of New York.

Orders are hereby issued for the violation(s) to be corrected on or before the reinspection scheduled for DECEMBER 19, 1989.

Failure to comply with these orders will result in the issuance of a Municipal Code Violation Summons for each uncorrected violation with the following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50.00	\$100.00
2nd OFFENSE	100.00	200.00
3rd OFFENSE	250.00	500.00

During this period, the property owner continues to be responsible and liable for any damages arising from the violation(s).

Relevant section(s) of the New York State Uniform Fire Prevention and Building Code (Title 9 NYCRR) to wit:

1163.11g All exposed wiring shall be enclosed or protected according to applicable generally accepted standards.
 (PLUGS HANGING OUT OF JUNCTION BOX SHALL BE PLACED INSIDE AND HAVE A PROPER COVER INSTALLED - (NEAR THE DOORWAY and ALSO ON CEILING).

BY ORDER OF THE FIRE MARSHAL

INSPECTOR: _____
 RONALD SHILO 6546

DATE OF COMPLIANCE: _____

INSPECTOR: _____

U-3-80

Fire Dept.
Fire Safety Division
Public Safety Bldg.
Rochester, N.Y. 14614



OFFICE OF THE
FIRE MARSHAL
TELEPHONE: 428-7037

442
6025

NOTICE OF VIOLATIONS

DATE 12/12/89

Wilkens Const. Name 176 Anderson Ave Address

Inspection of premises located at same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 12/19/89

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

(1163.115) Plug hanging out of Junction Box shall be fixed inside - & have proper cover installed (near doorway) Also on ceiling OK 1-5-90

By Order of
FIRE MARSHAL

INSPECTOR Alan Stuber 6546

DATE of COMPLIANCE 1-5-90

Inspector Stuber

FD506



City of Rochester
FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL

Room 300
 Public Safety Building
 Civic Center Plaza
 Rochester, New York 14614
 (716) 428-7037

NOTICE OF VIOLATIONS

December 12, 1989

COPY

Jamison Wood Products
 176 Anderson Avenue
 Rochester, New York 14607

PLEASE TAKE NOTICE THAT an inspection at

176 ANDERSON AVENUE ROCHESTER NEW YORK

reveals violation(s) of the Fire Prevention Code of the City of Rochester and/or the Codes, Rules and Regulations of the State of New York.

Orders are hereby issued for the violation(s) to be corrected on or before the reinspection scheduled for DECEMBER 19, 1989.

Failure to comply with these orders will result in the issuance of a Municipal Code Violation Summons for each uncorrected violation with the following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50.00	\$100.00
2nd OFFENSE	100.00	200.00
3rd OFFENSE	250.00	500.00

During this period, the property owner continues to be responsible and liable for any damages arising from the violation(s).

Relevant section(s) of the New York State Uniform Fire Prevention and Building Code (Title 9 NYCRR) to wit:

1163.13e-3 Portable fire extinguishers shall be appropriate as to type, size and location, listed by a nationally accepted testing laboratory, and shall be in their designated location and clearly visible, except that they may be located in an enclosure or recess conspicuously identified as containing a fire extinguisher. (FIRE EXTINGUISHER OF PROPER SIZE AND TYPE SHALL BE INSTALLED IN SHOP ABC 5# SHOULD BE ADEQUATE).

BY ORDER OF THE FIRE MARSHAL

INSPECTOR: _____
 RONALD SHILO

DATE OF COMPLIANCE: _____

INSPECTOR: _____



NOTICE OF VIOLATIONS

244-5910

DATE 12-12-89

Samson Wood Products
Name

176 Anderson Ave
Address

Inspection of premises located at Same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 12/19/89

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

(1163.13e-3) Fire extinguisher of Brown Size & Type shall be installed in Shop ABC 5# should be enough
OK 1-5-90

By Order of
FIRE MARSHAL

INSPECTOR Ronald Dub 6546

DATE of COMPLIANCE 1-5-90

Inspector Dub



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION:

176 ANDERSON AVENUE

07114	PERMIT NUMBER
02-15-89	DATE
\$ 65.00	FEE TOTAL
4/25/89	DATE RELEASED
02-28-90	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B08	DUST PRODUCING OPERATION	\$ 40.00
5412B10A	FLAMMABLE LIQUID STORAGE	25.00
	TOTAL	\$65.00

THIS IS YOUR INVOICE, PERMIT WILL BE ISSUED UPON PAYMENT

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

NAME
MICA CONCEPTS
MAILING ADDRESS
176 ANDERSON AVENUE
ROCHESTER, NEW YORK 14607

CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

11120	PERMIT NUMBER
11/13/89	DATE
30 -	FEE TOTAL
11/27/89	DATE RELEASED
12/31/90	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B12H	HIGHLY TOXIC MATERIAL	\$ 30

THIS IS NOT
A PERMIT

TOTAL \$ 30

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME

MAILING ADDRESS

AFFORDABLE EXTERMINATING
176 ANDERSON AVE
ROCHESTER NY 14607

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION:

176 ANDERSON AVENUE

07112	PERMIT NUMBER
02-15-89	DATE
\$65.00	FEE TOTAL
4/25/89	DATE RELEASED
02-28-90	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B08	DUST PRODUCING OPERATION	\$ 40.00
5412B10A	FLAMMABLE LIQUID STORAGE	25.00
	tOTAL	65.00

THIS IS YOUR INVOICE, PERMIT ISSUED UPON RECEIPT OF PAYMENT

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

NAME **WILKINS COMMERCIAL CONSTRUCTION**
MAILING ADDRESS **176 ANDERSON AVENUE
ROCHESTER, NEW YORK 14607**

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION:

176 ANDERSON AVENUE

07113	PERMIT NUMBER
02-15-89	DATE
\$40.00	FEE TOTAL
4/25/89	DATE RELEASED
02-28-90	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B08	DUST PRODUCING OPERATION	\$40.00

THIS IS YOUR INVOICE, PERMIT WILL BE ISSUED UPON RECEIPT OF PAYMENT

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME
MAILING ADDRESS
**JAMISON WOOD PRODUCTS
176 ANDERSON AVENUE
ROCHESTER, NEW YORK 14607**

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

FILE

0104194

CITY COURT SUMMONS

THE PEOPLE OF THE STATE OF NEW YORK -VS-

Joe Stepien - Rochester Co
 Last Name (Defendant) Anderson First As M.I.
 Street Address 176 Anderson Ave Apt. #
 City Worcester MA State MA Zip 01098

D.O.B. Sex Summons Issued To
LICENSE INFORMATION
 License # Exp Date / /
 Amusement Cent Entertainment Cent Alarm Permit
 Taxi Driver Sol/Vendor
 Dog Color Breed (M) (F)

VEHICLE DESCRIPTION
 Year Make Type Ctr MV Reg # HK Plt#
 PERSON ABOVE IS CHARGED AS FOLLOWS:

Row of 176 Anderson Ave
 Place of Occurrence Rochester, Monroe Co., N.Y.
 Date 9/20/80 Time 11:00 A.M./P.M.
 OFFENSE Disorderly Tenement
 In violation of SEC (1101.3A-3) SUB 9A1400R of
 the Code of the City of Rochester, N.Y. (242.10B)
 per pleu.

ON 8-11-80 Joe Stepien was notified
 of Row 440 to the Anderson Ave
 at this time old man Brown discarded
 Bldg. MAT. were found THROUGH ABOUT
 YARD. ALSO IN THE WEEDS NEAR R.R.
 TRACKS. ORDER WAS ISSUED NO WORK
 DONE. ALSO AT THE NOTICE AND JUNKED
PERSON ABOVE IS SUMMONED TO APPEAR AT:

CITY COURT PART I
 150 S. Plymouth Ave., Rochester, N.Y.
 APPEARANCE DATE: 4th day of 1980 at 11:00 A.M./P.M.

FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT Henry J. ...
 IBM 6546 SEC ...

COURT APPEARANCE

DISPOSITION MCVB Use Only

by Mail
 Amount paid \$
 Received by
 Schedule
 Hearing date
 Hearing officer
 Disposition Default - \$ 200 (1)
10/4/80

Court Use Only

Right to aid of Counsel
 Public Reading
 Assigned
 Released
 Cash Bond
 Forfeited Exonerated

	P	D	Judge

Guilty Not Guilty
 Fine or Days in City Jail
 Advised of right to appeal
 Reason
 Amount Fine Paid Date Entered by

K



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

10334	PERMIT NUMBER
06/22/89	DATE
65-	FEE TOTAL
7/14/89	DATE RELEASED
07/31/90	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 25
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 40

THIS IS NOT
A PERMIT

TOTAL \$ 65

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME
MAILING ADDRESS

RAY ROGERS
CENTRAL TRUST CO ANNEX
44 EXCHANGE ST
ROCHESTER NY 14614

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 176 ANDERSON AV

08852	PERMIT NUMBER
03/23/89	DATE
140-	FEE TOTAL
4/10/89	DATE RELEASED
04/30/90	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 25
5412B10B	COMBUSTIBLE LQD STORAGE - CLS II, III	\$ 25
5412B12A	COMPRESSED GAS - OVER 2000 CU FT	\$ 50
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 40

THIS IS NOT
A PERMIT

TOTAL \$ 140

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614

NAME

MAILING ADDRESS

JOSEPH STERN & SONS
176 ANDERSON AV
ROCHESTER

NY 14607

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

BUILDING INSPECTION / COMPLAINT FORM



INSPECTION # 52507

COMPANY Q04

ADDRESS

ANDERSON

AV

FROM / TO

176

TAX ACCT #

004600-00.0

PROPERTY OWNER

GARY

STERN

ADDRESS

176 ANDERSON AV

PHONE

461-2380

CITY

ROCHESTER

STATE

NY

ZIP 14607

MAILING NAME

JOSEPH STERN & SONS

ADDRESS

176 ANDERSON AV

PHONE

461-2380

CITY

ROCHESTER

STATE

NY

ZIP 14607

EMERGENCY CONTACT

GARY STERN

ADDRESS

40 EVANDALE RD

PHONE

461-9867

CITY

ROCHESTER

STATE

NY

ZIP 14618

NFPA 901 CODES	GENERAL PROPERTY USE <input type="checkbox"/> 70	SPECIFIC PROPERTY USE <input type="checkbox"/> 773	STRUCTURE TYPE <input type="checkbox"/> 2	STRUCTURE STATUS <input type="checkbox"/> 2
----------------	--	--	---	---

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **VICTOR SCREW PRODUCTS** PHONE
 BUSINESS OWNER ~~DONALD E MC KAY~~ **MANFREDI, J.**
 ADDRESS **176 ANDERSON AV** **ROCHESTER NY 14607**
 PHONE **244 6860**
 BUSINESS EMERGENCY **DONALD E MC KAY**
 ADDRESS **298 HUNTS PARK RD**
 PHONE **924 3884**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

SPECIAL INSTRUCTIONS:

DIRECTION ROOM #, ETC.

COMPLAINT

OK at Time of Inspection

OFFICER PREPARING REPORT: <i>A. C. Billauer</i>	COMPANY <i>Q-4</i>	DISTRICT <i>3</i>	GROUP <i>1</i>	DATE <i>4-18-89</i>
BUS/PROP REPRESENTATIVE: <i>J. Manfredi</i>	POSITION / TITLE <i>owner</i>			DATE
FIRE SAFETY INSPECTOR:				DATE

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
ADDRESS **ANDERSON AV**

FROM / TO
176

INSPECTION # **52504**
TAX ACCT # **004600-00.0**

PROPERTY OWNER
GARY I STERN

ADDRESS **176 ANDERSON AV** PHONE **461-2380**
CITY **ROCHESTER** STATE **NY** ZIP **14607**

MAILING NAME
JOSEPH STERN & SONS

ADDRESS **176 ANDERSON AV** PHONE
CITY **ROCHESTER** STATE **NY** ZIP **14607**

EMERGENCY CONTACT
GARY I STERN

ADDRESS **40 EVANDALE RD** PHONE **461-9867**
CITY **ROCHESTER** STATE **NY** ZIP **14618**

NFPA 901 CODES	GENERAL PROPERTY USE <input type="checkbox"/> 59	SPECIFIC PROPERTY USE <input type="checkbox"/> 591	STRUCTURE TYPE <input type="checkbox"/> 2	STRUCTURE STATUS <input type="checkbox"/> 2
----------------	--	--	---	---

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **CENTRAL TRUST CO** PHONE
BUSINESS OWNER
ADDRESS **176 ANDERSON AV** **ROCHESTER NY 14607**
PHONE **442 1810**
BUSINESS EMERGENCY ADDRESS PHONE

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

SPECIAL INSTRUCTIONS:

DIRECTION ROOM #, ETC.

COMPLAINT

*OK at Time of Inspection
1st floor*

OFFICER PREPARING REPORT: <i>St C. Beluen</i>	COMPANY Q-4	DISTRICT 3	GROUP 1	DATE 4-18-89
BUS/PROP REPRESENTATIVE: <i>Dallas Smith</i>	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04** INSPECTION # **52503**
 ADDRESS **ANDERSON AV** FROM / TO **176** TAX ACCT # **004600-00.0**
 PROPERTY OWNER **GARY STERN** ADDRESS **176 ANDERSON AV** PHONE **000-0000**
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 MAILING NAME **JOSEPH STERN & SONS** ADDRESS **176 ANDERSON AV** PHONE
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 EMERGENCY CONTACT **GARY STERN** ADDRESS **40 EVANDALE DR** PHONE **461-9168**
 CITY **ROCHESTER** STATE **NY** ZIP **14618**

NFPA 901 CODES	GENERAL PROPERTY USE <input type="checkbox"/> 70	SPECIFIC PROPERTY USE <input type="checkbox"/> 758	STRUCTURE TYPE <input type="checkbox"/> 2	STRUCTURE STATUS <input type="checkbox"/> 2
----------------	--	--	---	---

A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
= FLOOR

BUSINESS NAME **ASYMMETRICAL PRESS** PHONE
 BUSINESS OWNER **MITCH COHEN**
 ADDRESS **176 ANDERSON AV** **ROCHESTER NY 14607**
 PHONE **473 6933**
 BUSINESS EMERGENCY **MITCH COHEN**
 ADDRESS **220 GLENHILL DR** **ROCHESTER NY 14618**
 PHONE **271 0876**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

SPECIAL INSTRUCTIONS:

COMPLAINT

DIRECTION ROOM #, ETC.

*Business Vacant at Present
A. C. Bellucci*

OFFICER PREPARING REPORT: <i>A. C. Bellucci</i>	COMPANY Q-4	DISTRICT 3	GROUP 1	DATE 4/17/89
BUS/PROP REPRESENTATIVE:	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE

V3-8

LOCATION:

176 ANDERSON AVENUE

JAMISON WOOD PRODUCTS

LICENSE

TANK REMOVAL

GENERAL

PUBLIC ED.

PERMIT

DATE RECEIVED IN FIRE SAFETY

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OKAY TO FILE

INSPECTOR

02-14-89

02-21-89

X

1 visit

1 correction

FILE

SHILO

X Shilo



3-8
10

NOTICE OF VIOLATIONS

Jim
Billow

244-5910

DATE 2-14-88

JAMISON Wood Prod.
Name

176 ANDERSON Ave
Address

Inspection of premises located at SAME reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 2-21-88

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	<u>INITIAL</u>	<u>FAILURE TO RESPOND</u>
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 NYCRR

(1191.3a-3) SAW dust + wood shaving shall be cleaned up daily

Dust Producing Permit

By Order of
FIRE MARSHAL

INSPECTOR Ken Shilo 6546

DATE of COMPLIANCE _____

Inspector _____



Peter Wilkins
442-7177
442-6025

NOTICE OF VIOLATIONS

DAN

DATE 2/14/89

Wilkins Commercial Const. 176 Anderson Ave
Name Address

Inspection of premises located at Same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 2/21/89

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 NYCRR

① (1163.119) OPEN junction box & exposed wiring on fluorescent lite shall be covered in spray area. (Spliced wiring on fluorescent lite shall be removed.) All junction boxes to be covered. OK 4-12-89

② (1163.11e) All extension cord shall be removed and replaced with hard wire. OK 4-12-89

③ (1163.13e1) All extinguishers shall be checked & retagged expired (1/89) due yearly. 4-12-89 OK

④ (1191.3A-3) pile of wood & sandblast shall be cleaned up daily. (under work bench) 4/12/89

By Order of
FIRE MARSHAL

INSPECTOR

Ron Shilo 6546

DATE of COMPLIANCE 4-12/89

Inspector Shilo

Dust prod.

FLAMM. LIQ.

V 3-7

- GENERAL
- PUBLIC ED.
- PERMIT
- LICENSE
- TANK REMOVAL

LOCATION:

176 ANDERSON AVENUE MICA CONCEPTS

DATE RECEIVED IN FIRE SAFETY	APPOINTMENT	PERSON CONTACTED	NO ENTRY	ORDERS ISSUED	REFERRALS ISSUED	NO WORK DONE	SOME WORK DONE	OTHER	OKAY TO FILE	INSPECTOR
02-14-89		Woody	X							SHILO
02-21-89					X					Shilo
2/28					X					Shilo
3/7		juver				X		cabinet on order		Shilo
3-14					X					Shilo
3/21					X					Shilo
3/28					X					Shilo
4/4						X				Shilo
4-10			X					also deliv. permit collection (N.E.)		Shilo
4-24					X			cabinet on order		
5-1										
5/1/89								2 corrections	X	Shilo

FILE



NOTICE OF VIOLATIONS

DATE 4-19-89

MICA Concepts 170 Anderson Ave
Name Address

Inspection of premises located at Same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 4/26/89

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9/14/89

Mechanical or NATURAL means of ventilation shall be provided.

6/1/89

By Order of
FIRE MARSHAL

INSPECTOR Ron Skulo 6546

DATE of COMPLIANCE 5-1-89

Inspector Skulo

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04** INSPECTION # **52505**
 ADDRESS **ANDERSON AV** FROM / TO **176** TAX ACCT # **004600-00.0**
 PROPERTY OWNER **GARY I STERN** ADDRESS **176 ANDERSON AV** PHONE **461-2380**
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 MAILING NAME **JOSEPH STERN & SONS** ADDRESS **176 ANDERSON AV** PHONE
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 EMERGENCY CONTACT **GARY I STERN** ADDRESS **40 EVANDALE RD** PHONE **461-9867**
 CITY **ROCHESTER** STATE **NY** ZIP **14618**

NFPA 901 CODES	GENERAL PROPERTY USE <input type="checkbox"/> 70	SPECIFIC PROPERTY USE <input type="checkbox"/> 553	STRUCTURE TYPE <input type="checkbox"/> 2	STRUCTURE STATUS <input type="checkbox"/> 2
----------------	--	--	---	---

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **FRAUS EDGAR G PRODUCTIONS** PHONE
 BUSINESS OWNER **EDGAR PRAYS**
 ADDRESS **176 ANDERSON AV ROCHESTER NY 14607**
 PHONE **442 4820**
 BUSINESS EMERGENCY **EDGAR PRAY**
 ADDRESS
 PHONE **473 6795**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

SPECIAL INSTRUCTIONS:

DIRECTION ROOM #, ETC.

COMPLAINT

2nd near north hall near elevator needs to be cleaned up.

Retinspired on 6-28-89

OFFICER PREPARING REPORT: <i>St. C. Belucci</i>	COMPANY Q4	DISTRICT 3	GROUP 1	DATE 4-18-89
BUS/PROP REPRESENTATIVE: EDGAR PRAYS	POSITION / TITLE <i>owner of business</i>			DATE
FIRE SAFETY INSPECTOR:				DATE

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04** INSPECTION # **52506**
 ADDRESS **ANDERSON AV** FROM / TO **176** TAX ACCT # **004600-00.0**
 PROPERTY OWNER **GARY STERN** ADDRESS **176 ANDERSON AV** PHONE **461-2380**
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 MAILING NAME **JOSEPH STERN & SONS** ADDRESS **176 ANDERSON AV** PHONE
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 EMERGENCY CONTACT **GARY STERN** ADDRESS **40 EVANDALE RD** PHONE **461-9867**
 CITY **ROCHESTER** STATE **NY** ZIP **14618**

NFPA 901 CODES	GENERAL PROPERTY USE <input type="checkbox"/> 51	SPECIFIC PROPERTY USE <input type="checkbox"/> 555	STRUCTURE TYPE <input type="checkbox"/> 2	STRUCTURE STATUS <input type="checkbox"/> 2
----------------	--	--	---	---

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **STERN JOSEPH & SONS** PHONE
 BUSINESS OWNER
 ADDRESS
 PHONE
 BUSINESS EMERGENCY
 ADDRESS
 PHONE

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

SPECIAL INSTRUCTIONS:

DIRECTION ROOM #, ETC.

COMPLAINT

lot

Fire Extinguishers outdated

lot

Acetylene Tanks not properly secured

& oxygen tanks not properly secured

lot

Propane ~~Acetylene~~ Tanks ~~in~~ in warehouse not properly secured

Retinspired on 6-28-1989

OFFICER PREPARING REPORT: <i>St. C. Bellucci</i>	COMPANY <i>Q4</i>	DISTRICT <i>3</i>	GROUP <i>1</i>	DATE <i>4-17-89</i>
BUS/PROP REPRESENTATIVE: <i>Barry French</i>	POSITION / TITLE <i>President</i>			DATE
FIRE SAFETY INSPECTOR:				DATE



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

07567	PERMIT NUMBER
06/03/88	DATE
45-	FEE TOTAL
6/3/88	DATE RELEASED
07/31/89	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LIQUID STORAGE	\$ 15
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 30

THIS IS NOT
A PERMIT

TOTAL \$ 45

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME RAY ROGERS
MAILING ADDRESS CENTRAL TRUST CO ANNEX
44 EXCHANGE ST
ROCHESTER NY 14614

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 176 ANDERSON AV

08333	PERMIT NUMBER
11/08/88	DATE
25 -	FEE TOTAL
12/30/88	DATE RELEASED
12/31/89	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B12H	HAZARDOUS CHEMICAL STORAGE	\$ 25

*THIS IS NOT
A PERMIT*

TOTAL \$ 25

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME

MAILING ADDRESS

~~THE BUG STOPS HERE~~ AFFORDABLE
176 ANDERSON AVE EXTERMINATING
ROCHESTER NY 14607

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

LICENSE
 TANK
REMOVAL

GENERAL
PUBLIC ED.
PERMIT

LOCATION: 176 Anderson Ave.

STERN JOSEPH & SONS

DATE RECEIVED
IN FIRE
SAFETY:

04/20/88

DATE

4-22-88

APPOINTMENT

PERSON
CONTACTED

NO ENTRY
ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE
SOME WORK DONE

OTHER

OK TO FILE
INSPECTOR

1-1-0

Pat

1 CORRECTION

Shilo

X

FILE



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

LOCATION: 176 ANDERSON AV

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

04816	PERMIT NUMBER
04/08/88	DATE
135-	FEE TOTAL
5/3/88	DATE RELEASED
05/31/89	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LIQUID STORAGE	\$ 15
5412B10B	COMBUSTIBLE LIQUID STORAGE	\$ 15
5412B12A	HAZARDOUS CHEMICAL STORAGE	\$ 45
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 30
5412B24	PRIVATE PLANT	\$ 30

TOTAL \$ 135

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

NAME

MAILING ADDRESS

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

**JOSEPH STERN & SONS
176 ANDERSON AV
ROCHESTER**

NY 14607

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
ADDRESS
ANDERSON
PROPERTY OWNER
GARY

AV
STERN

FROM / TO
176

ADDRESS

176 ANDERSON AV

CITY **ROCHESTER**
ADDRESS

176 ANDERSON AV

CITY **ROCHESTER**
ADDRESS

40 EVANDALE RD

CITY **ROCHESTER**

INSPECTION # **036284**
SBL #
004600-00.0

PHONE
461-2380
ZIP **14607**
PHONE

PHONE
ZIP **14607**
PHONE

PHONE
ZIP **14618**
PHONE

MAILING NAME
JOSEPH STERN & SONS

EMERGENCY CONTACT
GARY STERN

NFPA 901 CODES	GENERAL PROPERTY USE 51	SPECIFIC PROPERTY USE 555	STRUCTURE TYPE 2	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **STERN JOSEPH & SONS** PHONE
BUSINESS OWNER
ADDRESS
PHONE
BUSINESS EMERGENCY ADDRESS
PHONE

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION, ROOM #, ETC.

COMPLAINT

*No flammable liquid present
None at time of Insp.*

*Open function hoses not corrected
from 8/5/87 Insp.*

OFFICER PREPARING REPORT: <i>R. T. Berger</i>	COMPANY Q4	GROUP 4	DATE 4/18/88
BUS/PROP REPRESENTATIVE:	POSITION / TITLE		DATE
FIRE SAFETY INSPECTOR: <i>Don Shub</i>			DATE 4-22-88

RFD 501 (2/88)



NOTICE OF VIOLATIONS

DATE 2-10-88

Asymmetrical Press
Name

176 Anderson Ave
Address

Inspection of premises located at Same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 2-17-88

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 NYCRR
(1191.3A-3) accumulation of shredded paper plastic bags full of excess paper stock shall be removed. Paper stock shall be kept in orderly fashion.
Some removed 3/22/88

By Order of
FIRE MARSHAL

INSPECTOR Don Dilibo 6546

DATE of COMPLIANCE 3/22/88

Inspector Mulo



NOTICE OF VIOLATIONS

DATE 1/28/88

GARY STERN

ASYMMETRICAL PRESS

176 ANDERSON AVE

Name

Address

Inspection of premises located at SAME reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 2/10/88

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 NYCRR

X (1191.3a3) ALL COMBUSTIBLES SHALL BE REMOVED FROM AREA OF HEATING UNITS
~~OK 3/23/88~~
OK 5-23-88 (W)

(1163.13c3) FIRE EXTINGUISHERS OF PROPER TYPE NEEDED. (A.B.C.) OK 3/29/88 (W)

(1243.10j) FIRE EXTINGUISHERS SHALL BE PROPERLY MOUNTED. (NOT MOUNTED) Ticket issued 3/29/88
WOK 4/28/88 (W) OK 4-28-88

(1162.3c) EXIT DIRECTIONAL SIGNS SHALL BE PLACED IN REAR INDICATING DIRECTION.

X (1162.2d) SELF CLOSER NEEDED ON REAR FIRE DOOR 5/24/88

(1162.3c) DOOR - EXIT SIGN SHALL BE PLACED THEREON.
OK 4/28/88 (W)

By Order of
FIRE MARSHAL

INSPECTOR P. J. [Signature]

DATE of COMPLIANCE 5-24-88

Inspector [Signature]

DATE 03-29-88

DEPONENT NAME: RONALD SHILO ADDRESS: 84 Rustic Street

PHONE: 428-7037 WORK

DEPOSES AND SAYS:

I am a Code Enforcement Officer with the City of Rochester Fire Department, the Fire Safety Division.

On January 28th, 1988 I went to 176 Anderson Avenue the Asymmetrical Press to to inspect violations on a line company complaint. I made the owner aware of the violations. I returned on February 10th, 1988 to find the original violation had not been corrected. At this time I found another violation and issued orders again to the owner. I have made the following inspections since with the following explanations:

- 01-28-88 - Original violation issued
- 02-08-88 - No work done to correct
- 02-24-88 - No work done to correct
- 03-09-88 - No work done to correct (Warned ticket would be issued if not corrected.)
- 03-22-88 - Two corrections made.
- 03-29-88 - Tickets issued.

Ticket #0104006 - Violation of Sec 1243.10j of 9 NYCRR.
Ticket #0104007 - Violation of Sec 1191.3A3 of 9 NYCRR.

NOTICE: Any false statements made herein are punishable as a Class A Misdemeanor to Section 210.45, of the New York State Penal Law.

WITNESS [Signature]

DATE 3-29-88

[Signature]
DEPONENT'S SIGNATURE

CODE ENFORCEMENT/FIRE SAFETY

SUPPORTING DEPOSITION

ROCHESTER FIRE DEPARTMENT

0104007

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK - VS

ASymmetrical Pouch
Last Name (Defendant) First
176 Anderson Ave
Street Address Apt #
Rochester NY
City State
11 Tim UALLARD
D.O.B. Sex Summons Issued To

LICENSE INFORMATION

License # Exp Date
 Amusmnt Cent Entmnt Cent Alarm Permit
 Taxi Driver Sol/Vendor Firehuldr
 Dog: Color
Breed (M) (F)

VEHICLE DESCRIPTION

Year Make Type Ctr MV Reg # Hk Pr

PERSON ABOVE IS CHARGED AS FOLLOWS:

176 Anderson Ave
Place of Occurrence Rochester, Monroe Co., N.Y.
3 129 1 8K 1159
Date Time (A.M./P.M.)
OFFENSE
In violation of SEC SUB of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place
Accumulation of waste paper
TRASH mixed business
also animal premises
original writ issued 2/27/84
NOT collected this date
owner gave prior warning

PERSON ABOVE IS SUMMONED TO APPEAR AT:

MUNICIPAL CODE VIOLATIONS BUREAU (ROOM 230)
150 S. Plymouth Ave., Rochester, N.Y.
 CITY COURT PART I
150 S. Plymouth Ave., Rochester, N.Y.
APPEARANCE DATE: 13TH day of APRIL
FINE SCHEDULE: 19 58 at 9:00 (A.M./P.M.)

FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT: Ronald Shilo
IBM: 546 SEC: Fire Safety

OFFICER'S COPY

0104008

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK - VS

ASymmetrical Pouch
Last Name (Defendant) First M.I.
176 Anderson Ave
Street Address Apt #
Rochester NY
City State
11 Tim UALLARD
D.O.B. Sex Summons Issued To

LICENSE INFORMATION

License # Exp Date
 Amusmnt Cent Entmnt Cent Alarm Permit
 Taxi Driver Sol/Vendor Firehuldr
 Dog: Color
Breed (M) (F)

VEHICLE DESCRIPTION

Year Make Type Ctr MV Reg # Hk Pr

PERSON ABOVE IS CHARGED AS FOLLOWS:

176 Anderson Ave
Place of Occurrence Rochester, Monroe Co., N.Y.
3 129 1 8K 1159
Date Time (A.M./P.M.)
OFFENSE: Fire ext. not mounted
In violation of SEC 243.10j SUB 9MPCRR of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place
original writ issued 1/28/84
upon 12SP this date was
NOT collected. owner
was given prior warning

PERSON ABOVE IS SUMMONED TO APPEAR AT:

MUNICIPAL CODE VIOLATIONS BUREAU (ROOM 230)
150 S. Plymouth Ave., Rochester, N.Y.
 CITY COURT PART I
150 S. Plymouth Ave., Rochester, N.Y.
APPEARANCE DATE: 13TH day of APRIL
FINE SCHEDULE: 19 58 at 9:00 (A.M./P.M.)

FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT: Ronald Shilo
IBM: 6546 SEC: Fire Safety

OFFICER'S COPY

BUILDING INSPECTION / COMPLAINT FORM



INCIDENT # 176-186 INSPECTION # 8, 702487

ADDRESS 1761 ANDERSON AVE

PROPERTY OWNER GARY STERN ADDRESS 40 EVANDALE RD PHONE 461-9867

EMERGENCY CONTACT SAME ADDRESS SAME PHONE

COMPLAINANT ADDRESS PHONE

004600-00.0

NFPA 901 CODES GENERAL PROPERTY USE 511 SPECIFIC PROPERTY USE 555 STRUCTURE TYPE 12 STRUCTURE STATUS 12

A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
= FLOOR

BUSINESS: NAME JOSEPH STERN & SONS INC. PHONE 461 2380

OWNER GARY STERN

ADDRESS 40 EVANDALE RD. PHONE 461 9867

EMERGENCY CONTACT SAME PHONE

DISPOSITION by FIRE SAFETY:

NOT REQUIRED
CORRECTED
ORDERS ISSUED
REFERRED

DIRECTION, ROOM #, ETC.

NATURE of VIOLATION or COMPLAINT

DIRECTION, ROOM #, ETC.	NATURE of VIOLATION or COMPLAINT	DISPOSITION by FIRE SAFETY:
1 1	SHEET METAL SHOP - OPEN JUNCTION BOXES ON CEILING & WALLS	X
2 1	SHEET METAL SHOP - SWITCH PLATE ON LIGHT SWITCH MISSING	X
3 1	SHEET METAL SHOP - FIRE EXTINGUISHER OUT OF DATE & ONE NOT MOUNTED	X
4 1	WAREHOUSE - OPEN JUNCTION BOX	
5 1	" - FIRE DOOR IN SUSPENDED LINK BROCKED OPEN TIRES & DEBRIS	X
6 1	WAREHOUSE - GENERAL CLEAN-UP of MATERIAL NOT USED PROPER EX + EXTINGUISHER SECURE TRUCKS	X

OFFICER PREPARING REPORT: T. G. W. TYLER COMPANY E-9 GROUP 3 DATE 8/5/87

BUS/PROP REPRESENTATIVE: X Bob Malek POSITION/TITLE SEC. DATE 8/5/87

FIRE SAFETY INSPECTOR: [Signature] DATE 1/28/88



NOTICE OF VIOLATIONS

DATE 1/28/88

JOSEPH STERN + SON
Name

176 ANDERSON AVE
Address

Inspection of premises located at SAME reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 2/10/88

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 NYCRR

(1163.13e1) FIRE EXTINGUISHERS SHALL BE UPDATED

(1243.10J) + PROPERLY HUNG O.K. 2-10-88 (M)

(1163.11g) COVER PLATE NEEDED ON SWITCH PLATE IN SHEET METAL SHOP. O.K. 2-10-88 (M)

(1162.2a) FIRE DOOR IN WAREHOUSE SHALL BE MADE OPERABLE + OBSTRUCTIONS REMOVED. O.K. 2-10-88 (M)

(1163.13e3) PROPER EXTINGUISHERS (NEEDED IN GARAGE) ACETYLENE PROpane TANKS IN GARAGE SHALL BE SECURED TO WALL. O.K. 2-10-88 (M)

(1191.3a3) ALL COMBUSTIBLE BY OVERHEAD DOOR OF NO VALUE SHALL BE REMOVED FROM BLDG. O.K. 2-10-88 (M)

By Order of
FIRE MARSHAL

INSPECTOR P. Fantigrassi

DATE of COMPLIANCE 2-10-88

Inspector Don DeLuca



BUILDING INSPECTION / COMPLAINT FORM

COMPANY **Q04**
ADDRESS
ANDERSON
PROPERTY OWNER
GARY

AV
STERN

FROM / TO
176

INSPECTION # **036285**
SBL #
004600-00.0

PHONE
461-2380
ZIP **14607**
PHONE
461-2380
ZIP **14607**
PHONE
461-9867
ZIP **14618**

MAILING NAME
JOSEPH STERN & SONS

EMERGENCY CONTACT
GARY STERN

ADDRESS
176 ANDERSON AV
CITY **ROCHESTER** STATE **NY**
ADDRESS
176 ANDERSON AV
CITY **ROCHESTER** STATE **NY**
ADDRESS
40 EVANDALE RD
CITY **ROCHESTER** STATE **NY**

NFPA 901 CODES	GENERAL PROPERTY USE 70	SPECIFIC PROPERTY USE 773	STRUCTURE TYPE 2	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
= FLOOR

BUSINESS NAME **VICTOR SCREW PRODUCTS** PHONE
BUSINESS OWNER **DONALD E MC KAY**
ADDRESS **176 ANDERSON AV** **ROCHESTER NY14607**
PHONE **244 6860**
BUSINESS EMERGENCY **DONALD E MC KAY**
ADDRESS **298 HUNTS PARK RD** **PHONE 924 3884**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION, ROOM #, ETC.

COMPLAINT

None at time of drop

OFFICER PREPARING REPORT: <i>L.T. Bergin</i>	COMPANY Q41	GROUP 4	DATE 4/18/08
BUS/PROP REPRESENTATIVE:	POSITION / TITLE		DATE
FIRE SAFETY INSPECTOR:			DATE

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
 ADDRESS
ANDERSON AV
 PROPERTY OWNER
GARY I STERN
 MAILING NAME
JOSEPH STERN & SONS
 EMERGENCY CONTACT
GARY I STERN

FROM / TO
176
 ADDRESS
176 ANDERSON AV
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 ADDRESS
176 ANDERSON AV
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 ADDRESS
40 EVANDALE RD
 CITY **ROCHESTER** STATE **NY** ZIP **14618**

INSPECTION # **036283**
 SBL #
004600-00.0
 PHONE
461-2380
 PHONE
461-9867

NFPA 901 CODES	GENERAL PROPERTY USE 70	SPECIFIC PROPERTY USE 553	STRUCTURE TYPE 2	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **PRAUS EDGAR G PRODUCTIONS** PHONE
 BUSINESS OWNER **EDGAR PRAY**
 ADDRESS **176 ANDERSON AV ROCHESTER NY 14607**
 PHONE **442 4820**
 BUSINESS EMERGENCY **EDGAR PRAY**
 ADDRESS
 PHONE **473 6795**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED

DIRECTION, ROOM #, ETC.

COMPLAINT

None at time of Insp.
This business inspected Aug 1987.

OFFICER PREPARING REPORT: <i>H. J. Meyer</i>	COMPANY: <i>Q/C</i>	GROUP: <i>9</i>	DATE: <i>9/18/88</i>
BUS/PROP REPRESENTATIVE:	POSITION / TITLE		DATE
FIRE SAFETY INSPECTOR:			DATE

RFID 501 (2/88)

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
ADDRESS
ANDERSON AV
PROPERTY OWNER
GARY I STERN
MAILING NAME
JOSEPH STERN & SONS
EMERGENCY CONTACT
GARY I STERN

FROM / TO
176
ADDRESS
176 ANDERSON AV
CITY
ROCHESTER STATE
NY ZIP
14607
PHONE
461-2380
INSPECTION #
036282
SBL #
004600-00.0
ADDRESS
176 ANDERSON AV
CITY
ROCHESTER STATE
NY ZIP
14607 PHONE
461-9867
ADDRESS
40 EVANDALE RD
CITY
ROCHESTER STATE
NY ZIP
14618

NFPA 901 CODES	GENERAL PROPERTY USE 59	SPECIFIC PROPERTY USE 591	STRUCTURE TYPE 2	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
= FLOOR

BUSINESS NAME **CENTRAL TRUST CO** PHONE
BUSINESS OWNER
ADDRESS **176 ANDERSON AV** **ROCHESTER NY 14607**
PHONE **442 1810**
BUSINESS EMERGENCY ADDRESS PHONE

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION, ROOM #, ETC.

COMPLAINT

None at time of inspection

OFFICER PREPARING REPORT: <i>[Signature]</i>	COMPANY Q04	GROUP 4	DATE 4/18/88
BUS/PROP REPRESENTATIVE:	POSITION / TITLE		DATE
FIRE SAFETY INSPECTOR:			DATE

RFD 501 (2/88)

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
ADDRESS
ANDERSON
PROPERTY OWNER
GARY

AV
STERN

FROM / TO
176

ADDRESS
176 ANDERSON AV

CITY **ROCHESTER** STATE **NY**

ADDRESS
176 ANDERSON AV

CITY **ROCHESTER** STATE **NY**

ADDRESS
40 EVANDALE DR

CITY **ROCHESTER** STATE **NY**

INSPECTION # **036281**
SBL #
004600-00.0

PHONE
000-0000
ZIP **14607**
PHONE

PHONE
461-9168
ZIP **14618**

MAILING NAME
JOSEPH STERN & SONS

EMERGENCY CONTACT
GARY STERN

NFPA 901 CODES	GENERAL PROPERTY USE 70	SPECIFIC PROPERTY USE 758	STRUCTURE TYPE 2	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
= FLOOR

BUSINESS NAME **ASYMMETRICAL PRESS**
BUSINESS OWNER *Mitch Cohen*
ADDRESS *220 Glen Hill Dr*
BUSINESS EMERGENCY *Same*
ADDRESS

PHONE **473-6933**

PHONE **271-0876**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION, ROOM #, ETC.

COMPLAINT

The safety inspected in Feb - and March of 1988. Violations recorded at that time

OFFICER PREPARING REPORT:

St. J. Geiger

COMPANY

Q4

GROUP

4

DATE

4/18/88


BUS/PROP REPRESENTATIVE:

POSITION / TITLE

DATE

FIRE SAFETY INSPECTOR:

DATE



NOTICE OF VIOLATIONS

DATE 4-19-88

Gary Stern
Name

176 Anderson Ave
Address

Inspection of premises located at seen reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: immediately

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

The 1000 gal underground tank that in the rear of 176 Anderson Ave shall be removed from the site immediately.

Gary Stern
461-2380

OK to file
Tank Removed
4-21-88
A Gelle

By Order of
FIRE MARSHAL

INSPECTOR Anthony Gellis 6519

DATE of COMPLIANCE 4-21-88

Inspector A Gelle



**CITY OF ROCHESTER
FIRE DEPARTMENT
FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION:

176 Anderson Avenue

06664	PERMIT NUMBER
12-29-87	DATE
25 ⁻	FEE TOTAL
1/7/88	DATE RELEASED
12-31-88	EXPIRATION DATE

PERMIT CODE

PERMIT CATEGORY

FEE

5412B12H Toxic Material Storage

\$25.00

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

NAME

MAILING
ADDRESS

The Bug Stops Here
176 Anderson Avenue
Rochester 14607

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

DATE/TIME 12-29-87 3:30 p.m.

DEPONENT NAME: Ronald Shilo ADDRESS: 150 S. Plymouth Avenue
Rochester, NY 14614

PHONE: Home -- Business 428-7037

Deposes and says that at about 8:30 a.m., on 12-29-87

At this date and time it was made known to me by the Fire Marshal that at the 2nd alarm fire at 176 Anderson Avenue on December 24, 1987 at 23:03 hours, the sprinkler system was shut down at said building. The Fire Marshal told me to further investigate the situation and issue a ticket to Mr. Gary Stern, owner of said building, for unauthorized shut down of system. Upon conversation with Mr. Stern he admitted that the sprinkler system was disconnected from building and shut down. I then issued a summons as ordered by the Fire Marshal.

*No Show \$500⁰⁰
DEFAULT FOR*

NOTICE: Any false statements made herein are punishable as a Class A Misdemeanor to Section 210.45, of the New York State Penal Law.

WITNESS Capt. Stephen Tanton

Inspector Ron Shilo
Deponent Signature

DATE/TIME 12/29/87 3:30 PM.

ROCHESTER FIRE DEPARTMENT SUPPORTING DEPOSITION CODE ENFORCEMENT/FIRE SAFETY

0104004

OFFICER'S COPY

THE PEOPLE OF THE STATE OF NEW YORK - 10

Last Name (Defendant) STERN First Gary M.I. Ed
 Street Address 40 Euandale Rd Apt. # _____
Rochester NY
 City Rochester State NY Zip _____
 D.O.B. 1/1 Sex Gary Stern Summons Issued To _____

LICENSE INFORMATION

License # _____ Exp Date _____
 Amusmnt Cent Entmnt Cent Alarm Permit
 Taxi Driver Sol/Vendor Alarm Code
 Dog: Color _____
 Breed _____ (M) (F)

VEHICLE DESCRIPTION

Year Make Type Clr MV Reg # HK Pit#

PERSON ABOVE IS CHARGED AS FOLLOWS:

Place of Occurrence 176 (100) Anderson Ave (HO RC)
Rochester, Monroe Co., N.Y.

Date 12/29/87 Time 10:30 AM/PM

OFFENSE SPRINKLER SYSTEM SHUT-OFF

In violation of SEC 163.13b-2 SUB 9 NYC RR of the Code of the City of Rochester, N.Y.

FACTUAL PART: The above named defendant did on the stated date, time and place
The (100) Anderson Ave HO/RC
Scene of 2 Alarm Fire 12/29/87
@ 2303 House. Sprinkler system
was shut off. WAS IN Non
Working condition. at time of
fire.

PERSON ABOVE IS SUMMONED TO APPEAR AT:

- MUNICIPAL CODE VIOLATIONS BUREAU (ROOM 230)
150 S. Plymouth Ave., Rochester, N.Y.
- CITY COURT PART I
150 S. Plymouth Ave., Rochester, N.Y.

APPEARANCE DATE: 13TH day of JAN
 FINE SCHEDULE: 19 88 at 9:00 Dog AM/PM

FALSE STATEMENTS MADE HEREIN ARE PUNISHABLE AS A CLASS A MISDEMEANOR PURSUANT TO SECTION 210.45 OF THE NEW YORK STATE PENAL LAW

COMPLAINANT Row Shulo
 IBM 6546 SEC Fire Dept

OFFICER'S COPY

DATE _____

LOCATION: 00176 ANDERSON AV 03 OWNER: VICTOR SCREW PRODUCTS CO
176 ANDERSON AV
ROCHESTER NY 14607

OCCUPANT: _____ TYPE OF OPERATION: _____
PERSON CONTACTED: _____ PHONE NO: _____ APPOINTMENT: (Y/N) _____

CONDITIONS, SURROUNDINGS AND ARRANGEMENTS FOUND:

CODE FEE PERMIT
5412B10B 0015 03553 FLAMMABLE LIQUID STORAGE *VOID*

.....
.....
..... *NO PERMIT REQUIRED 5/20/87*

VOID

DATE VIOLATIONS ISSUED _____ 19____ CORRECTED _____ 19____

DATE OF APPROVAL FOR PERMIT _____ 19____ SIGNATURE *Joseph Supina*

----- FOR OFFICE USE ONLY -----

DATE PERMIT ISSUED *MAY 19 1987* _____ 19____ DATE EXPIRED _____ 19____

PERMIT NUMBER _____ FEE REQ'D _____



NOTICE OF VIOLATIONS

DATE 8-18-87

Joseph Stern Rogensky Name 170 Anderson Ave Address

Inspection of premises located at same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 8-25-87

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 NYCRR

① (1175.1d) all PROPANE cylinders rear of Bldg. shall be kept in unsecured area provided (several TANKS left standing around unsecured) OK 8/25/87 (M)

② (1191.3A-3) Pile of tires accumulating rear of Bldg. shall be removed (near R/R Tracks) (M) 8/25/87

Tires to be neatly arranged

By Order of
FIRE MARSHAL


INSPECTOR Don Shuls 6546

DATE of COMPLIANCE 9/4/87

Inspector Shuls

V234

Fire Dept.
Fire Safety Division
Public Safety Bldg.
Rochester, N.Y. 14614



OFFICE OF THE
FIRE MARSHAL
TELEPHONE: 428-7037

NOTICE OF VIOLATIONS

DATE July 9, 1987

Joseph Stern Roofing & Siding 176 Anderson Ave
Name Address

Inspection of premises located at same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: July 17, 1987

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
<u>Gary Stern</u>		
<u>461-2380</u>	1st OFFENSE \$ 50	\$100
	2nd OFFENSE \$100	\$200
<u>974CR</u>	3rd & SUBSEQUENT \$250	\$500

(54-226) Dispensing unit shall be repaired and made to operate properly (1164.3a-1)
OK 9/4/87 (D)

(1163.3i) Weeds and/or dry grass shall not be permitted within 10 feet of any LPG gas container OK 8/28/87 (M)

By Order of
FIRE MARSHAL

INSPECTOR Joseph Sapiega 6590

DATE of COMPLIANCE 8/10 9/4/87 Inspector R. Shul



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

03025	PERMIT NUMBER
AUG 5 1987	DATE
30 -	FEE TOTAL
10/28/87	DATE RELEASED
06/30/88	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B12C	HAZARDOUS CHEMICAL STORAGE	\$ 25 per A.S.

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME

MAILING ADDRESS

**FLOWER CITY CHEMICALS
176 ANDERSON AV
ROCHESTER**

NY 14607

TOTAL \$ 25
30 per M.S.

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



176 Anderson Avenue • Rochester, New York 14607 • (716) 461-2380

April 24, 1987

City Of Rochester
Public Safety Building
Rochester, New York 14614


Attention: Joseph Sapiena
Fire Safety Division

This letter serves to inform you of our action to dispose of tires on the property behind 176 Anderson Avenue.

This company has been in contact with John Sabastian's Northside Salvage and U-Need-A-Tire for rental of a "tire cutter" to cut the tires for proper disposal.

We realize the penalty for this situation and our intention is to rid the property of the trash as soon as possible.

Sincerely,



Barry E. French
Vice President

BEF:pam

• CARLISLE and BUILT-UP ROOFING •

Commercial

Industrial

Institutional





NOTICE OF VIOLATIONS

DATE Mar! 25, 1987

Joseph Stern Roofing
Name

176 Anderson Ave
Address

Inspection of premises located at _____ reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: Apr 1, 1987

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
<u>Barry French</u> 1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9474 CBR

(1191.2) Combustible waste, refuse and large quantities of dry vegetation which by reason of their proximity to buildings or structures, would constitute a fire hazard or contribute to the spread of fire shall be removed. (Also refers to 1245.14)

By Order of
FIRE MARSHAL

INSPECTOR Joseph Spicenza

DATE of COMPLIANCE 6/16/87

Inspector Spicenza



BUILDING INSPECTION / COMPLAINT FORM

COMPANY **E09**
ADDRESS

INSPECTION # **018602**

ANDERSON AV

FROM / TO

176

TAX ACCT. #

004600-00.0

PROPERTY OWNER
GARY STERN

ADDRESS

176 ANDERSON AV

PHONE

461-2380

CITY **ROCHESTER**

STATE

NY

ZIP **14607**

MAILING NAME
JOSEPH STERN & SONS

ADDRESS

176 ANDERSON AV

PHONE

CITY **ROCHESTER**

STATE

NY

ZIP **14607**

EMERGENCY CONTACT
GARY STERN

ADDRESS

40 EVANDALE RD

PHONE

461-9867

CITY **ROCHESTER**

STATE

NY

ZIP **14618**

NFPA 901 CODES GENERAL PROPERTY USE **70** SPECIFIC PROPERTY USE **754** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS NAME **WINER FINE HARDWOOD FURNI** PHONE
 BUSINESS OWNER **ALAN WINER**
 ADDRESS **176 ANDERSON AV ROCHESTER NY 14607**
274 N Goodman PHONE **244 5678**
 BUSINESS EMERGENCY **ALAN WINER**
 ADDRESS **120 HILLSIDE AV ROCHESTER NY 14610**
 PHONE **473 2670**

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION, ROOM #, ETC.

COMPLAINT

MOVED TO 274 Goodman ST N.

OFFICER PREPARING REPORT:	COMPANY	GROUP	DATE
BUS/PROP REPRESENTATIVE:	POSITION / TITLE		DATE
FIRE SAFETY INSPECTOR:	DATE		

RFD 501



CITY OF ROCHESTER
FIRE DEPARTMENT
FIRE SAFETY
PERMIT RELEASE & INVOICE

FIRE SAFETY DIVISION

Public Safety Building
 Civic Center Plaza
 Rochester, New York 14614
 (716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

03011	PERMIT NUMBER
JUL 10 1987	DATE
\$135.00	FEE TOTAL
7-23-87	DATE RELEASED
05/01/88	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LIQUID STORAGE	\$ 15
5412B10B	FLAMMABLE LIQUID STORAGE	\$ 15
5412B12A	HAZARDOUS CHEMICAL STORAGE	\$ 45
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 30
5412B24	PRIVATE PLANT	\$ 30

TOTAL \$ 135

MAIL YOUR CHECK OR PRESENT THIS INVOICE
 WITH FEE PAID IN FULL TO:

NAME

MAILING ADDRESS

JOSEPH STERN & SONS
 176 ANDERSON AV
 ROCHESTER

NY 14607

CITY TREASURER
 ROOM 100 A, CITY HALL
 ROCHESTER, NEW YORK 14614

PLEASE WRITE PERMIT NUMBERS
 ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

00620	PERMIT NUMBER
MAY 8 1986	DATE
135-	FEE TOTAL
5/16/86	DATE RELEASED
5/01/87	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LIQUID STORAGE	\$ 15
5412B10B	FLAMMABLE LIQUID STORAGE	\$ 15
5412B12A	HAZARDOUS CHEMICAL STORAGE	\$ 45
5412B17	COMBUSTIBLE MATERIAL STORAGE	\$ 30
5412B24	PRIVATE PLANT	\$ 30

TOTAL \$ 135

MAIL YOUR CHECK OR PRESENT THIS INVOICE WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME

MAILING ADDRESS

JOSEPH STERN & SONS
176 ANDERSON AV
ROCHESTER

NY 14607

PLEASE WRITE PERMIT NUMBERS ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
PERMIT RELEASE & INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

00988	PERMIT NUMBER
JUN 23 1986	DATE
25 ⁰⁰	FEE TOTAL
7/9/86	DATE RELEASED
6/30/87	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B12C	HAZARDOUS CHEMICAL STORAGE	\$ 25

TOTAL \$ 25

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME

MAILING ADDRESS

FLOWER CITY CHEMICALS
176 ANDERSON AV
ROCHESTER

NY 14607

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

BUILDING INSPECTION / COMPLAINT FORM



INCIDENT #		INSPECTION #	8 507879
ADDRESS	176 ANDERSON AVE		
PROPERTY OWNER	GARRY STERN	ADDRESS	40 Evandale Rd (10) PHONE 461-9867
EMERGENCY CONTACT	SAMP	ADDRESS	PHONE 442-7428
COMPLAINANT		ADDRESS	PHONE

004600-80.0

NFPA 901 CODES	GENERAL PROPERTY USE	SPECIFIC PROPERTY USE	STRUCTURE TYPE	STRUCTURE STATUS
	511	18.51		

A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS: NAME Joseph STERN & SONS PHONE 461 2350 OWNER GARRY STERN ADDRESS 176 ANDERSON AVE PHONE 461 7428	DISPOSITION by FIRE SAFETY: <input type="checkbox"/> NOT REQUIRED <input type="checkbox"/> CORRECTED <input type="checkbox"/> ORDERS ISSUED <input type="checkbox"/> REFERRED
---	---	---

DIRECTION, ROOM #, ETC.	NATURE of VIOLATION or COMPLAINT					
2 OFFICES	OK					
Sheet metal GARAGE	Elec outlets NOT MOUNTED					X
Sheet metal GARAGE	Hedges CLEAN UP.					X
1	STORAGE ^{AREA} Hedges CLEAN UP. Excessive STORAGE THROUGH OUT					X
0 REAR	LARGE Pile of TIRES OVER A HEDGEWOOD (OLD TIRES)					X
0	General CLEAN UP OF YARD IN REAR NEEDED.					X
1	JUNK CAR IN BUILDING.					X
0	SKID'S PAPER SCATTER THROUGH OUT YARD IN REAR.					X
1	IN REAR OF BUILDINGS STORAGE AREAS Large amounts of COMBUSTIBLES & Equipment & ACETYLENE TANKS. Equipment STORED INSIDE with Fuel.					X

OFFICER PREPARING REPORT:	COMPANY	GROUP	DATE
LT. F. Gentile	E9	3	8-22-85
BUS/PROP REPRESENTATIVE:	POSITION/TITLE		DATE
			8-22-85
FIRE SAFETY INSPECTOR:			DATE
Joseph Sapienza			4-21-86

V-3026

Fire Dept.
Fire Safety Division
Public Safety Bldg.
Rochester, N.Y. 14614



OFFICE OF THE
FIRE MARSHAL
TELEPHONE: 428-7037

NOTICE OF VIOLATIONS

DATE March 7, 1986

Joseph Stern & Sons Inc 176 Anderson Ave
Name Address

Inspection of premises located at same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: March 14, 1986

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
<u>Nancy Stern</u>		
<u>461-2380</u>	1st OFFENSE \$ 50	\$100
	2nd OFFENSE \$100	\$200
	3rd & SUBSEQUENT \$250	\$500

974 CRE

- OK 1. (1175.1d) Acetylene and oxygen cylinders empty or full shall be secured to prevent being tipped over. (Sheet metal shop)
- OK 2. (1163.11g) Cover shall be installed on breaker box at rear of sheet metal shop.
- OK 3. (1171.3b-3) Fire extinguishers shall be provided where flammable roofing material is stored.
- OK 4. (1175.1c) L.P. Gas storage area located at rear of building shall be provided with a sign identifying the area as flammable gas storage
- OK 5. (1163.11g) Cover shall be installed on open box in office (near door)

By Order of
FIRE MARSHAL

600665

INSPECTOR

Joseph Sapienza
6590

DATE of COMPLIANCE

4/14/86

Inspector

Sapienza



BUILDING INSPECTION / COMPLAINT FORM

INCIDENT # _____

INSPECTION # 8507880

ADDRESS 176 ANDERSON AVE

PROPERTY OWNER GARRY STERN

ADDRESS

PHONE 461-9867

EMERGENCY CONTACT SAME

ADDRESS

PHONE 442-7428

COMPLAINANT

ADDRESS

PHONE

004600-000

NFPA 901 CODES

GENERAL PROPERTY USE L70

SPECIFIC PROPERTY USE L794

STRUCTURE TYPE L1

STRUCTURE STATUS B1

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

BUSINESS:

PHONE 244

DISPOSITION by FIRE SAFETY:

NAME FINE HARDWOOD FURNITURE

NOT REQUIRED

OWNER ALAN WIYER

CORRECTED

ADDRESS _____ PHONE 473 2670

ORDERS ISSUED

DIRECTION, ROOM #, ETC.

NATURE of VIOLATION or COMPLAINT

REFERRED

1 FLOOR

Needs METAL CABINET FOR STORAGE OF SMALL AMOUNTS OF FLAMABLES.



OFFICER PREPARING REPORT: LT. F Gestler

COMPANY E9

GROUP 3

DATE 8-23-85

BUS/PROP REPRESENTATIVE:

POSITION/TITLE

DATE 8-23-85

FIRE SAFETY INSPECTOR:

Joseph Sapientza

DATE 3-14-86

FIRE SAFETY INSPECTION RECORD

507882

LICENSE

GENERAL

TANK REMOVAL

PUBLIC ED.

LOCATION: 176 ANDERSON AVE.

VICTOR SCREW PRODUCTS PERMIT

DATE RECEIVED IN FIRE SAFETY:

FEB 25 1986

DATE

3-14-86

APPOINTMENT

PERSON CONTACTED

NO ENTRY ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

2-2-0

OTHER

OK TO FILE

INSPECTOR

Corrected - New Permit issued

X Lapina



NOTICE OF VIOLATIONS

DATE May 14, 1985

Cornell Sique
 Name

176 Anderson Ave.
 Address

Inspection of premises located at name reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: May 21, 1985

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
Ray Beak		
473-0280	1st OFFENSE \$ 50	\$100
	2nd OFFENSE \$100	\$200
	3rd & SUBSEQUENT \$250	\$500

9NYCER

OK 1) 1163.13e-1 Fire extinguisher shall be updated

OK 2) 1243.10j Fire extinguisher shall be properly mounted

OK 3) 1171.3b-3(iii) All flammable & combustible liquids which are not in use shall be stored in a metal cabinet

By Order of 502096
 FIRE MARSHAL

INSPECTOR Joseph Sapienza ⁶⁵⁹⁰

DATE of COMPLIANCE 5/29/85

Inspector Sapienza



City of Rochester FIRE DEPARTMENT

FIRE SAFETY DIVISION

300 Public Safety Building
Rochester, New York 14614
(716) 428-7037

DATE 02/04/93

PERMIT

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

MICA CONCEPTS
176 ANDERSON AV

94-02002	PERMIT NUMBER
----------	---------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B08	DUST PRODUCING OPERATION	\$ 80
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 50

TREASURER: CLERK

MAY25'93 10:59AM

TRSRUR 01

1 FIRE PVN 130.00

SUBTOTAL 130.00

TOTAL 130.00

CHECK 130.00

ITEM 1

7574 01 0101 MAY25'93 10:59A

THIS PERMIT EXPIRES

02/28/94

FIRE MARSHAL

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

Please return this part with payment - when paying in person, bring entire bill

MAIL YOUR CHECK OR PRESENT THIS INVOICE WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS

ON YOUR CHECK

CITY TREASURER
ROOM 100A, CITY HALL
ROCHESTER, NEW YORK 14614

176 ANDERSON AV

94-02002	PERMIT NUMBER
02/04/93	INVOICE DATE
03/31/93	DUE DATE
\$ 130	AMOUNT DUE

Paid for permit 5/25/93

MICA CONCEPTS
176 ANDERSON AVENUE
ROCHESTER NY 14607

Permit fee payments not received after thirty (30) days from the due date will be considered delinquent.

These delinquent properties operating with invalid permits will be subject to the issuance of a Municipal Code Violations Summons pursuant to Chapter 54-10 of the Municipal Code.

Municipal Code Summons Schedule

	Initial	Default
1st Offense, or after 30 days	\$ 75.00	\$150.00
2nd Offense, or after 60 days	\$150.00	\$300.00
3rd Offense, or after 90 days	\$375.00	\$750.00

FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL
PUBLIC ED
PERMIT
HIGH-RISE

LOCATION 176 ANDERSON AVE

STERN ROOFING

DATE RECEIVED IN FIRE SAFETY:

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OK TO FILE

INSPECTOR

DATE

6/2/93

~~6/17~~ 93

6-23

6-24

7-8

7-24

7/29

8-16

8-23

8/30

9-3

10/7

X

X

X

X

X

X

X

X

X

X

X

X

X

6546

Shub

Shub

Shub

Shub

Shub

Shub


Shub

Shub

Shub

X Shub

FILE



NOTICE OF VIOLATIONS

DATE 6-2-93

Steven Rodgers Name 176 Anderson Ave Address

Inspection of premises located at 176 Anderson Ave reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 6-9-92

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 75	\$150
2nd OFFENSE	\$150	\$300
3rd & SUBSEQUENT	\$375	\$750

- ① 1163.3D All propane & compressed gas cylinders shall be securely chained
OK 10-7-93
- ② 1191.2A Dumpster overloaded shall be removed from present spot. To near Bldg. Also old pallets, wood & junk shall be removed
8/3/93
- ③ 1171.3B-3 All gas powered equip. shall be removed from basement. (below 1st Bank) 8/30
- ④ 1163.4g Open Junction Box w/ite in sprinkler room. (basement) shall be covered 10/7/93

By Order of
FIRE MARSHAL

INSPECTOR Ron Shick 6546

DATE of COMPLIANCE _____ Inspector _____



COMPANY **Q04**

ADDRESS
ANDERSON

PROPERTY OWNER
GARY

MAILING NAME
JOSEPH STERN & SONS

EMERGENCY CONTACT
GARY STERN

AV
STERN

FROM / TO
176

ADDRESS
176 ANDERSON AV

CITY **ROCHESTER**

ADDRESS
176 ANDERSON AV

CITY **ROCHESTER**

ADDRESS
40 EVANDALE RD

CITY **ROCHESTER**

INSPECTION #

09117

TAX ACCT #

004600-00.0

PHONE

461-2380

STATE **NY** ZIP

14607

PHONE

STATE **NY** ZIP

14607

PHONE

STATE **NY** ZIP

461-9867

14618

NFPA 901 CODES	GENERAL PROPERTY USE 70	SPECIFIC PROPERTY USE 773	STRUCTURE TYPE F	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

NO ENTRY DATES:	BUSINESS NAME VICTOR SCREW PRODUCTS	PHONE	DISPOSITION by FIRE SAFETY:
	BUSINESS OWNER J MANFREDI		
A = ATTIC	ADDRESS 176 ANDERSON AV	ROCHESTER NY14607	REFERRED
C = CELLAR		PHONE 244 6860	
G = GARAGE	BUSINESS EMERGENCY DONALD E MC KAY		CORRECTED
O = OUTSIDE	ADDRESS 298 HUNTS PARK RD	PHONE 924 3884	
# = FLOOR #	SPECIAL INSTRUCTIONS:		NOT REQUIRED
DIRECTION ROOM #, ETC.	SPECIAL HAZARDS OR CONSTRUCTION		
	COMPLAINT		
	<i>ok AT Time OF INSP</i>		

OFFICER PREPARING REPORT: <i>LT Conline</i>	COMPANY 4	DISTRICT 3	GROUP 3	DATE 6/14/93
BUS/PROP REPRESENTATIVE:	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
ADDRESS
ANDERSON AV
PROPERTY OWNER
GARY I STERN
MAILING NAME
JOSEPH STERN & SONS
EMERGENCY CONTACT
GARY I STERN

INSPECTION # **09113**
TAX ACCT # **004600-00.0**
ADDRESS
176 ANDERSON AV
CITY **ROCHESTER** STATE **NY** ZIP **14607**
PHONE **461-2380**
ADDRESS
176 ANDERSON AV
CITY **ROCHESTER** STATE **NY** ZIP **14607**
PHONE
ADDRESS
40 EVANDALE RD
CITY **ROCHESTER** STATE **NY** ZIP **14618**
PHONE **461-9867**

NFPA 901 CODES GENERAL PROPERTY USE **59** SPECIFIC PROPERTY USE **591** STRUCTURE TYPE **P** STRUCTURE STATUS **2**

NO ENTRY DATES:
A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
= FLOOR

BUSINESS NAME **M & T BANK** PHONE
BUSINESS OWNER
ADDRESS **176 ANDERSON AV** **ROCHESTER NY 14607**
PHONE **442 1810**
BUSINESS EMERGENCY **RAYMOND ROGERS**
ADDRESS
PHONE **482 8299**

DISPOSITION by FIRE SAFETY:

REFERRED
ORDERS ISSUED
CORRECTED
NOT REQUIRED

SPECIAL INSTRUCTIONS:
SPECIAL HAZARDS OR CONSTRUCTION

DIRECTION ROOM #, ETC. COMPLAINT

USED FOR STORAGE ONLY

OFFICER PREPARING REPORT: *HT Cent. Dept.* COMPANY **Q4** DISTRICT **BN3** GROUP **3** DATE **6/1/93**
BUS/PROP REPRESENTATIVE: *John J. ...* POSITION / TITLE DATE
FIRE SAFETY INSPECTOR: DATE

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**

ADDRESS

ANDERSON

AV

PROPERTY OWNER

GARY

STERN

MAILING NAME

JOSEPH STERN & SONS

EMERGENCY CONTACT

GARY STERN

FROM / TO

176

ADDRESS

176 ANDERSON AV

CITY **ROCHESTER**

ADDRESS

176 ANDERSON AV

CITY **ROCHESTER**

ADDRESS

40 EVANDALE RD

CITY **ROCHESTER**

INSPECTION #

09112

TAX ACCT #

004600-00.0

PHONE

461-2380

STATE **NY** ZIP

14607

PHONE

STATE **NY** ZIP

14607

PHONE

STATE **NY** ZIP

461-9867

14618

NFPA 901 CODES	GENERAL PROPERTY USE 70	SPECIFIC PROPERTY USE	STRUCTURE TYPE P	STRUCTURE STATUS 2
----------------	--------------------------------	-----------------------	-------------------------	---------------------------

NO ENTRY DATES: A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS NAME INTRASTATE TRUCKING PHONE BUSINESS OWNER NICK PASSERO ADDRESS 176 ANDERSON AV ROCHESTER NY 14607 PHONE 232 5817	DISPOSITION by FIRE SAFETY:		
	BUSINESS EMERGENCY ADDRESS PHONE	REFERRED ORDERS ISSUED CORRECTED NOT REQUIRED		
	SPECIAL INSTRUCTIONS:			
	SPECIAL HAZARDS OR CONSTRUCTION			
DIRECTION ROOM #, ETC.	COMPLAINT			
	<i>No Longer in Business At this Address</i>			

OFFICER PREPARING REPORT: <i>LT Centina</i>	COMPANY Q4	DISTRICT 3	GROUP 3	DATE 6/2/93
BUS/PROP REPRESENTATIVE:	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE



City of Rochester FIRE DEPARTMENT

FIRE SAFETY DIVISION

300 Public Safety Building
Rochester, New York 14614
(716) 428-7037

PERMIT

DATE 03/22/93

For keeping, storing, using, installing, manufacturing, handling, transporting, or otherwise employing flammable, combustible, or explosive materials, or materials, processes, or equipment, which if improperly used may produce conditions hazardous to life or property.

TO WHOM IT MAY CONCERN:

By virtue of the provisions of the Fire Prevention Code of the City of Rochester, NY.,

INTRASTATE TRUCKING
176 ANDERSON AV

94-04004	PERMIT NUMBER
----------	---------------

having made application in due form, and as the conditions, surroundings, and arrangements are, in my opinion, such that the intent of the Fire Prevention Code can be observed, authority is hereby given and this PERMIT is GRANTED for:

PERMIT CODE	PERMIT CATEGORY	FEE
5412B24	PRIVATE PLANT	\$ 65

Please return this part with payment - when paying in person, bring entire bill

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

CITY TREASURER
ROOM 100A, CITY HALL
ROCHESTER, NEW YORK 14614

176 ANDERSON AV

94-04004	PERMIT NUMBER
03/22/93	INVOICE DATE
05/31/93	DUE DATE
\$ 65	AMOUNT DUE

INTRASTATE TRUCKING
111 EAST AVENUE
ROCHESTER NY 14604

FD513

shall be complied with, and this permit will become void only after expiration

THIS PERMIT EXPIRES **04/30/94**

This permit does not take the place of any License required by law and is not transferable. Any change in the use or occupancy of premises shall require a new permit.

Eugene Ziffard
FIRE MARSHAL

THIS PERMIT MUST AT ALL TIMES BE KEPT ON FILE AT THE PREMISES MENTIONED ABOVE

Please return this part with payment - when paying in person, bring entire bill

MAIL YOUR CHECK OR PRESENT THIS INVOICE
WITH FEE PAID IN FULL TO:

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

CITY TREASURER
ROOM 100A, CITY HALL
ROCHESTER, NEW YORK 14614

94-04004	PERMIT NUMBER
03/22/93	INVOICE DATE
05/31/93	DUE DATE
\$ 65	AMOUNT DUE

INTRASTATE TRUCKING
111 EAST AVENUE
ROCHESTER NY 14604

FD513

BUILDING INSPECTION / COMPLAINT FORM



06308

COMPANY **004**
ADDRESS
ANDERSON AV
PROPERTY OWNER
GARY I STERN

FROM / TO
176

INSPECTION #
TAX ACCT #
004600-00.0

ADDRESS
176 ANDERSON AV PHONE **461-2380**
CITY **ROCHESTER** STATE **NY** ZIP **14607**

ADDRESS
176 ANDERSON AV PHONE
CITY **ROCHESTER** STATE **NY** ZIP **14607**

MAILING NAME
JOSEPH STERN & SONS

EMERGENCY CONTACT
GARY I STERN

ADDRESS
40 EVANDALE RD PHONE **461-9867**
CITY **ROCHESTER** STATE **NY** ZIP **14618**

NFPA 901 CODES	GENERAL PROPERTY USE <input type="checkbox"/> 59	SPECIFIC PROPERTY USE <input type="checkbox"/> 591	STRUCTURE TYPE <input type="checkbox"/> P	STRUCTURE STATUS <input type="checkbox"/> 2
----------------	--	--	---	---

NO ENTRY DATES:

BUSINESS NAME ~~CENTRAL TRUST CO~~ *M&T* PHONE
BUSINESS OWNER
ADDRESS **176 ANDERSON AV** **ROCHESTER NY 14607**
PHONE **442 1810**

DISPOSITION by FIRE SAFETY:

BUSINESS EMERGENCY **RAYMOND ROGERS**
ADDRESS
PHONE **482 8299**

SPECIAL INSTRUCTIONS:

SPECIAL HAZARDS OR CONSTRUCTION

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION ROOM #, ETC.

COMPLAINT

None

OFFICER PREPARING REPORT: <i>AJ Burger</i>	COMPANY 443	DISTRICT 4	GROUP 4	DATE 7/22/92
BUS/PROP REPRESENTATIVE:	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE

BUILDING INSPECTION / COMPLAINT FORM



06309

COMPANY **004**
ADDRESS
ANDERSON AV
PROPERTY OWNER

FROM / TO
176

INSPECTION #
TAX ACCT #
004600-00.0

GARY I STERN
MAILING NAME
JOSEPH STERN & SONS

ADDRESS
176 ANDERSON AV
CITY **ROCHESTER** STATE **NY** ZIP **14607**

PHONE
461-2380

EMERGENCY CONTACT
GARY I STERN

ADDRESS
176 ANDERSON AV
CITY **ROCHESTER** STATE **NY** ZIP **14607**



PHONE

ADDRESS
40 EVANDALE RD
CITY **ROCHESTER** STATE **NY** ZIP **14618**

PHONE
461-9867

NFPA 901 CODES	GENERAL PROPERTY USE <input type="text" value="70"/>	SPECIFIC PROPERTY USE <input type="text" value="553"/>	STRUCTURE TYPE <input type="text" value="F"/>	STRUCTURE STATUS <input type="text" value="2"/>
----------------	--	--	---	---

NO ENTRY DATES: A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS NAME PRAUS EDGAR G PRODUCTIONS PHONE BUSINESS OWNER EDGAR PRAUS ADDRESS 176 ANDERSON AV ROCHESTER NY 14607 PHONE 442 4820	DISPOSITION by FIRE SAFETY: REFERRED ORDERS ISSUED CORRECTED NOT REQUIRED
	BUSINESS EMERGENCY EDGAR PRAUS ADDRESS PHONE 442 9734	
	SPECIAL INSTRUCTIONS:	
	SPECIAL HAZARDS OR CONSTRUCTION	
DIRECTION ROOM #, ETC.	COMPLAINT 	

OFFICER PREPARING REPORT: 	COMPANY 004 DISTRICT 3 GROUP 4	DATE 7/22/92
BUS/PROP REPRESENTATIVE: 	POSITION / TITLE	DATE
FIRE SAFETY INSPECTOR:		DATE

BUILDING INSPECTION / COMPLAINT FORM



06310

COMPANY 004

INSPECTION #

ADDRESS ANDERSON AV

FROM / TO 176

TAX ACCT # 004600-00.0

PROPERTY OWNER GARY STERN

ADDRESS 176 ANDERSON AV
CITY ROCHESTER STATE NY ZIP 14607
PHONE 461-2380

MAILING NAME JOSEPH STERN & SONS

ADDRESS 176 ANDERSON AV
CITY ROCHESTER STATE NY ZIP 14607
PHONE

EMERGENCY CONTACT GARY STERN

ADDRESS 40 EVANDALE RD
CITY ROCHESTER STATE NY ZIP 14618
PHONE 461-9867

NFPA 901 CODES	GENERAL PROPERTY USE 51	SPECIFIC PROPERTY USE 555	STRUCTURE TYPE F	STRUCTURE STATUS 2
----------------	-------------------------	---------------------------	------------------	--------------------

NO ENTRY DATES:	BUSINESS NAME STERN JOSEPH & SONS	PHONE	DISPOSITION by FIRE SAFETY:			
	BUSINESS OWNER ADDRESS	PHONE	PERMITS			
A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS EMERGENCY ADDRESS	PHONE	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
	SPECIAL INSTRUCTIONS:					
	SPECIAL HAZARDS OR CONSTRUCTION					
DIRECTION ROOM #, ETC.	COMPLAINT					
	<i>none</i>					

OFFICER PREPARING REPORT: <i>[Signature]</i>	COMPANY 043	DISTRICT 4	GROUP 4	DATE 7/22/99
BUS/PROP REPRESENTATIVE: <i>[Signature]</i>	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE

BUILDING INSPECTION / COMPLAINT FORM



06311

COMPANY 004

INSPECTION #

ADDRESS

FROM / TO

TAX ACCT #

ANDERSON

AV

176

004600-00.0

PROPERTY OWNER

ADDRESS

PHONE

GARY

STERN

176 ANDERSON AV

461-2380

CITY ROCHESTER

STATE NY

ZIP

14607

MAILING NAME

ADDRESS

PHONE

JOSEPH STERN & SONS

176 ANDERSON AV

CITY ROCHESTER

STATE NY

ZIP

14607

EMERGENCY CONTACT

ADDRESS

PHONE

GARY STERN

40 EVANDALE RD

461-9867

CITY ROCHESTER

STATE NY

ZIP

14618

NFPA 901 CODES	GENERAL PROPERTY USE <input type="text" value="70"/>	SPECIFIC PROPERTY USE <input type="text" value="773"/>	STRUCTURE TYPE <input type="text" value="P"/>	STRUCTURE STATUS <input type="text" value="2"/>
----------------	--	--	---	---

NO ENTRY DATES:

BUSINESS NAME **VICTOR SCREW PRODUCTS** PHONE _____

BUSINESS OWNER **J MANFREDI**

ADDRESS **176 ANDERSON AV** **ROCHESTER NY 14607** PERMITS _____

PHONE **244 6860**

BUSINESS EMERGENCY **DONALD E MC KAY**

ADDRESS **298 HUNTS PARK RD** PHONE **924 3884**

DISPOSITION by FIRE SAFETY:

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

SPECIAL INSTRUCTIONS:

SPECIAL HAZARDS OR CONSTRUCTION

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

DIRECTION ROOM #, ETC.

COMPLAINT

none

OFFICER PREPARING REPORT: <i>[Signature]</i>	COMPANY <input type="text" value="04"/>	DISTRICT <input type="text" value="3"/>	GROUP <input type="text" value="4"/>	DATE <input type="text" value="7/22/92"/>
BUS/PROP REPRESENTATIVE: <i>[Signature]</i>	POSITION / TITLE			DATE
FIRE SAFETY INSPECTOR:				DATE

FIRE SAFETY INSPECTION RECORD

LICENSE

V-3262

GENERAL
 PUBLIC ED
 PERMIT
 HIGH-RISE

LOCATION: 176 ANDERSON AVE

STERN, JOSEPH & SONS

DATE RECEIVED IN FIRE SAFETY:

APPOINTMENT

PERSON CONTACTED

NO ENTRY

ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

OK TO FILE

INSPECTOR

DATE

2/27/92

GARY

X

2 val

6546

13
3/18/92

X

X

Shel

3/29

John

X

X

1 correct

Shel

4-2

X

X

Shel

4-76

X

X

Shel

4/25

X

3 correct

Shel

5/4

X Shel

FILE



City of Rochester

FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL

Room 300
Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037

NOTICE OF VIOLATIONS

Gary Stern
Jos. Stern
176 Anderson Avenue
Rochester, New York 14607

February 28, 1992

PLEASE TAKE NOTICE THAT an inspection at 176 Anderson Avenue, Rochester, New York reveals Violation(s) of the Fire Prevention Code of the City of Rochester and/or the Codes, Rules and Regulations of the State of New York.

Orders are hereby issued for the violation(s) to be corrected on or before the reinspection scheduled for March 5, 1992. Failure to comply with these orders will result in the issuance of a Municipal Code Violation Summons for each uncorrected violation with the following penalties:

	INITIAL	FAILURE TO RESPOND
1ST OFFENSE	\$ 50.00	\$100.00
2ND OFFENSE	100.00	200.00
3RD OFFENSE	250.00	500.00

During this period, the property owner continues to be responsible and liable for any damages arising from the violation(s).

Relevant section(s) of the New York State Uniform Fire Prevention and Building Code (Title 9NYCRR) to wit:

1162.5b Fire, exit, stair and smoke stop doors shall be kept closed at all times, except for those equipped with approved automatic releasing hold-open devices installed and maintained in accordance with generally accepted standards.

FIRE DOOR BETWEEN SHOP AND OFFICE SHALL HAVE CLOSER REPAIRED OR REPLACED.

1171.3b-3 The storage of Class I, Class II or Class III liquids in closed containers shall comply with the following paragraphs, except that the Code Enforcement Official may impose a quantity limitation or require greater protection where unusual hazard to life or property is involved, or he may authorize an increase of these amounts where the type of construction, fire protection provided, or other factors, substantially reduce the hazard.

ALL FLAMMABLE SHALL BE KEPT IN METAL CABINETS WHEN NOT IN USE.

3/25

OK
5/4/92



City of Rochester
FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL

Room 300
Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037

NOTICE OF VIOLATIONS

PAGE 2

1175.1d Compressed gas cylinders in storage or in service shall be secured to prevent falling or being upset and shall be protected against tampering by unauthorized persons.
ALL COMPRESSED GAS CYLINDERS SHALL BE CHAINED.

4/16/92

BY ORDER OF THE FIRE MARSHAL

INSPECTOR

Shilo
Ronald Shilo 6546

DATE OF COMPLIANCE

5/4/92

INSPECTOR _____



City of Rochester

FIRE SAFETY DIVISION
FOR INTERNAL USE ONLY

V-3-262

DATE 2/27/92

PAGE 1 OF 1

BUSINESS NAME Jos Stern

OWNER: _____

MAILING ADDRESS 176 Anderson ZIP 07

ADDRESS: _____

ADDRESS OF VIOLATIONS: _____

CITY: _____ ZIP _____

ATTENTION: Gary Stern

REINSPECTION DATE: 3/5/92

CODE VIOLATION #	DESCRIPTION and/or LOCATION OF VIOLATION
1175.10	All compressed gas cylinders shall be chained
1171.3B-3	All flamm. shall be kept in metal cabinets when not used.
1162.5B	fire door between shop & office shall have a closer repaired or replaced.

INSPECTOR: [Signature] IBM # 6546



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

18406	PERMIT NUMBER
03/06/92	DATE
	FEE TOTAL
	DATE RELEASED
04/30/93	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
-------------	-----------------	-----

5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 25
5412B10B	COMBUSTIBLE LQD STORAGE - CLS I	\$ 25
5412B12A	COMPRESSED GAS - OVER 2000 CU FT	\$ 50
5412B17	COMBUSTIBLE MATERIAL STORAGE - OVER TRSURER 01	\$ 40

1 FIRE PVN 140.00
SUBTOTAL 140.00
TOTAL 140.00
CHECK 140.00
ITEM 1
1757 01 0101 MAR25' 92 02:56P

TOTAL \$ 140

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614

NAME
MAILING ADDRESS

STERN, JOSEPH & SONS
176 ANDERSON AV
ROCHESTER

NY 14607

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL
PUBLIC ED
PERMIT
HIGH-RISE

LOCATION: 176 ANDERSON

MICA CONCEPTS

DATE RECEIVED IN FIRE SAFETY:

APPOINTMENT	PERSON CONTACTED	NO ENTRY	ORDERS ISSUED	REFERRALS ISSUED	NO WORK DONE	SOME WORK DONE	OTHER
-------------	------------------	----------	---------------	------------------	--------------	----------------	-------

OK TO FILE
INSPECTOR

DATE

12/10/91

12/16/91

~~12/22~~

1/2/92

X

X

Viol

6546

Correction

X [Signature]

File



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

18407	PERMIT NUMBER
03/06/92	DATE
	FEE TOTAL
	DATE RELEASED
04/30/93	EXPIRATION DATE

PERMIT CODE

PERMIT CATEGORY

FEE

5412B24

PRIVATE PLANT

TREASURER, CLERK
MAR27 92 03:24PM

TRSURER 01

1 FIRE PVN 35.00
SUBTOTAL 35.00
TOTAL 35.00
CHECK 35.00

ITEM 1

1983 01 0101 MAR27 92 03:24P

TOTAL \$ 35

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME

MAILING ADDRESS

**INTRASTATE TRUCKING
111 EAST AVENUE
ROCHESTER**

NY 14604

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



City of Rochester

FIRE SAFETY DIVISION
FOR INTERNAL USE ONLY

U-3-244

DATE 12-16-91

PAGE 1 OF 1

BUSINESS NAME MICA Concepts

OWNER: _____

MAILING ADDRESS 176 Anderson ZIP 07

ADDRESS: _____

ADDRESS OF VIOLATIONS: _____

CITY: _____ ZIP _____

ATTENTION: Charm Jarre

REINSPECTION DATE: 12-16-91

CODE VIOLATION #	DESCRIPTION and/or LOCATION OF VIOLATION
1163,732-1	fire extinguisher shall be checked
	+ updated (expired) Nov 91

INSPECTOR: Shelo IBM # _____



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 176 ANDERSON AV

17038	PERMIT NUMBER
01/10/92	DATE
	FEE TOTAL
FEB 10 1992	DATE RELEASED
02/28/93	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B08	DUST PRODUCING OPERATION	\$ 40
5412B10A	FLAMMABLE LIQ STORAGE - CLS I	\$ 25

TREASURER CLERK
FEB10'92 01:28PM

TRSURER 01

1 FIRE PVN 65.00
SUBTOTAL 65.00
TOTAL 65.00
CHECK 65.00
ITEM 1

9890 01 0101 FEB10'92 01:28P
TOTAL \$ 65

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME
MAILING ADDRESS

MICA CONCEPTS
176 ANDERSON AVENUE
ROCHESTER NY 14607

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



City of Rochester

FIRE DEPARTMENT
OFFICE OF THE FIRE MARSHAL

NOTICE OF VIOLATIONS

Room 300
Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037

Mica Concepts
176 Anderson Avenue
Rochester, New York 14607

December 11, 1991

PLEASE TAKE NOTICE THAT an inspection at 176 Anderson Avenue, Rochester, New York reveals Violation(s) of the Fire Pevention Code of the City of Rochester and/or the Codes, Rules and Regulations of the State of New York.

Orders are hereby issued for the violation(s) to be corrected on or before the reinspection scheduled for December 16, 1991. Failure to comply with these orders will result in the issuance of a Municipal Code Violation Summons for each uncorrected violation with the following penalties:

	INITIAL	FAILURE TO RESPOND
1ST OFFENSE	\$ 50.00	\$100.00
2ND OFFENSE	100.00	200.00
3RD OFFENSE	250.00	500.00

During this period, the property owner continues to be responsible and liable for any damages arising from the violation(s).


Relevant section(s) of the New York State Uniform Fire Prevention and Building Code (Title 9NYCRR) to wit:

1163.13f-1 The provision for installation and maintenance of portable fire extinguishers shall be in accordance with this subchapter and reference standard RS 73-1.

FIRE EXTINGUISHER SHALL BE CHECKED AND UPDATED (EXPIRED NOVEMBER 1991.

BY ORDER OF THE FIRE MARSHAL

INSPECTOR


Ronald Shilo 6546

DATE OF COMPLIANCE 1/2/92

INSPECTOR



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 176 ANDERSON AV

16805	PERMIT NUMBER
11/21/91	DATE
	FEE TOTAL
	DATE RELEASED
12/31/92	EXPIRATION DATE

PERMIT CODE

PERMIT CATEGORY

FEE

5412B12H

HIGHLY TOXIC MATERIAL

\$ 30

TREASURER CLERK
DEC23' 91 12:34PM

TRSURER 01

1 FIRE PVN 30.00
SUBTOTAL 30.00
TOTAL 30.00
CHECK 30.00
ITEM 1

8012 01 0101 DEC23' 91 12:34P

TOTAL \$ 30

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME

MAILING
ADDRESS

AFFORDABLE EXTERMINATING
P.O. BOX 60982
ROCHESTER NY 14606

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

BUILDING INSPECTION / COMPLAINT FORM



07664

COMPANY **Q04**

INSPECTION #

ADDRESS

FROM / TO

TAX ACCT #

ANDERSON

AV

176

004600-00.0

PROPERTY OWNER

ADDRESS

PHONE

GARY

STERN

176 ANDERSON AV

461-2380

CITY **ROCHESTER**

STATE

NY ZIP

14607

MAILING NAME

ADDRESS

PHONE

JOSEPH STERN & SONS

176 ANDERSON AV

CITY **ROCHESTER**

STATE

NY ZIP

14607

EMERGENCY CONTACT

ADDRESS

PHONE

GARY STERN

40 EVANDALE DR

461-9168

CITY **ROCHESTER**

STATE

NY ZIP

14618

NFPA 901 CODES	GENERAL PROPERTY USE 70	SPECIFIC PROPERTY USE 758	STRUCTURE TYPE 2	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

NO ENTRY DATES:

BUSINESS NAME **GARY J ENTERPRISES** PHONE
 BUSINESS OWNER **GARY J ROCKOFF**
 ADDRESS **176 ANDERSON AV** **ROCHESTER NY14607**
 PHONE **442 2570**
 BUSINESS EMERGENCY **GARY J ROCKOFF**
 ADDRESS **724 SURREY HILL WY** **ROCHESTER NY14623**
 PHONE **427 7687**

DISPOSITION by FIRE SAFETY:

- A = ATTIC
- C = CELLAR
- G = GARAGE
- O = OUTSIDE
- # = FLOOR #

SPECIAL INSTRUCTIONS:

SPECIAL HAZARDS OR CONSTRUCTION

DIRECTION ROOM #, ETC.

COMPLAINT

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
----------	---------------	-----------	--------------

warehouse

*missing panel box cover
several open junction boxes
on ceiling*

*Fire extinguishers need
inspecting*

*Note corrected as of 9/26/91
B. Boremb*

OFFICER PREPARING REPORT: <i>TL James McGowan</i>	COMPANY <i>Q4</i>	DISTRICT	GROUP <i>1</i>	DATE <i>8-23-91</i>
BUS/PROP REPRESENTATIVE: <i>Gary J. Ruff</i>	POSITION / TITLE <i>owner</i>			DATE <i>8/23-91</i>
FIRE SAFETY INSPECTOR:				DATE



NOTICE OF VIOLATIONS

DATE 10/4/91

GARY J Enterprises
Name

176 Anderson Ave
Address

Inspection of premises located at _____ reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: 10/11/91

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

	<u>INITIAL</u>	<u>FAILURE TO RESPOND</u>
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

(1163.115) 9/11/91 all open JUNCTIONS BOXES & PANEL BOX shall be covered o/c 10/29/91

~~1163.13e-1~~ fire exting. shall be checked & re-tagged

o/c 11/14/91

By Order of
FIRE MARSHAL

INSPECTOR Ronald [Signature]

DATE of COMPLIANCE 11/14/91

Inspector [Signature]

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
 ADDRESS **ANDERSON AV**
 PROPERTY OWNER **GARY STERN**
 MAILING NAME **JOSEPH STERN & SONS**
 EMERGENCY CONTACT **GARY STERN**

FROM / TO **176**
 ADDRESS **176 ANDERSON AV**
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 ADDRESS **176 ANDERSON AV**
 CITY **ROCHESTER** STATE **NY** ZIP **14607**
 ADDRESS **40 EVANDALE RD**
 CITY **ROCHESTER** STATE **NY** ZIP **14618**

INSPECTION # **07666**
 TAX ACCT # **004600-00.0**

NFPA 901 CODES: GENERAL PROPERTY USE **70** SPECIFIC PROPERTY USE **773** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

NO ENTRY DATES:	BUSINESS NAME VICTOR SCREW PRODUCTS BUSINESS OWNER J MANFREDI ADDRESS 176 ANDERSON AV PHONE 244 6860	DISPOSITION by FIRE SAFETY:	REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
A = ATTIC	BUSINESS EMERGENCY DONALD E MC KAY ADDRESS 298 HUNTS PARK RD PHONE 924 3884					
C = CELLAR	SPECIAL INSTRUCTIONS:					
G = GARAGE	SPECIAL HAZARDS OR CONSTRUCTION					
O = OUTSIDE	DIRECTION ROOM #, ETC.	COMPLAINT				
# = FLOOR #	<i>No Violations at time of Insp.</i>					

OFFICER PREPARING REPORT: <i>F. A. Bocca</i>	COMPANY QMY	DISTRICT 3	GROUP 1	DATE 9/26/91
BUS/PROP REPRESENTATIVE: <i>J Manfredi</i>	POSITION / TITLE Owner			DATE 9/26/91
FIRE SAFETY INSPECTOR:	DATE			

RFD 501 REV. 12/90



07663

COMPANY **Q04**
ADDRESS
ANDERSON AV
PROPERTY OWNER
GARY I STERN

FROM / TO
176

INSPECTION #
TAX ACCT #
004600-00.0

ADDRESS **176 ANDERSON AV** PHONE **461-2380**
CITY **ROCHESTER** STATE NY ZIP **14607**
ADDRESS **176 ANDERSON AV** PHONE
CITY **ROCHESTER** STATE NY ZIP **14607**
ADDRESS **40 EVANDALE RD** PHONE **461-9867**
CITY **ROCHESTER** STATE NY ZIP **14618**

MAILING NAME
JOSEPH STERN & SONS

EMERGENCY CONTACT
GARY I STERN

NFPA 901 CODES	GENERAL PROPERTY USE 59	SPECIFIC PROPERTY USE 591	STRUCTURE TYPE 2	STRUCTURE STATUS 2
----------------	--------------------------------	----------------------------------	-------------------------	---------------------------

NO ENTRY DATES:	BUSINESS NAME DIMENSION TECHNIQUES BUSINESS OWNER ARNOLD LAGERGREN ADDRESS 176 ANDERSON AV PHONE ROCHESTER NY 14607 PHONE 442 7450	DISPOSITION by FIRE SAFETY:			
		REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
A = ATTIC C = CELLAR G = GARAGE O = OUTSIDE # = FLOOR #	BUSINESS EMERGENCY ADDRESS PHONE				
DIRECTION ROOM #, ETC.	SPECIAL INSTRUCTIONS: COMPLAINT				
	SPECIAL HAZARDS OR CONSTRUCTION				
<i>Store room</i>	<i>open junction box</i>				
<i>Hallway</i>	<i>debris next to heating unit</i>				
	<i>- Business moved as of Sept 8, 1991 office now vacant - no reentry. 9-26-91 No Entry B. B...</i>				

OFFICER PREPARING REPORT: <i>TLT James Mc Gowan</i>	COMPANY Q-4	DISTRICT	GROUP 1	DATE 8-23-91
BUS/PROP REPRESENTATIVE: <i>M. Lagergren</i>	POSITION / TITLE <i>Officer Mgr.</i>			DATE 8/23/91
FIRE SAFETY INSPECTOR:				DATE

LICENSE

GENERAL
PUBLIC ED
PERMIT
HIGH-RISE

LOCATION: 176 ANDERSON AV

DATE RECEIVED IN FIRE SAFETY:

06/20/91

DATE

APPOINTMENT	PERSON CONTACTED	NO ENTRY	ORDERS ISSUED	REFERRALS ISSUED	NO WORK DONE	SOME WORK DONE	OTHER	OK TO FILE INSPECTOR
-------------	------------------	----------	---------------	------------------	--------------	----------------	-------	-------------------------

6-29-91
7-1

X

vet BAC orders will pick up

K. [Signature]

FILE



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 176 ANDERSON AV

15750	PERMIT NUMBER
07/01/91	DATE
<i>165</i>	FEE TOTAL
JUL 30 1991	DATE RELEASED
07/31/92	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 25
5412B17	COMBUSTIBLE MATERIAL STORAGE - OVER	\$ 40

TRANSFER TO CLERK
JUL 01 04:16PM

RECEIVED

PERMIT FEE 65.00
SUBTOTAL 65.00
TOTAL 65.00
CHECK 65.00
TOTAL \$ 65

JUL 01 04:16PM

FOR DEPOSIT ONLY

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME
MAILING ADDRESS

**RAY ROGERS
CENTRAL TRUST CO ANNEX
44 EXCHANGE ST
ROCHESTER**

NY 14614

JUL 01 04:16PM
2310 CHECK 65.00

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

ROCHESTER, NEW YORK FIRE DEPARTMENT FIELD INCIDENT REPORT

ALARM

INCIDENT # 9108350 BOX # 33414 ADDRESS NUMBER 176 STREET Anderson TYPE DIR. AN

DATE MO 06 DA 19 YR 91 DAY OF WEEK 4 WEATHER COND 1 TEMP 5 ALARM TYPE 1 GOVT BLDG

TIMES

FIRST ALARM
 TIME OF ALARM 18:58 CODE 9 ENGINE CODE 9 TRUCK UND. CONTROL CODE 2 TIME 19:15

EXTRA UNITS SENT
 TIME OF ALARM CODE 9 ENGINE CODE 9 TRUCK TIME OF ALARM CODE 9 ENGINE CODE 9 TRUCK

SECOND ALARM
 TIME OF ALARM CODE 9 ENGINE CODE 9 TRUCK AMBULANCE CODE 9 B/C CODE 9 19:05

RESPONSE

FIRST ALARM
 UNIT W/R BC314 UNIT W/R Q04R UNIT W/R M04R UNIT W/R UNIT W/R UNIT W/R UNIT W/R UNIT W/R

EXTRA UNITS SENT
 UNIT W/R UNIT W/R

MULTIPLE ALARM
 UNIT W/R UNIT W/R

UNIT W/R UNIT W/R UNIT W/R UNIT W/R UNIT W/R UNIT W/R UNIT W/R UNIT W/R

DESCRIPTION OF FIRE

INCTYPE 91 TYPE CONST STORIES SPECIFIC PROPERTY USE MOBILE PPOP TYPE AREA OF ORG. EQUIP INV FORM OF HEAT IGN FORM MAT'L TYPE MAT'L IGN FACTOR CODE 5

YEAR MAKE MODEL LICENSE NUMBER SERIAL NUMBER VOLTAGE

FIRE EXTENDED TO EXT OF FLAME DMG

OWNER/OCCUPANT

OWNER INITIALS NAME OCCUPANT INITIALS NAME

OWNER ADDRESS NUMBER STREET TYPE DIR CITY STATE ZIP

COMBAT

NUMBER USED BOOST 1 1/2" 3/4" 2 1/2" 3" M S OXY PORT ABLE FOAM AMOUNT OF WATER USED SPKLR STAND PIPE HYD PRESS HYD COND SMOKE DET ENTRY

AFTERMATH

DOLLAR LOSS OF PROPERTY NUMBER OF RESCUES INJURED CIV. F.F. DEAD CIV. F.F. REFERRED TO: FIRE SAFETY FIRE INVESTIGATION

REMARKS Pool of hardened roofing tar on ground at rear of Joseph Stern + Sons Roofing

RANK RC INIT. R NAME YANIZ GRP CPY 2RC33 BATT R Ryan

FIRE SAFETY INSPECTION RECORD

LICENSE

GENERAL
 PUBLIC ED
 PERMIT
 HIGH-RISE

LOCATION: 00176 ANDERSON AV STERN JOSEPH & SONS

DATE RECEIVED IN FIRE SAFETY
 OCT 18 1990

DATE

APPOINTMENT	PERSON CONTACTED	NO ENTRY	ORDERS ISSUED	REFERRALS ISSUED	NO WORK DONE	SOME WORK DONE	OTHER	OK TO FILE	INSPECTOR
-------------	------------------	----------	---------------	------------------	--------------	----------------	-------	------------	-----------

4-4-91
 4-11-
~~4-28~~

X

2 util

X

OK TO

Shub
Shub

FILE



**CITY OF ROCHESTER
FIRE DEPARTMENT**

**FIRE SAFETY
INVOICE**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

LOCATION: 176 ANDERSON AV

15150	PERMIT NUMBER
03/25/91	DATE
140.00	FEE TOTAL
4/4/91	DATE RELEASED
04/30/92	EXPIRATION DATE

PERMIT CODE	PERMIT CATEGORY	FEE
5412B10A	FLAMMABLE LQD STORAGE - CLS I	\$ 25
5412B10B	COMBUSTIBLE LQD STORAGE - CLS II, III	\$ 25
5412B12A	COMPRESSED GAS - OVER 2000 CU FT	\$ 50
5412B17	COMBUSTIBLE MATERIAL STORAGE - OVER	\$ 40

TOTAL \$ 140

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME
MAILING ADDRESS

STERN, JOSEPH & SONS
176 ANDERSON AV
ROCHESTER

NY 14607

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED

BUILDING INSPECTION / COMPLAINT FORM



COMPANY **Q04**
 ADDRESS **ANDERSON AV**
 PROPERTY OWNER **GARY STERN**
 MAILING NAME **JOSEPH STERN & SONS**
 EMERGENCY CONTACT **GARY STERN**

FROM / TO **176**
 ADDRESS **176 ANDERSON AV**
 CITY **ROCHESTER**
 ADDRESS **176 ANDERSON AV**
 CITY **ROCHESTER**
 ADDRESS **40 EVANDALE RD**
 CITY **ROCHESTER**

INSPECTION # **67128**
 TAX ACCT # **004600-00.0**
 PHONE **461-2380**
 NY ZIP **14607**
 PHONE **461-2380**
 NY ZIP **14607**
 PHONE **461-9867**
 NY ZIP **14618**

NFPA 901 CODES GENERAL PROPERTY USE **51** SPECIFIC PROPERTY USE **555** STRUCTURE TYPE **2** STRUCTURE STATUS **2**

A = ATTIC
 C = CELLAR
 G = GARAGE
 O = OUTSIDE
 # = FLOOR #

BUSINESS NAME **STERN JOSEPH & SONS** *Roofing*
 BUSINESS OWNER **GARY STERN**
 ADDRESS _____ PHONE _____
 BUSINESS EMERGENCY ADDRESS _____ PHONE _____

DISPOSITION by FIRE SAFETY:

REFERRED	ORDERS ISSUED	CORRECTED	NOT REQUIRED
	X		
		X	

SPECIAL INSTRUCTIONS:

SPECIAL HARZARDS OR CONSTRUCTION

DIRECTION ROOM #, ETC.

numerous amts of "flammable" liquids stored in warehouse. (adhesives)

Propane tanks not claimed.

Recommend F.P. Inspection for special storage area for flammable liquids (adhesives) and permit.

#176 Main ENTRANCE - Double ^{TARY} DOORS - open junction boxes - and conduit pipe with loose wires out

OFFICER PREPARING REPORT: **Capt C Salina** COMPANY **Q4** DISTRICT **Q4** GROUP **2** DATE **5/23/90**
 BUS/PROP REPRESENTATIVE: _____ POSITION / TITLE _____ DATE _____
 FIRE SAFETY INSPECTOR: *[Signature]* DATE **4-4-91**

85378



**CITY OF ROCHESTER
FIRE DEPARTMENT**

FIRE SAFETY DIVISION

Public Safety Building
Civic Center Plaza
Rochester, New York 14614
(716) 428-7037 & 428-7038

**FIRE SAFETY
INVOICE**

LOCATION: 176 ANDERSON AV

15151	PERMIT NUMBER
03/25/91	DATE
35	FEE TOTAL
4/3/91	DATE RELEASED
04/30/92	EXPIRATION DATE

PERMIT CODE

PERMIT CATEGORY

FEE

5412B24

PRIVATE PLANT

\$ 35

TOTAL \$ 35

To Receive Your Validated Permit

PLEASE WRITE PERMIT NUMBERS
ON YOUR CHECK

MAIL YOUR CHECK WITH THIS INVOICE
WITH FEE PAID IN FULL TO:

**CITY TREASURER
ROOM 100 A, CITY HALL
ROCHESTER, NEW YORK 14614**

NAME
MAILING ADDRESS

**INTRASTATE TRUCKING
111 EAST AVENUE
ROCHESTER**

NY 14604

RETURN TO FIRE DEPARTMENT AFTER PAYMENT IS RECEIVED



City of Rochester

FIRE SAFETY DIVISION
FOR INTERNAL USE ONLY

DATE 4-4-91

PAGE ___ OF ___

BUSINESS NAME Stearns Roofing

OWNER: _____

MAILING ADDRESS 76 Anderson ZIP _____

ADDRESS: _____

ADDRESS OF VIOLATIONS: _____

CITY: _____ ZIP _____

ATTENTION: Gary Stearns

REINSPECTION DATE: 4-11-91

CODE VIOLATION #	DESCRIPTION and/or LOCATION OF VIOLATION
1175.1D	All compressed gas cylinders shall be checked
1171.3B-3	All flammables shall be stored in metal ^{CABINETS} containers when not in use

611
File

INSPECTOR: R Shulo

IBM # 6546

LICENSE

GENERAL

TANK REMOVAL

PUBLIC ED.

PERMIT 1588

LOCATION: 176 Anderson Ave.

Joseph Stern Roofing

DATE RECEIVED IN FIRE SAFETY:

APPOINTMENT

PERSON CONTACTED

NO ENTRY ORDERS ISSUED

REFERRALS ISSUED

NO WORK DONE

SOME WORK DONE

OTHER

3 cards

OK TO FILE

INSPECTOR

DATE

4-24-85

X

6590

5-1

X

LPG tanks have be properly stored & some tires moved

Spencer

5-8

Balance of tire storage has been packed neatly - Violation corrected

Spencer

Fire Dept.
 Fire Safety Division
 Public Safety Bldg.
 Rochester, N.Y. 14614



OFFICE OF THE
 FIRE MARSHAL
 TELEPHONE: 428-7037

NOTICE OF VIOLATIONS

DATE April 24, 1985

Joseph Napierczak 176 Anderson Ave
 Name Address

Inspection of premises located at same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: May 1, 1985

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

Greg Stern

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

JMY/CR

- (OK)* 1) 1191.2a Tools stored in the rear of bldg shall be stacked in an orderly manner.
- (OK)* 2) 1163.3a F P G cylinders located inside the Anderson Supply warehouse shall be removed and stored in the area set aside for such storage.
- (OK)* 3) 1175.1d Certificate tanks located in the shop shall be secured at all times.

By Order of
 FIRE MARSHAL

501455

INSPECTOR

Joseph Napierczak 6590

DATE of COMPLIANCE

5/8/85

Inspector

Napierczak

404594

FD570

FIRE SAFETY INSPECTION RECORD

LICENSE
 TANK REMOVAL

GENERAL PUBLIC ED. PERMIT

LOCATION: 176 Anderson Ave.

Stern & Son

DATE RECEIVED IN FIRE SAFETY

JUL 27 1984

DATE

APPOINTMENT

PERSON CONTACTED

NO ENTRY ORDERS ISSUED
REFERRALS ISSUED
NO WORK DONE
SOME WORK DONE

OTHER

OK TO FILE
INSPECTOR

461-2380

1-3-1-2 2 corr

9-12-84

JOYCE

X

6590

9-25

JOYCE

X

10-2

"

X

10-9

X

JS
JS
JS

BUILDING INSPECTION / COMPLAINT FORM



INCIDENT # _____ INSPECTION # 8,404594

ADDRESS 176 ANDERSON AVE.

PROPERTY OWNER GARY STERN
JOSEPH STERN & SONS ADDRESS 40 EVANDALE RD. PHONE 461-9867

EMERGENCY CONTACT JOE STERN ADDRESS 155 GRAYSTONE LA. PHONE 442-7428

COMPLAINANT _____ ADDRESS _____ PHONE _____

NFPA 901 CODES _____ GENERAL PROPERTY USE 1,8,0 SPECIFIC PROPERTY USE 18,51 STRUCTURE TYPE 2 STRUCTURE STATUS 4

A = ATTIC
C = CELLAR
G = GARAGE
O = OUTSIDE
= FLOOR

BUSINESS: NAME JOSEPH STERN & SONS PHONE 461-2380
OWNER GARY STERN
ADDRESS 176 ANDERSON AVE. PHONE _____

DISPOSITION by FIRE SAFETY:
 NOT REQUIRED
 CORRECTED
 ORDERS ISSUED
 REFERRED

DIRECTION, ROOM #, ETC.	NATURE of VIOLATION or COMPLAINT	REFERRED
<u>#1 REAR BLDG.</u>	<u>WIRES HANGING FROM CEILING TO GROUND - BOXES LOOSE AT WIRE ENDS.</u>	<input checked="" type="checkbox"/>
<u>C REAR</u>	<u>3 PITS APPROX. 10'-15' DEEP DEEP (NEED RAILINGS) OR COVERINGS</u>	<input checked="" type="checkbox"/>
<u>C VICTOR SCREW PRODUCTS</u>	<u>PANELL BOX w/ WIRES HANGING OUT</u>	<input checked="" type="checkbox"/>
	<u>BUILDING STILL UNDER RENOVATION CONSTRUCTION</u>	
	<u>PERMIT PENDING AWAITING REMODELING ~ FIRE SAFETY J. SAPIENZA INFORMED OF SITUATION</u>	

OFFICER PREPARING REPORT: LT. R. BRESCIA COMPANY QM-4 GROUP 1 DATE 07-25-84

BUS/PROP REPRESENTATIVE: JOE STERN POSITION/TITLE OWNER DATE 07-25-84

FIRE SAFETY INSPECTOR: J. Sapienza DATE 9-12-84



NOTICE OF VIOLATIONS

mail

DATE Sept 12, 1984

Joseph Stern & Sons
Name

176 Anderson Ave
Address

Inspection of premises located at same reveals violations of the Fire Prevention Code. Orders are hereby issued for correction of hazards listed herewith on or before: Sept 19, 1984

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:

Gary Stern
461-2380

	INITIAL	FAILURE TO RESPOND
1st OFFENSE	\$ 50	\$100
2nd OFFENSE	\$100	\$200
3rd & SUBSEQUENT	\$250	\$500

9 NYCRR

OK
1. 1242.7c Three (3) open pits located in the rear of the bldg shall be covered (inside)

OK
2. 1163.11b Electrical conduct hanging from ceiling to floor shall be secured.
(block bldg at rear of property)

OK to file

By Order of
FIRE MARSHAL


INSPECTOR Joseph Sapienza
659C

DATE of COMPLIANCE 10/9/84

Inspector Sapienza

D506

LE CLAIR-FLEMING



MECHANICAL PIPING & HVAC

283 ORCHARD STREET
ROCHESTER, NEW YORK 14606
(716) 663-2940

Mr. Joseph Sapienza
City of Rochester
Fire Department
Public Safety Building
Rochester, New York 14614

May 3, 1984

Dear Mr. Sapienza;

I am informing you that on or before May 16, 1984 we
LeClair-Fleming will begin activate and repairing
sprinklers on Joseph Stern Roofing Co. at 176 Anderson Ave.
Rochester, New York 14610. And job will be completed 60
days there after.

If any problems arise please feel free to contact us.

Thank you for your help and coopectation.

Sincerely,

Glenn H. LeClair
Glenn H. Leclaire

GHL/bk

*Test & Material Certificate after complete air @
(200lbs 2 hrs)*



*Glen
LeClair*
~~663-2940~~
663-2940

NOTICE OF VIOLATIONS

Date MAY 11, 1983

JOSEPH STERN & SONS INC
Name

176 ANDERSON AVE
Address

Inspection of premises located at SAME
reveals violations of the Fire Prevention Code. Orders are hereby issued for for correc-
tion of hazards listed herewith on or before: MAY 18, 1983

ATTENTION: GARY STERN
461-2380

OK

1. F 204-11.2a

SPRINKLER SYSTEMS SHALL BE MAINTAINED IN
CONDITION FREE FROM MECHANICAL INJURY, STOPPAGE
OR WATER FAILURE OR OBSTRUCTIONS.

OK

2. F 204-11.2b

VALVES CONTROLLING WATER SUPPLY TO SPRINKLER
SECURED IN THE OPEN POSITION.

OK

F 204-11.1f

FIRE DEPARTMENT CONNECTION LOCATED IN ROOM
SHALL BE MAINTAINED IN WORKING ORDER CAPS
INSTALLED TO PROTECT THIS CONNECTION. OR 5-6

OK

F 204-11.5

PORTABLE FIRE EXTINGUISHERS SHALL BE APPROPRIATE IN SIZE
TYPE AND LOCATION SHALL BE IN THERE DESIGNATED
EASILY VISIBLE. (THEY SHOULD BE ACCESSIBLE 75' IN
ROOMS)

By Order of
FIRE MARSHAL

DATE of COMPLIANCE

4/12/85

Joseph A. ...
Inspector

Inspector

Joseph A. ...



LECLAIRE-FLEMING CO.

MECHANICAL PIPING & HVAC
284 COTTAGE STREET ROCHESTER, NEW YORK 14611
(716) 663-2940

April 9, 1985

Stern Roofing Co.
176 Anderson Ave.
Rochester, New York 14610

To Whom it may Concern:

Dry Sprinkler System at 176 Anderson Ave.
was operational and system activated as of April 4, 1985.

Sincerely,

Glenn H. LeClaire
LeClaire-Fleming Plumbing
and Heating

POST IN A CONSPICUOUS PLACE

Permit for the Storage and Sale of Explosives and Combustibles

16232

DEPARTMENT OF PUBLIC SAFETY
BUREAU OF BUILDINGS

Plat Plan No.

Rochester, N. Y., July 11th 1940. 19 .

Permission is hereby granted to..... Frankel Brothers & Company, Inc. of
 ... 176 Anderson Avenue 7 ... Rochester, N. Y., to sell and store GASOLINE.....
 at No. " " Street. This Permit will expire... Mar. 1 1941 .
 Public Station? Bulk? Wholesale? or Private Use?..... Private
 If for Renewal, Transfer, or Additional Storage, give former Permit No.
 Number and Capacity of Tanks 1-550
 Total Quantity Gallons. Number of Pumps 1

..... Thomas C. Woods
 Commissioner of Public Safety.

..... Walker S. Lee
 Superintendent of Buildings.

This Permit is granted on the express condition that the said Explosives or Combustibles are kept in an approved receptacle or apartment used exclusively for that purpose, approved by the Bureau, and not in proximity to Gas, Oil, Arc Lights or Stoves or any open flame; that signs "NO SMOKING," be placed in a conspicuous place on the premises where said Explosives or Combustibles are kept; that for other than Private Use approved foam extinguishment shall be provided.

Renewal, Additional Storage, Transfer

Permit Number	Date	Number and Capacity of Tanks	Number of Pumps
16412	FEB 19 1941		
17522	MAR 1 1942		
18888	MAR 1 1943		
19695	MAR 1 1944		
20840	MAR 1 1945		
22172	MAR 1 1946		
23071	MAR 1 1947		
24370	MAR - 1 1948		
25250	MAR 1 1949	Frankel Bros. Co. Inc.	
26507	FEB 28 1950		
27802	MAR 14 1951		
28541	MAR 1 - 1952		
29427	MAR 1 1953		
30375	MAR 1 1954		



NOTICE OF VIOLATIONS

Date Mar 14 1983

Joseph W. Turner & Sons Inc

Name

Address

Inspection of premises located at 176 Anderson Ave

reveals violations of the Fire Prevention Code. Orders are hereby issued for for correction of hazards listed herewith on or before: June 14 19 83

Price Warner 461-2380

54-22J

(OK) Under ground tanks which contain or have contained a flammable liquid and are to be discontinued from service shall be removed from the site within ninety (90) days.

Tank to be put back into service - tested OK

OK to file

FD506

By Order of
FIRE MARSHAL

Joseph W. Turner & Sons Inc
Robert Thompson
Inspector

DATE of COMPLIANCE 6/28/83

Inspector Joseph W. Turner