7

Fire Safety Division

Location 274 N. GOODMAN ST

Construction MASONRY & FRAME Stories 4 Length 450' Width 350'

Use of Bldg.

Fire Extinguishers: No. and Kind SODA & ACID - CO^2 DRY POWDER 12 SPRINKLER - SHUT-OFF

Floor Openings Other Than Stairs or Elevators: AIR-SHAFT IN BLDG # 1

How Protected?

Heating Apparatus: Type RG&E STEAM

Location of Floor Drains: NONE

How Can Access Be Gained to Basement? NONE

Main Electrical Switch: BOILER ROOM BLDG #3 - CENTER OF SOUTH WALL - RG&E ROOM

Water Main Shut Off: BLDG # 2 1ST FLOOR - S.W. CORNER -

Gas Shut Off: BLDG #1 1ST FLOOR FRONT

Air Conditioning Shut Off: BLDG. # 3

Special Conditions:

BOOSTER PUMP FOR SPRINKLER - BLDG # ~~4~~ LABEL DEPT. 90LBS.

FD200

Owner	Address	TEL. No.
HERB LOCHNER	1305 CALKING RD.	334-9769

DATE OF INSPECTION	INSPECTOR	Co.	PERSON INTERVIEWED	VIOLATIONS
10-14-76	LIEUT. HOLLEY	TR4	WALTER- McILMOYLE	
5-15-78	Lt. Pettine	T-4		

REMARKS