

**FIRE SAFETY INSPECTION RECORD**


- LICENSE
- PERMIT
- COMPLAINT/REFERRAL
- EAST
- WEST
- SPECIAL



320 GOODMAN ST N

LOCATION: U OF R OPERA DEPT/SCENE SHOP

**PERSON CONTACTED:**

DATE RECEIVED IN FIRE SAFETY	TIME OF INSPECTION	NO ENTRY	# ORDERS ISSUED	# REFERRALS ISSUED	NO WORK DONE	# VIOLATIONS CORRECTED	NO VIOLATIONS NOTED	TELEPHONE#: OWNER NAME: _____ OWNER ADDRESS: _____ OWNER PHONE: _____	OK TO FILE	INSPECTOR
DATE								NOTES		
12-19-13			1					1 VIOLATION / 1 ORDER		
1-14-14						1		Chicago Permit		

	Y	N
Sprinkler System	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Alarm Permit	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Cooking Hood	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Fire Alarm System	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Standpipe System	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Cooking System	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Bars/Wires on Windows	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Lock Box	<input checked="" type="checkbox"/>	<input type="checkbox"/>
NFPA 901 Type	751	
Building Const Type	3	
Number of Stories	1	
Posted Occupancy		

Permit#: \_\_\_\_\_  
Local Central (circle one)

APPROVED  
FIRE SAFETY DIVISION  
  
Fire Marshal





# City of Rochester

Fire Department  
185 Exchange Blvd., Ste 665  
Rochester, New York 14614-2124  
www.cityofrochester.gov



Fire Safety  
Division

January 8, 2014

COPY

University of Rochester  
Mark Cavanaugh, CFPS, CHSP  
Director/Fire Marshal/Chief Safety Officer  
Environmental Health & Safety  
685 Mt Hope Avenue  
RC Box 278878  
Rochester, NY 14627

Reference: **U OF R OPERA DEPT / SCENE SHOP – 320 N GOODMAN STREET**

On 12/19/2013 an inspection was conducted as part of the application process for your Fire Department Permit. The following violation of the New York State Fire Code was found and must be corrected before your permit can be approved. Orders are hereby issued for **immediate correction** of violations listed herein. Compliance shall be verified by the Fire Marshal.

Failure to comply with these orders may result in issuance of Municipal Code Violation Ticket with following penalties:


	INITIAL	FAILURE TO RESPOND
1 <sup>st</sup> Offense	\$75.00	\$150.00
2 <sup>ND</sup> Offense	\$150.00	\$300.00
3 <sup>RD</sup> & Subsequent	\$375.00	\$750.00

**Violation Code:** 906.2

**Violation Description:** Extinguishers: portable (outdated inspection tag) annually.

**Violation Summary/Location:** Shop area.

If you have any questions regarding this inspection or any other Fire Safety issue, please contact Fire Safety Inspector Thomas Tambe at (585)428-3685.

BY ORDER OF  
FIRE MARSHAL  , Fire Safety Inspector

XC:

Gary & Marcia Stern Family LTD  
274 N Goodman St  
Rochester, NY 14607

